

SONG TU TAY, Viet Nam

WMO: 488920

Lat: 11.428N

Lon: 114.331E

Elev: 5

StdP: 101.26

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.4	24.8	20.3	15.0	26.0	21.1	15.8	26.3	9.3	27.0	9.0	26.5	3.8	20	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	4.1	33.6	28.1	32.9	27.8	32.3	27.5	28.6	32.3	28.2	31.7	28.0	31.3	2.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.6	31.1	27.2	23.0	30.6	27.0	22.7	30.4	92.6	32.6	90.9	32.0	89.5	31.5	31.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	8.1	7.2	23.3	35.5	1.3	1.6	22.3	36.6	21.6	37.5	20.8	38.4	19.9	39.6		
			20.4	29.3	1.9	0.8	19.0	29.8	17.9	30.3	16.9	30.7	15.5	31.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.8	27.6	27.8	28.9	30.0	30.4	29.3	28.7	28.8	28.6	28.7	28.7	27.9	
	DBStd	1.45	1.10	1.04	1.06	1.23	1.44	1.30	1.12	1.15	1.20	1.27	1.35	1.27	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	6856	547	499	586	599	631	579	580	584	558	578	560	554	
	CDD18.3	3814	289	266	327	349	373	329	322	326	308	320	310	296	
	CDH23.3	44071	2854	2604	3606	4330	4900	4120	3841	3863	3622	3699	3543	3088	
	CDH26.7	15853	597	578	1191	1950	2440	1746	1399	1424	1268	1286	1213	761	
Wind	WSAvg	3.4	4.5	3.9	3.1	2.1	2.2	3.3	3.7	3.9	3.5	2.5	3.4	4.3	
Precipitation	PrecAvg	2388	114	57	60	51	162	287	274	225	299	222	301	314	
	PrecMax	4144	614	336	448	372	526	647	653	698	579	494	1073	1144	
	PrecMin	1456	5	0	0	0	7	106	43	49	47	39	33	9	
	PrecStd	621	132	79	104	75	135	143	148	134	145	114	216	296	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.5	31.7	32.9	34.2	34.7	33.6	32.3	32.2	32.4	32.7	32.7	31.9	
		MCWB	26.7	26.5	27.3	27.9	28.9	28.2	27.4	27.8	27.9	27.8	27.9	27.3	
	2%	DB	30.6	30.9	32.1	33.3	33.8	32.5	31.5	31.5	31.5	31.9	32.0	31.0	
		MCWB	26.3	26.2	26.9	27.6	28.4	27.8	27.2	27.5	27.5	27.4	27.6	26.9	
	5%	DB	29.9	30.2	31.4	32.6	33.1	31.7	30.8	30.9	30.9	31.2	31.2	30.2	
		MCWB	26.0	25.9	26.6	27.4	28.1	27.5	27.1	27.2	27.1	27.1	27.3	26.6	
	10%	DB	29.2	29.5	30.7	31.9	32.4	31.0	30.2	30.3	30.3	30.5	30.5	29.5	
		MCWB	25.6	25.7	26.3	27.1	27.8	27.3	26.9	27.0	26.9	26.8	27.0	26.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	27.4	27.8	28.6	29.7	28.6	28.1	28.3	28.5	28.2	28.4	27.9
			MCDB	30.6	30.5	31.8	33.1	33.5	32.2	31.1	31.2	31.6	31.6	31.7	31.0
2%		WB	26.8	26.7	27.2	28.1	28.9	28.1	27.7	27.7	27.8	27.7	27.9	27.2	
		MCDB	29.7	29.7	31.1	32.3	32.8	31.3	30.5	30.4	30.7	31.0	31.2	30.1	
5%		WB	26.3	26.3	26.9	27.7	28.4	27.7	27.4	27.5	27.4	27.3	27.5	26.8	
		MCDB	28.9	29.0	30.6	31.6	32.0	30.7	30.0	30.1	30.1	30.3	30.6	29.5	
10%		WB	26.0	26.0	26.5	27.3	28.0	27.5	27.1	27.2	27.1	27.0	27.1	26.5	
		MCDB	28.3	28.5	29.9	31.0	31.5	30.4	29.6	29.6	29.6	29.8	30.0	28.9	
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.9	4.5	4.7	4.1	3.1	3.0	3.0	3.2	3.7	3.6	3.1	
		MCDBR	4.3	4.8	5.2	5.2	4.8	4.2	3.7	3.6	4.1	4.6	4.6	4.1	
		MCWBR	2.1	2.2	2.2	1.9	1.8	1.5	1.5	1.4	1.8	2.0	2.1	2.0	
	5% WB	MCDBR	3.9	4.3	5.0	5.2	4.7	3.5	3.4	3.3	3.8	4.3	4.4	3.9	
		MCWBR	1.9	2.1	2.2	2.0	2.0	1.6	1.7	1.5	1.9	2.0	2.2	2.0	
Clear-Sky Solar Irradiance	taub	0.472	0.438	0.449	0.437	0.427	0.440	0.461	0.467	0.452	0.452	0.474	0.512		
	taud	2.285	2.400	2.387	2.428	2.495	2.475	2.396	2.364	2.403	2.400	2.301	2.147		
	Ebn at Noon	834	880	874	875	868	847	832	838	858	856	826	784		
	Edh at Noon	132	122	125	120	110	110	120	126	122	120	129	149		
All-Sky Solar Radiation	RadAvg	4.58	5.72	6.30	6.74	5.95	4.92	4.81	5.21	4.82	5.03	4.62	3.98		
	RadStd	0.55	0.44	0.54	0.41	0.64	0.61	0.48	0.46	0.66	0.53	0.56	0.65		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page