

RACH GIA, Viet Nam

WMO: 489070

Lat: 10.000N

Lon: 105.083E

Elev: 10

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	71.5	73.2	62.7	85.2	74.3	65.0	92.7	76.8	15.0	80.6	12.3	81.0	3.9	20	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.7	91.9	79.3	90.7	79.3	89.7	79.4	82.4	88.1	81.8	87.4	81.4	86.9	7.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	159.9	86.3	80.1	156.3	85.8	79.8	154.6	85.5	46.2	88.6	45.6	87.8	45.2	87.3	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.0	18.2	16.2	DB	68.8	93.6	1.8	1.2	67.4	94.4	66.4	95.1	65.4	95.8	64.0	96.6	
			WB	64.0	83.6	2.3	1.3	62.3	84.5	60.9	85.3	59.6	86.1	57.9	87.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	79.6	80.5	82.9	84.8	84.7	83.5	82.6	82.6	82.4	82.4	82.2	80.2
	DBStd	2.56	2.01	1.82	1.61	1.90	2.28	2.29	2.14	2.03	1.98	1.71	1.80	2.68
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11815	917	855	1021	1043	1074	1005	1012	1012	971	1004	965	936
	CDD65	6340	452	435	556	593	609	555	547	547	521	539	515	471
	CDH74	72856	4024	4239	6517	7691	7940	6888	6513	6477	6043	6144	5790	4590
	CDH80	25618	906	1256	2518	3488	3552	2710	2232	2170	1915	1924	1796	1151
Wind	WSAvg	7.1	4.6	5.0	5.8	5.9	7.5	9.5	10.7	11.1	9.6	5.4	4.7	4.9
Precipitation	PrecAvg	84.9	0.5	0.4	0.9	3.1	8.9	11.7	14.1	12.2	11.4	12.1	7.4	2.2
	PrecMax	114.1	1.8	1.7	4.0	15.9	14.5	19.3	28.0	20.6	19.4	21.8	15.7	6.0
	PrecMin	62.0	0.0	0.0	0.0	0.0	3.2	6.1	5.5	5.6	4.4	4.0	2.3	0.2
	PrecStd	13.5	0.6	0.6	1.2	3.5	3.1	2.6	5.9	3.7	3.9	4.0	3.2	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.3	89.9	92.4	93.6	93.5	90.8	89.7	89.0	89.6	90.3	89.9	89.0
		MCWB	77.0	76.3	77.1	79.3	80.8	81.5	80.9	80.6	80.2	78.6	78.4	77.8
	2%	DB	86.8	88.4	90.8	92.2	91.5	89.3	88.0	87.6	88.0	88.8	88.5	87.3
		MCWB	76.7	76.4	77.2	79.3	81.0	81.2	80.5	80.4	79.9	78.7	78.3	77.3
	5%	DB	85.5	87.1	89.5	90.9	90.0	88.1	86.9	86.7	86.8	87.4	87.5	86.2
		MCWB	76.2	76.3	77.2	79.3	81.0	80.9	80.2	80.2	79.7	78.7	78.1	77.0
	10%	DB	84.3	85.9	88.3	89.6	88.8	87.1	86.0	85.9	85.8	86.4	86.4	85.1
		MCWB	75.8	76.1	77.3	79.4	80.9	80.6	80.0	80.0	79.6	78.7	77.9	76.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.8	79.0	80.9	82.8	83.1	82.8	81.9	81.8	81.7	81.0	80.3	79.2
		MCDB	84.9	85.4	88.1	88.4	89.0	87.8	86.9	86.6	87.1	85.9	86.0	85.1
	2%	WB	77.9	78.1	80.0	81.9	82.4	81.9	81.3	81.0	80.9	80.1	79.7	78.7
		MCDB	84.0	84.9	87.0	88.1	88.5	87.1	86.1	85.6	85.9	85.3	85.3	84.6
	5%	WB	77.3	77.4	79.3	81.1	81.8	81.6	80.8	80.7	80.4	79.8	79.1	78.1
		MCDB	83.3	84.5	86.2	87.6	87.8	86.7	85.5	85.3	85.1	84.9	84.7	83.8
	10%	WB	76.6	76.8	78.6	80.6	81.4	81.0	80.4	80.3	80.0	79.3	78.7	77.5
		MCDB	82.5	84.1	85.5	87.3	87.3	86.1	85.0	84.8	84.6	84.3	84.3	83.0
Mean Daily Temperature Range	5% DB	MDBR	9.8	11.7	11.5	9.7	7.3	5.9	5.4	5.0	5.6	7.2	8.0	8.7
		MCDBR	10.9	12.8	13.1	11.7	9.3	7.0	6.3	6.1	7.3	9.4	9.6	9.8
		MCWBR	3.6	3.8	3.2	3.1	3.1	3.1	3.1	2.9	3.0	2.9	2.8	3.0
	5% WB	MCDBR	9.9	11.3	10.3	8.8	7.4	6.3	5.7	5.5	6.0	7.5	8.5	9.0
		MCWBR	3.7	4.1	3.8	3.6	3.4	3.4	3.2	3.1	3.1	3.1	3.0	3.1
Clear-Sky Solar Irradiance	taub	0.522	0.531	0.553	0.515	0.453	0.451	0.454	0.453	0.451	0.494	0.488	0.501	
	taud	2.053	2.023	2.008	2.144	2.369	2.401	2.382	2.378	2.377	2.245	2.233	2.149	
	Ebn at Noon	251	253	250	257	268	265	266	269	273	260	259	253	
	Edh at Noon	53	56	58	50	39	37	38	39	40	45	44	48	
All-Sky Solar Radiation	RadAvg	1605	1804	1868	1858	1618	1517	1448	1483	1467	1485	1532	1507	
	RadStd	85	73	86	94	135	89	113	104	113	117	92	93	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+0.41	+0.63	N/A	N/A	N/A	+0.34	N/A	N/A	N/A	N/A

Nomenclature: See separate page