

CA MAU, Viet Nam

WMO: 489140

Lat: 9.183N

Lon: 105.150E

Elev: 2

StdP: 101.30

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.3	23.0	17.9	12.9	25.5	19.1	13.9	26.4	6.3	29.3	5.6	29.2	0.9	0	0.331

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.4	33.9	26.3	33.3	26.2	32.8	26.1	27.4	30.6	27.2	30.4	27.0	30.2	2.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	28.5	26.4	21.9	28.4	26.2	21.6	28.2	86.9	30.9	85.6	30.6	84.8	30.4	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.3	4.5	4.1	DB	20.8	35.2	1.5	1.1	19.8	36.0	18.9	36.6	18.1	37.2	17.0	38.0	
			WB	18.4	28.8	1.6	1.1	17.2	29.6	16.3	30.3	15.4	30.9	14.3	31.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.2	26.9	27.4	28.6	29.7	29.5	28.6	28.2	28.2	28.0	27.9	27.9	27.1
	DBStd	1.45	1.09	0.94	0.94	1.02	1.38	1.36	1.33	1.32	1.33	1.09	0.98	1.38
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6630	522	488	578	591	603	558	563	539	557	538	529	529
	CDD18.3	3588	264	254	320	341	345	308	305	304	289	298	288	271
	CDH23.3	38323	2315	2411	3565	4198	4166	3469	3298	3258	3002	3054	3020	2568
	CDH26.7	13037	591	731	1336	1876	1784	1258	1082	1057	901	871	886	665
Wind	WSAvg	1.6	1.8	1.9	1.8	1.4	1.3	1.4	1.5	1.6	1.5	1.3	1.6	1.8
Precipitation	PrecAvg	2340	21	14	28	88	211	316	337	315	356	371	218	66
	PrecMax	3347	108	95	231	425	402	534	508	509	634	724	370	255
	PrecMin	1861	0	0	0	0	90	170	166	148	183	124	51	1
	PrecStd	302	28	24	53	90	73	93	97	87	114	149	90	62
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	32.4	33.7	34.6	35.0	33.7	33.1	33.0	32.9	32.5	32.1	31.8
		MCWB	24.8	24.9	25.3	26.3	26.6	26.6	26.3	26.3	26.2	26.0	25.8	25.3
	2%	DB	30.9	31.5	32.8	33.9	34.0	32.9	32.3	32.3	32.2	31.8	31.5	31.1
		MCWB	24.5	24.6	25.3	26.2	26.5	26.5	26.3	26.3	26.1	25.9	25.7	25.0
	5%	DB	30.2	30.9	32.2	33.3	33.2	32.2	31.7	31.7	31.5	31.2	31.0	30.5
		MCWB	24.3	24.5	25.2	26.0	26.5	26.4	26.2	26.2	26.1	25.9	25.6	24.9
	10%	DB	29.5	30.3	31.5	32.7	32.4	31.5	31.0	31.0	30.7	30.5	30.4	29.8
		MCWB	24.1	24.3	25.1	25.9	26.5	26.4	26.2	26.2	26.0	25.9	25.5	24.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.9	25.9	26.7	27.6	27.8	27.7	27.2	27.2	27.1	27.0	26.7	26.4
		MCDB	30.1	30.6	30.5	31.5	31.1	30.4	30.1	30.4	30.2	30.0	29.9	30.0
	2%	WB	25.3	25.4	26.2	27.1	27.5	27.2	27.0	26.8	26.7	26.7	26.4	26.0
		MCDB	29.1	29.6	30.1	31.0	30.7	30.1	29.9	29.8	29.7	29.5	29.4	29.2
	5%	WB	25.0	25.1	25.9	26.7	27.2	27.0	26.7	26.6	26.5	26.4	26.2	25.6
		MCDB	28.5	29.0	29.9	30.6	30.5	30.0	29.5	29.6	29.4	29.1	29.0	28.7
	10%	WB	24.7	24.7	25.6	26.5	27.0	26.7	26.5	26.5	26.2	26.2	26.0	25.3
		MCDB	28.0	28.5	29.5	30.4	30.3	29.6	29.3	29.3	29.0	28.8	28.7	28.2
Mean Daily Temperature Range	5% DB	MDBR	5.7	6.1	6.2	6.4	5.9	5.4	5.3	5.3	5.0	5.0	5.0	5.1
		MCDBR	6.3	6.6	6.8	7.0	6.8	6.3	6.1	6.1	6.0	5.9	5.6	5.8
		MCWBR	1.9	1.6	1.5	1.4	1.6	1.7	1.7	1.6	1.6	1.6	1.5	1.6
	5% WB	MCDBR	5.6	6.1	6.3	6.4	6.1	5.7	5.5	5.5	5.4	5.3	5.2	5.3
		MCWBR	1.9	1.7	1.6	1.7	1.9	2.0	2.1	1.9	1.8	1.8	1.7	1.7
Clear-Sky Solar Irradiance	taub	0.499	0.499	0.512	0.475	0.440	0.445	0.448	0.448	0.444	0.475	0.482	0.500	
	taud	2.162	2.153	2.158	2.291	2.433	2.438	2.419	2.404	2.408	2.319	2.265	2.175	
	Ebn at Noon	814	829	822	842	855	840	841	853	868	840	825	804	
	Edh at Noon	151	157	158	137	116	114	117	121	121	131	136	147	
All-Sky Solar Radiation	RadAvg	5.08	5.84	6.12	6.09	5.08	4.66	4.48	4.66	4.55	4.59	4.73	4.65	
	RadStd	0.31	0.27	0.31	0.33	0.44	0.32	0.38	0.34	0.37	0.43	0.33	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.37	+0.64	N/A	N/A	+0.18	+0.22	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.33	+0.59	N/A	+0.32	+0.17	+0.16	N/A	N/A	N/A	N/A

Nomenclature: See separate page