

PHU QUOC, Viet Nam

WMO: 489170

Lat: 10.217N

Lon: 103.967E

Elev: 13

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	70.7	72.5	58.6	73.5	77.9	61.1	80.6	78.9	20.2	80.0	18.0	80.1	3.9	90	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.3	91.7	80.1	90.6	79.8	89.7	79.5	82.6	88.3	81.9	87.5	81.5	87.0	7.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	160.7	86.2	80.4	157.8	86.0	79.9	155.3	85.6	46.4	88.5	45.8	88.1	45.3	87.4	91.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.5	18.6	16.7	65.6	94.7	4.2	2.4	62.6	96.5	60.2	97.9	57.8	99.3	54.8	101.0
			61.3	84.4	2.7	1.8	59.4	85.6	57.8	86.7	56.3	87.7	54.4	89.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	80.2	81.1	82.9	84.0	84.0	82.8	82.0	81.9	81.5	81.6	82.0	80.8
	DBStd	2.23	2.10	2.04	1.95	1.69	2.13	2.17	2.04	1.99	1.79	1.56	1.53	2.06
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11702	938	870	1021	1019	1053	985	991	989	944	978	959	955
	CDD65	6227	473	450	556	569	588	535	526	524	494	513	509	490
	CDH74	69323	4463	4522	6393	7068	7459	6429	6035	5991	5385	5290	5418	4870
CDH80	23752	1281	1458	2469	3014	3193	2385	1936	1855	1484	1520	1725	1432	
Wind	WSAvg	6.7	5.2	5.0	5.1	5.0	6.9	8.7	9.5	10.2	8.6	5.0	5.2	6.2
Precipitation	PrecAvg	108.1	1.2	0.8	2.4	5.7	9.0	14.6	17.0	17.5	18.7	12.7	6.1	2.2
	PrecMax	153.0	4.2	3.5	7.2	16.9	15.2	26.8	32.3	35.9	30.2	26.7	13.6	6.4
	PrecMin	75.7	0.0	0.0	0.0	0.2	3.1	6.5	7.3	8.0	8.6	6.0	0.4	0.0
	PrecStd	16.3	1.1	1.1	2.2	3.5	2.6	4.8	6.3	6.5	5.6	5.2	3.6	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.3	90.5	92.3	93.3	93.4	91.4	89.8	89.5	89.6	90.0	89.8	89.6
		MCWB	76.9	77.3	78.0	80.1	81.4	81.5	81.0	80.5	80.6	78.7	78.6	77.2
	2%	DB	87.9	88.8	90.5	91.6	91.6	89.5	88.1	87.8	87.9	88.8	88.8	88.2
		MCWB	76.1	76.7	78.0	79.9	81.2	81.2	80.6	80.3	80.3	78.6	78.1	76.8
	5%	DB	86.7	87.6	89.3	90.4	90.0	88.0	87.0	86.4	86.4	87.6	87.9	87.3
		MCWB	75.7	76.4	78.0	79.8	81.0	80.9	80.3	80.1	79.9	78.7	77.8	76.3
	10%	DB	85.7	86.4	88.1	89.4	88.9	87.0	85.9	85.5	85.3	86.3	86.9	86.1
		MCWB	75.3	75.9	77.9	79.8	80.9	80.6	79.9	79.8	79.5	78.7	77.4	75.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.8	79.9	81.0	82.7	83.6	83.0	82.4	81.9	81.9	81.3	81.0	80.3
		MCDB	85.5	86.8	87.8	89.7	89.5	88.3	87.0	86.6	86.8	86.3	86.2	86.2
	2%	WB	78.5	78.9	80.2	81.8	82.7	82.1	81.5	81.1	80.9	80.4	80.1	79.1
		MCDB	84.7	85.6	87.0	88.9	88.7	87.2	86.0	85.5	85.8	85.8	85.8	85.1
	5%	WB	77.7	78.1	79.6	81.1	82.1	81.6	80.9	80.7	80.4	79.9	79.3	78.3
		MCDB	83.9	84.8	86.5	88.1	88.0	86.6	85.4	85.1	85.0	85.0	85.1	84.3
	10%	WB	77.0	77.4	79.0	80.6	81.6	81.0	80.4	80.1	79.9	79.3	78.8	77.5
		MCDB	83.3	84.1	85.9	87.5	87.4	86.0	84.9	84.4	84.3	84.2	84.5	83.2
Mean Daily Temperature Range	5% DB	MDBR	11.8	12.2	11.5	11.2	9.3	7.8	7.4	6.7	7.2	9.3	10.1	10.8
		MCDBR	12.5	13.1	12.7	13.0	11.6	9.2	9.0	8.1	9.4	11.7	11.3	12.2
		MCWBR	5.3	5.2	4.8	5.1	5.2	4.5	4.6	4.3	4.6	4.7	4.5	5.3
	5% WB	MCDBR	11.8	12.2	11.8	11.6	9.9	8.3	7.9	7.2	8.2	10.0	10.8	11.4
		MCWBR	5.7	5.7	5.2	5.1	5.0	4.6	4.7	4.2	4.5	4.7	4.9	5.5
Clear-Sky Solar Irradiance	taub		0.533	0.546	0.564	0.523	0.454	0.454	0.457	0.455	0.448	0.483	0.480	0.492
	taud		2.059	2.020	2.022	2.157	2.402	2.426	2.400	2.401	2.408	2.298	2.280	2.211
	Ebn at Noon		247	250	247	255	268	265	265	269	274	264	261	256
	Edh at Noon		53	57	57	50	38	36	38	38	38	43	42	45
All-Sky Solar Radiation	RadAvg		1656	1846	1904	1884	1606	1475	1391	1419	1410	1504	1590	1574
	RadStd		82	88	97	105	140	100	136	121	140	126	87	79

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	+0.40	N/A	N/A	+0.67	+0.29	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+0.54	+0.81	N/A	N/A	+0.32	+0.32	N/A	N/A	N/A	N/A

Nomenclature: See separate page