

PHU QUOC, Viet Nam

WMO: 489170

Lat: 10.217N

Lon: 103.967E

Elev: 4

StdP: 101.28

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.5	22.5	14.8	10.5	25.5	16.2	11.5	26.1	9.0	26.7	8.0	26.7	1.7	90	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.2	33.1	26.7	32.6	26.5	32.1	26.4	28.1	31.3	27.7	30.8	27.5	30.6	3.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.1	26.9	22.5	30.0	26.6	22.2	29.8	90.1	31.4	88.6	31.2	87.4	30.8	33.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.3	7.4	DB	18.7	34.9	2.3	1.4	17.0	35.8	15.6	36.6	14.3	37.4	12.7	38.4	(4)
(5)			WB	16.3	29.1	1.5	1.0	15.2	29.8	14.3	30.4	13.5	30.9	12.4	31.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	26.8	27.3	28.3	28.9	28.2	27.8	27.7	27.5	27.5	27.8	27.1	(6)	
(7)		DBStd	1.24	1.17	1.13	1.08	0.94	1.18	1.20	1.13	1.11	0.99	0.86	0.85	1.15	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6501	521	483	567	566	585	547	551	549	524	543	533	531	(10)
(11)		CDD18.3	3459	263	250	309	316	327	297	292	291	274	285	283	272	(11)
(12)		CDH23.3	38513	2479	2512	3552	3927	4144	3572	3353	3328	2992	2939	3010	2706	(12)
(13)	CDH26.7	13196	712	810	1372	1674	1774	1325	1076	1031	824	844	958	796	(13)	
(14)	Wind	WSAvg	3.0	2.3	2.2	2.3	2.2	3.1	3.9	4.3	4.6	3.8	2.2	2.3	2.8	(14)
(15)	Precipitation	PrecAvg	2745	30	21	61	146	228	372	433	445	475	323	154	56	(15)
(16)		PrecMax	3886	106	89	184	430	385	681	820	911	766	677	346	162	(16)
(17)		PrecMin	1923	0	1	1	5	78	164	186	204	219	152	9	1	(17)
(18)		PrecStd	414	29	28	55	88	66	122	161	166	141	131	92	40	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	32.5	33.5	34.1	34.1	33.0	32.1	31.9	32.0	32.2	32.1	32.0	(19)
MCWB			25.0	25.2	25.5	26.7	27.5	27.5	27.2	26.9	27.0	25.9	25.9	25.1	(20)	
2%		DB	31.0	31.6	32.5	33.1	33.1	31.9	31.1	31.0	31.1	31.6	31.5	31.2	(21)	
		MCWB	24.5	24.8	25.6	26.6	27.3	27.3	27.0	26.9	26.8	25.9	25.6	24.9	(22)	
5%		DB	30.4	30.9	31.9	32.5	32.2	31.1	30.5	30.2	30.2	30.9	31.1	30.7	(23)	
		MCWB	24.3	24.7	25.6	26.6	27.2	27.2	26.8	26.7	26.6	26.0	25.4	24.6	(24)	
10%		DB	29.8	30.2	31.2	31.9	31.6	30.5	29.9	29.7	29.6	30.1	30.5	30.0	(25)	
		MCWB	24.1	24.4	25.5	26.5	27.2	27.0	26.6	26.6	26.4	26.0	25.2	24.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.6	27.2	28.2	28.7	28.3	28.0	27.7	27.4	27.2	26.8	(27)	
MCD B			29.7	30.4	31.0	32.0	32.0	31.3	30.6	30.3	30.4	30.2	30.1	30.1	(28)	
2%		WB	25.9	26.0	26.8	27.7	28.2	27.8	27.5	27.3	27.2	26.9	26.7	26.2	(29)	
		MCD B	29.3	29.8	30.6	31.6	31.5	30.7	30.0	29.7	29.9	29.9	29.9	29.5	(30)	
5%		WB	25.4	25.6	26.4	27.3	27.8	27.6	27.2	27.1	26.9	26.6	26.3	25.7	(31)	
		MCD B	28.9	29.3	30.3	31.2	31.1	30.4	29.7	29.5	29.5	29.5	29.5	29.0	(32)	
10%		WB	25.0	25.2	26.1	27.0	27.5	27.2	26.9	26.7	26.6	26.3	26.0	25.3	(33)	
		MCD B	28.5	28.9	30.0	30.8	30.8	30.0	29.4	29.1	29.1	29.0	29.2	28.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	6.8	6.4	6.2	5.2	4.3	4.1	3.7	4.0	5.2	5.6	6.0	(35)
MCDBR			7.0	7.3	7.0	7.2	6.5	5.1	5.0	4.5	5.2	6.5	6.3	6.8	(36)	
MCWBR			3.0	2.9	2.7	2.8	2.9	2.5	2.6	2.4	2.6	2.6	2.5	2.9	(37)	
5% WB		MCDBR	6.6	6.8	6.5	6.4	5.5	4.6	4.4	4.0	4.6	5.5	6.0	6.3	(38)	
		MCWBR	3.1	3.2	2.9	2.8	2.8	2.6	2.6	2.3	2.5	2.6	2.7	3.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.533	0.546	0.564	0.523	0.454	0.454	0.457	0.455	0.448	0.483	0.480	0.492	(40)	
taud		2.059	2.020	2.022	2.157	2.402	2.426	2.400	2.401	2.408	2.298	2.280	2.211	(41)		
Ebn at Noon		780	787	779	803	844	834	834	848	863	831	823	808	(42)		
Edh at Noon		167	179	181	157	120	115	119	121	121	134	133	141	(43)		
(44)	All-Sky Solar Radiation	RadAvg	5.22	5.82	6.00	5.94	5.06	4.65	4.38	4.47	4.45	4.74	5.01	4.96	(44)	
(45)		RadStd	0.26	0.28	0.31	0.33	0.44	0.32	0.43	0.38	0.44	0.40	0.27	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.22	N/A	N/A	+0.37	+0.16	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+0.30	+0.45	N/A	N/A	+0.18	+0.18	N/A	N/A	N/A	N/A

Nomenclature: See separate page