

TRUONG SA, Viet Nam

WMO: 489200

Lat: 8.650N

Lon: 111.917E

Elev: 3

StdP: 101.29

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.7	23.8	19.8	14.5	23.8	20.8	15.4	24.8	14.4	25.0	13.8	25.3	6.4	50	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	4.3	33.5	27.9	32.8	27.6	32.2	27.3	28.3	32.2	28.0	31.8	27.7	31.2	2.9	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.9	27.0	22.6	30.7	26.7	22.3	30.3	91.3	32.5	89.7	32.0	88.5	31.6	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	11.6	10.3	DB	20.7	35.0	3.1	1.8	18.5	36.3	16.6	37.3	14.9	38.3	12.6	39.6	(4)
(5)			WB	19.7	29.0	2.5	0.4	17.8	29.2	16.3	29.4	14.9	29.7	13.1	29.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	26.7	27.3	28.2	29.4	29.7	29.0	28.5	28.7	28.5	28.3	28.1	27.2		
	DBStd	1.52	1.37	1.13	1.38	1.16	1.35	1.29	1.17	1.09	1.13	1.30	1.21	1.34		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6687	518	484	564	582	612	571	574	581	556	568	543	534		
	CDD18.3	3646	259	251	306	332	353	321	316	323	306	310	293	276		
	CDH23.3	41948	2381	2444	3391	4136	4590	4008	3759	3903	3637	3588	3308	2803		
(13)	CDH26.7	14467	379	497	1084	1787	2135	1642	1342	1466	1291	1217	1032	595		
(14)	Wind	WSAvg	5.2	7.6	6.7	5.2	3.6	3.3	4.3	5.0	5.0	4.0	5.5	7.5		
(15) Precipitation	PrecAvg	2720	171	84	105	61	138	210	282	243	268	237	360	528		
	PrecMax	4044	519	390	705	212	263	383	698	523	478	477	697	1302		
	PrecMin	1963	1	0	0	0	15	63	87	65	41	66	124	54		
	PrecStd	541	122	104	168	50	82	86	136	116	119	91	131	328		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	31.6	32.7	33.9	34.8	33.8	32.9	32.5	32.5	32.4	32.0	31.1		
		MCWB	26.6	26.6	27.2	28.0	28.6	27.7	27.4	27.5	27.6	27.5	27.5	27.3		
	2%	DB	30.1	30.7	31.9	33.2	33.8	32.7	31.8	31.7	31.7	31.7	31.2	30.2		
		MCWB	26.2	26.3	26.8	27.6	28.1	27.5	27.2	27.3	27.2	27.2	27.2	26.7		
	5%	DB	29.3	29.9	31.2	32.5	32.9	31.9	31.2	31.2	31.2	31.1	30.6	29.6		
		MCWB	25.8	26.0	26.6	27.4	27.7	27.3	27.0	27.1	27.1	26.9	27.0	26.4		
	10%	DB	28.5	29.2	30.6	31.8	32.1	31.1	30.5	30.7	30.5	30.4	30.0	29.0		
		MCWB	25.5	25.7	26.3	27.1	27.4	27.2	26.8	26.9	26.9	26.7	26.7	26.1		
	0.4%	WB	27.1	27.3	27.9	28.6	29.0	28.3	28.1	28.1	28.1	28.1	28.2	27.7		
		MCDB	30.2	30.2	31.6	32.7	33.9	32.0	31.6	31.6	31.6	31.7	31.1	30.4		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.6	26.9	27.4	28.1	28.4	28.0	27.6	27.7	27.6	27.6	27.6	27.1		
		MCDB	29.2	29.6	30.9	32.1	32.7	31.6	30.9	30.9	31.0	30.9	30.4	29.6		
	5%	WB	26.2	26.5	27.0	27.7	28.0	27.6	27.3	27.4	27.2	27.2	27.2	26.7		
		MCDB	28.4	28.9	30.4	31.5	32.0	31.0	30.3	30.4	30.3	30.4	29.9	28.9		
	10%	WB	25.9	26.1	26.6	27.3	27.7	27.3	27.0	27.1	27.0	26.8	26.9	26.4		
		MCDB	27.9	28.3	29.7	30.9	31.3	30.5	29.9	30.0	29.9	29.8	29.5	28.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	3.3	4.0	4.5	4.3	3.8	3.5	3.5	3.5	3.7	3.5	2.7		
		MCDBR	3.7	4.3	5.0	5.3	5.2	4.7	4.2	4.1	4.3	4.4	4.2	3.4		
		MCWBR	1.9	2.1	2.3	2.2	2.0	2.0	1.9	2.0	2.0	2.1	2.2	1.8		
	5% WB	MCDBR	3.3	3.9	4.4	4.9	4.7	4.2	3.9	3.8	3.9	4.1	3.9	3.2		
		MCWBR	1.9	2.1	2.3	2.3	2.2	2.1	2.1	2.0	2.1	2.2	2.2	1.9		
(40) Clear-Sky Solar Irradiance	taub		0.470	0.441	0.440	0.427	0.416	0.430	0.444	0.459	0.444	0.442	0.457	0.515		
	taud		2.314	2.408	2.430	2.471	2.525	2.503	2.449	2.388	2.423	2.436	2.378	2.154		
	Ebn at Noon		844	883	884	883	875	853	844	844	867	871	850	792		
	Edh at Noon		131	122	121	114	106	107	113	123	120	117	122	151		
(44) All-Sky Solar Radiation	RadAvg		4.45	5.67	6.19	6.53	5.84	5.01	4.93	5.25	4.93	5.04	4.49	3.68		
	RadStd		0.67	0.64	0.71	0.42	0.60	0.38	0.52	0.35	0.62	0.54	0.41	0.74		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page