

MOHE, China

WMO: 501360

Lat: 52.9744N

Lon: 122.5108E

Elev: 1437

StdP: 13.95

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.2	-38.8	-48.1	0.3	-41.8	-44.5	0.4	-38.6	16.2	-3.8	13.6	-2.9	0.6	180	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.2	86.7	66.3	83.1	65.4	79.5	64.1	70.0	80.5	68.2	77.9	66.4	75.2	6.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	103.7	74.4	64.9	97.4	72.4	63.2	91.4	70.8	35.1	80.4	33.5	78.4	32.0	75.2	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	14.5	12.3	-46.2	92.6	3.6	3.2	-48.7	94.8	-50.8	96.7	-52.9	98.5	-55.5	100.7		
(5)			-46.3	73.1	3.5	2.0	-48.8	74.6	-50.9	75.8	-52.9	76.9	-55.5	78.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.8	-17.7	-8.6	9.7	31.9	47.1	60.1	65.1	60.2	46.7	28.2	1.2	-16.0	(6)
(7)		DBStd	30.96	8.83	9.62	12.22	8.68	6.91	6.37	5.12	6.11	7.51	9.54	13.57	9.52	(7)
(8)		HDD50	10016	2099	1640	1250	546	137	5	0	5	149	676	1463	2046	(8)
(9)		HDD65	14403	2564	2060	1715	994	554	171	61	170	549	1141	1913	2511	(9)
(10)		CDD50	1198	0	0	0	2	48	308	469	321	50	0	0	0	(10)
(11)		CDD65	110	0	0	0	0	0	23	65	22	0	0	0	0	(11)
(12)		CDH74	2268	0	0	0	5	85	706	994	446	32	0	0	0	(12)
(13)		CDH80	673	0	0	0	2	20	217	320	111	3	0	0	0	(13)
(14)	Wind	WSAvg	4.2	2.6	3.0	4.8	6.2	6.2	4.6	4.1	4.1	4.7	4.7	3.3	2.3	(14)
(15)	Precipitation	PrecAvg	18.1	0.3	0.2	0.2	0.9	1.7	2.8	4.2	3.9	2.0	1.0	0.6	0.4	(15)
(16)		PrecMax	23.9	0.8	0.5	0.7	2.1	4.5	6.0	8.3	6.7	4.9	3.4	1.1	0.9	(16)
(17)		PrecMin	11.3	0.0	0.0	0.0	0.0	0.2	0.7	1.4	1.8	0.8	0.1	0.2	0.1	(17)
(18)		PrecStd	2.9	0.2	0.1	0.2	0.6	1.0	1.5	1.7	1.5	1.1	0.8	0.3	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	30.3	48.5	70.9	83.1	91.1	91.8	87.4	78.3	62.0	40.0	17.1	(19)
(20)			MCWB	9.0	24.1	35.8	48.8	57.7	66.1	68.3	68.1	59.4	47.0	32.9	14.4	(20)
(21)		2%	DB	6.7	22.0	42.0	61.5	75.4	86.0	87.4	83.2	72.9	54.4	32.3	11.1	(21)
(22)			MCWB	4.8	17.8	32.1	43.5	53.6	64.4	67.7	66.6	58.2	42.8	27.5	9.3	(22)
(23)		5%	DB	2.7	16.0	36.3	54.9	70.4	81.7	83.6	79.3	67.6	48.9	27.0	5.1	(23)
(24)			MCWB	1.3	13.2	28.7	40.7	51.7	63.1	67.0	65.9	55.2	39.4	23.7	3.8	(24)
(25)		10%	DB	-1.4	11.0	31.7	49.6	65.6	77.7	79.7	75.1	62.9	44.0	22.0	-0.2	(25)
(26)			MCWB	-2.5	8.6	25.7	37.5	49.4	61.5	66.0	63.4	52.6	36.4	19.4	-1.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	24.4	36.4	49.0	59.2	70.2	73.0	71.5	62.6	48.0	33.3	14.7	(27)
(28)			MCD B	11.8	30.2	47.6	69.4	76.8	82.3	84.4	82.9	72.9	60.6	39.6	16.7	(28)
(29)		2%	WB	4.8	18.0	32.5	44.5	56.0	67.1	70.8	69.1	60.0	43.6	27.9	9.2	(29)
(30)			MCD B	6.5	21.9	41.3	59.1	70.9	79.8	81.3	79.2	69.0	53.0	31.9	11.1	(30)
(31)		5%	WB	1.3	13.2	29.2	41.2	53.3	64.9	69.1	66.8	57.3	40.1	23.9	3.8	(31)
(32)			MCD B	2.6	16.1	36.0	54.0	67.2	77.2	78.8	75.8	64.5	47.9	26.8	5.2	(32)
(33)		10%	WB	-2.4	8.6	26.0	38.3	50.7	63.0	67.5	64.7	54.2	36.7	19.5	-1.2	(33)
(34)			MCD B	-1.3	11.0	31.6	48.3	63.1	75.1	76.2	72.6	61.5	43.5	21.9	-0.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	26.5	33.9	33.5	27.1	28.7	29.6	25.2	25.9	27.1	24.7	25.4	24.1	(35)
(36)			MCDBR	29.0	36.2	33.9	37.3	40.7	38.4	34.3	34.5	36.7	32.6	26.8	26.5	(36)
(37)			MCWBR	27.2	32.2	25.0	21.5	20.7	18.1	16.2	18.5	21.6	21.0	21.6	24.8	(37)
(38)		5% WB	MCDBR	28.9	35.9	32.3	34.6	35.1	31.8	26.9	27.8	29.8	31.6	26.4	26.3	(38)
(39)			MCWBR	27.1	31.9	23.8	20.4	18.9	16.0	14.3	15.9	18.2	20.8	21.4	24.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.253	0.283	0.331	0.457	0.510	0.476	0.449	0.409	0.360	0.328	0.287	0.262	(40)	
(41)		taud	2.145	2.105	2.045	1.874	1.860	2.064	2.202	2.296	2.372	2.322	2.169	2.069	(41)	
(42)		Ebn at Noon	230	257	266	242	236	248	253	258	258	240	211	195	(42)	
(43)		Edh at Noon	22	31	41	56	60	49	43	36	30	25	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	420	782	1306	1669	1655	1883	1640	1446	1117	731	446	317	(44)	
(45)		RadStd	16	22	56	114	126	174	150	145	97	47	21	16	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page