

MOHE, China

WMO: 501360

Lat: 52.9744N

Lon: 122.5108E

Elev: 438

StdP: 96.17

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.2	-39.3	-44.5	0.0	-41.0	-42.5	0.1	-39.2	7.2	-19.9	6.1	-19.4	0.3	180	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	30.4	19.0	28.4	18.5	26.4	17.8	21.1	26.9	20.1	25.5	19.1	24.0	2.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.8	23.5	18.3	13.9	22.4	17.3	13.1	21.6	63.7	26.9	59.9	25.8	56.5	24.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.7	6.5	5.5	-43.4	33.7	2.0	1.8	-44.9	34.9	-46.0	35.9	-47.1	36.9	-48.6	38.2		
			-43.5	22.9	2.0	1.1	-44.9	23.7	-46.1	24.3	-47.2	25.0	-48.6	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.4	-27.6	-22.5	-12.4	-0.1	8.4	15.6	18.4	15.7	8.2	-2.1	-17.1	-26.7
	DBStd	17.20	4.91	5.34	6.79	4.82	3.84	3.54	2.84	3.40	4.17	5.30	7.54	5.29
	HDD10.0	5564	1166	911	694	303	76	3	0	3	83	376	813	1137
	HDD18.3	8002	1424	1144	953	552	308	95	34	94	305	634	1063	1395
	CDD10.0	666	0	0	0	1	27	171	261	178	28	0	0	0
	CDD18.3	61	0	0	0	0	0	13	36	12	0	0	0	0
	CDH23.3	1260	0	0	0	3	47	392	552	248	18	0	0	0
	CDH26.7	374	0	0	0	1	11	121	178	62	2	0	0	0
Wind	WSAvg	1.9	1.1	1.4	2.1	2.8	2.8	2.1	1.8	1.8	2.1	2.1	1.5	1.0
Precipitation	PrecAvg	459	8	5	6	23	42	71	106	99	52	25	14	9
	PrecMax	608	20	12	19	54	114	153	210	169	124	86	27	24
	PrecMin	287	0	1	0	1	4	17	36	45	20	2	4	3
	PrecStd	73	5	3	5	16	26	37	43	37	27	20	7	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-11.2	-0.9	9.2	21.6	28.4	32.8	33.2	30.8	25.7	16.7	4.5	-8.3
		MCWB	-12.8	-4.4	2.1	9.3	14.3	18.9	20.2	20.0	15.2	8.3	0.5	-9.8
	2%	DB	-14.1	-5.5	5.5	16.4	24.1	30.0	30.8	28.5	22.7	12.4	0.2	-11.6
		MCWB	-15.1	-7.9	0.1	6.4	12.0	18.0	19.8	19.2	14.6	6.0	-2.5	-12.6
	5%	DB	-16.3	-8.9	2.4	12.7	21.3	27.6	28.7	26.3	19.8	9.4	-2.8	-14.9
		MCWB	-17.1	-10.4	-1.8	4.9	10.9	17.3	19.4	18.9	12.9	4.1	-4.6	-15.7
	10%	DB	-18.5	-11.7	-0.1	9.8	18.7	25.4	26.5	23.9	17.2	6.7	-5.6	-17.9
		MCWB	-19.2	-13.0	-3.5	3.0	9.7	16.4	18.9	17.5	11.4	2.4	-7.0	-18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-12.7	-4.2	2.5	9.5	15.1	21.2	22.8	22.0	17.0	8.9	0.7	-9.6
		MCDB	-11.2	-1.0	8.7	20.8	24.9	28.0	29.1	28.3	22.7	15.9	4.2	-8.5
	2%	WB	-15.1	-7.8	0.3	6.9	13.3	19.5	21.5	20.6	15.6	6.5	-2.3	-12.6
		MCDB	-14.2	-5.6	5.1	15.1	21.6	26.6	27.4	26.2	20.6	11.7	0.0	-11.6
	5%	WB	-17.1	-10.4	-1.6	5.1	11.9	18.3	20.6	19.3	14.1	4.5	-4.5	-15.6
		MCDB	-16.3	-8.8	2.2	12.2	19.5	25.1	26.0	24.3	18.1	8.8	-2.9	-14.9
	10%	WB	-19.1	-13.0	-3.3	3.5	10.4	17.2	19.7	18.2	12.3	2.6	-7.0	-18.5
		MCDB	-18.5	-11.7	-0.2	9.1	17.3	23.9	24.6	22.6	16.4	6.4	-5.6	-17.9
Mean Daily Temperature Range	5% DB	MDBR	14.7	18.8	18.6	15.0	15.9	16.5	14.0	14.4	15.0	13.7	14.1	13.4
		MCDBR	16.1	20.1	18.8	20.7	22.6	21.3	19.0	19.2	20.4	18.1	14.9	14.7
		MCWBR	15.1	17.9	13.9	12.0	11.5	10.1	9.0	10.3	12.0	11.7	12.0	13.8
	5% WB	MCDBR	16.0	20.0	17.9	19.2	19.5	17.7	14.9	15.4	16.6	17.6	14.6	14.6
		MCWBR	15.0	17.7	13.2	11.3	10.5	8.9	8.0	8.9	10.1	11.6	11.9	13.7
Clear-Sky Solar Irradiance	taub	0.253	0.283	0.331	0.457	0.510	0.476	0.449	0.409	0.360	0.328	0.287	0.262	
	taud	2.145	2.105	2.045	1.874	1.860	2.064	2.202	2.296	2.372	2.322	2.169	2.069	
	Ebn at Noon	725	811	839	764	745	781	799	812	813	756	664	615	
	Edh at Noon	68	98	129	177	189	156	134	115	94	80	66	61	
All-Sky Solar Radiation	RadAvg	1.32	2.47	4.12	5.26	5.22	5.94	5.17	4.56	3.52	2.31	1.41	1.00	
	RadStd	0.05	0.07	0.18	0.36	0.40	0.55	0.47	0.46	0.30	0.15	0.07	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page