

ARXAN, China

WMO: 507270

Lat: 47.1809N

Lon: 119.9340E

Elev: 3271

StdP: 13.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.6	-30.5	-41.0	0.6	-34.5	-36.5	0.8	-30.4	17.8	7.1	15.0	-0.4	1.0	200	0.674

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	83.2	62.9	79.9	61.5	76.8	60.3	67.1	77.6	65.1	74.8	63.4	72.5	7.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	99.4	72.1	61.7	92.7	70.3	59.8	86.7	68.3	33.6	77.8	32.0	74.9	30.6	72.4	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	16.8	14.5	-38.3	89.1	4.2	4.6	-41.4	92.4	-43.9	95.1	-46.2	97.7	-49.3	101.0
			-38.2	70.1	4.4	2.4	-41.4	71.8	-43.9	73.2	-46.4	74.5	-49.6	76.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	-11.9	-3.8	12.0	32.6	47.1	58.1	63.8	60.1	48.2	32.1	9.9	-6.6
	DBStd	28.09	9.51	11.10	12.02	10.10	8.27	6.73	5.21	6.14	8.10	10.04	12.22	10.13
	HDD50	8949	1919	1506	1179	529	155	12	0	5	129	557	1203	1755
	HDD65	13364	2384	1926	1644	972	556	224	85	175	505	1020	1653	2220
	CDD50	1150	0	0	0	7	66	254	428	317	75	3	0	0
	CDD65	91	0	0	0	0	3	16	48	23	1	0	0	0
	CDH74	1355	0	0	0	3	89	338	566	308	51	0	0	0
	CDH80	295	0	0	0	0	18	75	130	66	6	0	0	0
Wind	WSAvg	5.2	3.0	4.1	5.7	7.4	7.4	5.5	4.9	5.1	5.9	5.8	4.7	3.3
Precipitation	PrecAvg	17.8	0.2	0.2	0.4	0.8	1.5	3.1	5.0	3.2	1.9	0.8	0.4	0.3
	PrecMax	24.3	0.5	0.4	0.8	1.5	4.1	5.3	8.0	6.7	4.2	2.0	0.6	0.5
	PrecMin	12.5	0.1	0.0	0.2	0.2	0.2	0.4	1.6	0.9	0.4	0.1	0.1	0.1
	PrecStd	2.6	0.1	0.1	0.2	0.4	0.9	1.3	1.6	1.4	1.1	0.5	0.1	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.6	33.4	50.0	70.3	82.4	87.1	88.1	86.0	79.8	67.5	47.2	26.8
		MCWB	14.9	26.8	36.1	47.0	54.1	60.5	67.1	64.8	56.8	47.4	34.8	22.6
	2%	DB	12.6	26.5	42.5	62.3	75.7	81.5	83.4	80.8	74.2	60.6	38.9	18.4
		MCWB	10.3	21.8	32.8	43.3	52.1	59.9	65.0	63.2	55.0	44.6	31.2	15.5
	5%	DB	7.8	20.8	36.7	56.6	70.2	77.7	80.1	77.1	69.5	54.4	33.4	13.3
		MCWB	6.1	17.2	29.1	40.7	49.5	58.8	64.2	62.0	53.0	41.6	28.0	11.3
	10%	DB	3.5	15.0	31.7	51.1	65.1	73.9	76.6	73.7	65.2	49.0	28.1	9.3
		MCWB	2.2	12.5	25.8	37.6	47.8	57.5	63.1	60.4	52.0	38.5	24.2	7.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.3	27.5	37.4	48.0	56.5	65.6	70.7	69.0	61.8	48.7	35.8	22.9
		MCDB	18.2	32.9	48.1	68.4	75.2	79.1	81.4	81.7	73.0	63.7	45.1	26.5
	2%	WB	10.4	21.8	33.0	44.1	53.8	63.0	68.1	66.1	57.6	45.5	31.4	15.6
		MCDB	12.5	26.4	41.4	60.3	70.2	74.7	78.4	76.7	67.7	58.6	38.4	18.3
	5%	WB	6.1	17.3	29.3	41.0	51.3	61.0	66.3	64.0	55.3	42.5	27.9	11.4
		MCDB	7.7	20.8	36.3	56.0	67.1	72.3	76.0	73.2	66.5	53.0	33.4	13.3
	10%	WB	2.2	12.4	26.0	38.0	49.0	59.3	64.6	62.2	53.0	39.4	24.3	7.9
		MCDB	3.5	15.0	31.6	50.1	63.8	70.2	73.5	70.7	63.5	48.1	28.1	9.3
Mean Daily Temperature Range	5% DB	MDBR	21.0	24.7	24.2	22.9	26.0	24.9	21.8	22.8	25.6	22.7	21.5	20.1
		MCDBR	24.8	29.1	27.3	31.5	34.7	32.2	27.5	28.2	32.5	31.7	26.5	23.4
		MCWBR	22.8	24.4	19.1	17.0	16.2	13.9	12.4	12.8	15.7	17.9	19.4	20.9
	5% WB	MCDBR	24.7	28.6	26.4	30.0	29.3	24.9	22.4	22.2	26.3	28.9	25.9	23.3
		MCWBR	22.6	24.0	18.6	16.6	14.6	12.2	11.6	11.5	13.8	16.7	19.2	20.8
Clear-Sky Solar Irradiance	taub	0.252	0.274	0.325	0.402	0.477	0.471	0.432	0.396	0.349	0.320	0.282	0.260	
	taud	2.246	2.175	2.108	2.044	1.899	2.026	2.201	2.279	2.360	2.345	2.297	2.224	
	Ebn at Noon	266	282	281	268	251	254	263	268	272	262	251	246	
	Edh at Noon	24	33	42	49	60	53	44	39	32	28	23	22	
All-Sky Solar Radiation	RadAvg	639	1025	1473	1720	1906	1890	1808	1691	1388	995	639	499	
	RadStd	34	51	78	114	135	167	142	116	108	67	37	36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page