

ARXAN, China

WMO: 507270

Lat: 47.1809N

Lon: 119.9340E

Elev: 997

StdP: 89.91

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.0	-34.7	-40.6	0.1	-36.9	-38.1	0.1	-34.7	7.9	-13.8	6.7	-18.0	0.4	200	0.674

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	28.5	17.1	26.6	16.4	24.9	15.7	19.5	25.3	18.4	23.8	17.4	22.5	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	14.2	22.3	16.5	13.2	21.3	15.4	12.4	20.2	60.3	25.4	56.5	23.8	53.2	22.5	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.5	6.5	-39.1	31.7	2.4	2.5	-40.8	33.6	-42.1	35.1	-43.5	36.5	-45.2	38.3		
			-39.0	21.2	2.5	1.3	-40.8	22.1	-42.2	22.9	-43.6	23.6	-45.3	24.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.9	-24.4	-19.9	-11.1	0.3	8.4	14.5	17.7	15.6	9.0	0.1	-12.3	-21.4	
	DBStd	15.60	5.28	6.16	6.68	5.61	4.59	3.74	2.90	3.41	4.50	5.58	6.79	5.63	
	HDD10.0	4972	1066	837	655	294	86	7	0	3	72	309	668	975	
	HDD18.3	7424	1324	1070	913	540	309	124	47	97	281	567	918	1233	
	CDD10.0	639	0	0	0	4	37	141	238	176	42	2	0	0	
	CDD18.3	51	0	0	0	0	2	9	27	13	1	0	0	0	
	CDH23.3	753	0	0	0	2	49	188	314	171	28	0	0	0	
	CDH26.7	164	0	0	0	0	10	42	72	37	3	0	0	0	
Wind	WSAvg	2.3	1.3	1.8	2.6	3.3	3.3	2.4	2.2	2.3	2.6	2.6	2.1	1.5	
Precipitation	PrecAvg	451	6	5	9	20	37	78	126	82	48	20	9	8	
	PrecMax	618	13	10	20	39	103	134	204	171	106	50	16	13	
	PrecMin	317	2	1	4	4	6	11	40	24	11	2	2	2	
	PrecStd	66	2	2	5	11	22	33	41	35	27	12	3	3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.5	0.8	10.0	21.3	28.0	30.6	31.2	30.0	26.6	19.7	8.4	-2.9	
		MCWB	-9.5	-2.9	2.3	8.4	12.3	15.9	19.5	18.2	13.8	8.6	1.6	-5.2	
	2%	DB	-10.8	-3.0	5.8	16.8	24.3	27.5	28.6	27.1	23.5	15.9	3.9	-7.6	
		MCWB	-12.0	-5.7	0.4	6.3	11.2	15.5	18.3	17.3	12.8	7.0	-0.5	-9.1	
	5%	DB	-13.4	-6.2	2.6	13.6	21.2	25.4	26.7	25.1	20.8	12.4	0.8	-10.4	
		MCWB	-14.4	-8.2	-1.6	4.8	9.7	14.9	17.9	16.7	11.7	5.3	-2.2	-11.5	
	10%	DB	-15.8	-9.5	-0.2	10.6	18.4	23.3	24.8	23.2	18.4	9.4	-2.2	-12.6	
		MCWB	-16.6	-10.8	-3.4	3.1	8.8	14.2	17.3	15.8	11.1	3.6	-4.3	-13.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-9.3	-2.5	3.0	8.9	13.6	18.6	21.5	20.6	16.6	9.3	2.1	-5.1
			MCDB	-7.6	0.5	8.9	20.2	24.0	26.2	27.4	27.6	22.8	17.6	7.3	-3.1
		2%	WB	-12.0	-5.7	0.5	6.7	12.1	17.2	20.0	18.9	14.2	7.5	-0.4	-9.1
			MCDB	-10.8	-3.1	5.2	15.7	21.2	23.7	25.8	24.8	19.9	14.8	3.5	-7.6
5%		WB	-14.4	-8.1	-1.5	5.0	10.7	16.1	19.1	17.8	13.0	5.8	-2.3	-11.5	
		MCDB	-13.5	-6.2	2.4	13.3	19.5	22.4	24.4	22.9	19.2	11.7	0.8	-10.4	
10%		WB	-16.5	-10.9	-3.3	3.4	9.4	15.1	18.1	16.8	11.7	4.1	-4.3	-13.4	
		MCDB	-15.8	-9.5	-0.2	10.0	17.7	21.2	23.1	21.5	17.5	8.9	-2.1	-12.6	
Mean Daily Temperature Range	5% DB	MDBR	11.7	13.7	13.4	12.7	14.4	13.8	12.1	12.6	14.2	12.6	11.9	11.2	
		MCDBR	13.8	16.2	15.2	17.5	19.3	17.9	15.3	15.7	18.1	17.6	14.7	13.0	
		MCWBR	12.7	13.5	10.6	9.4	9.0	7.7	6.9	7.1	8.7	9.9	10.8	11.6	
	5% WB	MCDBR	13.7	15.9	14.6	16.7	16.3	13.8	12.4	12.4	14.6	16.0	14.4	12.9	
		MCWBR	12.6	13.4	10.3	9.2	8.1	6.8	6.4	6.4	7.7	9.3	10.6	11.6	
	Clear-Sky Solar Irradiance	taub	0.252	0.274	0.325	0.402	0.477	0.471	0.432	0.396	0.349	0.320	0.282	0.260	
taud		2.246	2.175	2.108	2.044	1.899	2.026	2.201	2.279	2.360	2.345	2.297	2.224		
Ebn at Noon		840	890	887	846	792	801	829	846	859	827	790	774		
Edh at Noon		77	104	132	156	188	166	138	122	102	88	74	70		
All-Sky Solar Radiation	RadAvg	2.02	3.23	4.64	5.42	6.01	5.96	5.70	5.33	4.38	3.14	2.02	1.57		
	RadStd	0.11	0.16	0.25	0.36	0.43	0.53	0.45	0.36	0.34	0.21	0.12	0.11		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page