

HAILUN, China

WMO: 507560

Lat: 47.4453N

Lon: 126.8744E

Elev: 220

StdP: 98.71

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.8	-28.7	-34.0	0.2	-30.3	-32.0	0.2	-28.3	7.3	-14.4	6.3	-15.0	1.2	160	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.2	30.3	19.9	28.8	20.3	27.4	20.0	23.7	27.0	22.8	25.9	21.9	25.2	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.7	17.9	25.4	21.8	16.9	24.7	20.8	15.9	23.9	72.6	27.1	68.9	25.8	65.5	25.3	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.2	6.2	-32.6	33.6	3.3	1.9	-35.0	34.9	-37.0	36.1	-38.8	37.1	-41.2	38.5		
			-32.7	25.3	3.3	1.0	-35.1	26.0	-37.0	26.5	-38.9	27.1	-41.3	27.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-20.9	-15.6	-5.6	5.5	13.7	20.0	22.2	20.1	13.9	4.7	-8.0	-18.4	(6)
(7)		DBStd	15.88	4.62	5.41	6.34	4.66	4.22	3.52	2.23	2.56	3.71	4.76	6.61	4.93	(7)
(8)		HDD10.0	3927	958	718	484	149	13	0	0	9	174	541	881		(8)
(9)		HDD18.3	5976	1216	951	743	386	154	22	1	12	138	423	791	1139	(9)
(10)		CDD10.0	1268	0	0	0	14	127	299	379	314	126	10	0	0	(10)
(11)		CDD18.3	277	0	0	0	0	11	71	122	67	6	0	0	0	(11)
(12)		CDH23.3	1978	0	0	0	6	143	632	779	365	53	1	0	0	(12)
(13)		CDH26.7	471	0	0	0	0	33	209	178	45	6	0	0	0	(13)
(14)	Wind	WSAvg	2.8	2.1	2.4	3.1	3.6	3.6	3.0	2.6	2.5	2.7	3.0	2.7	2.2	(14)
(15)	Precipitation	PrecAvg	551	2	3	7	23	47	96	147	133	66	23	7	4	(15)
(16)		PrecMax	867	6	8	23	64	108	216	446	263	133	62	26	17	(16)
(17)		PrecMin	349	0	0	0	0	7	20	30	16	6	0	1	1	(17)
(18)		PrecStd	117	2	2	5	17	28	45	80	71	32	16	5	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.1	2.1	12.2	23.9	30.1	34.0	32.3	29.2	27.4	20.6	9.6	-1.8	(19)
(20)		0.4%	MCWB	-7.5	-1.3	5.5	11.9	15.2	19.8	22.5	22.5	18.4	12.6	5.7	-2.9	(20)
(21)		2%	DB	-9.3	-1.2	8.6	19.6	27.1	31.0	30.0	28.0	24.7	17.1	6.3	-6.3	(21)
(22)		2%	MCWB	-10.3	-3.6	3.0	9.5	14.4	19.0	21.7	22.1	17.3	11.0	3.0	-7.4	(22)
(23)		5%	DB	-11.9	-4.2	5.8	16.7	24.6	29.1	28.6	26.7	23.0	14.5	3.4	-8.8	(23)
(24)		5%	MCWB	-12.8	-6.0	1.3	8.2	13.6	18.5	21.9	21.1	16.1	9.1	0.6	-9.7	(24)
(25)		10%	DB	-14.0	-7.2	3.5	13.9	22.1	27.0	27.3	25.5	21.1	12.3	1.0	-10.9	(25)
(26)		10%	MCWB	-14.7	-8.7	-0.1	6.6	12.4	17.8	21.5	20.4	15.2	7.8	-0.9	-11.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.4	-0.8	6.6	12.7	17.9	22.4	25.2	24.7	20.9	14.1	6.1	-3.1	(27)
(28)		0.4%	MCDWB	-6.3	1.4	11.2	21.4	25.7	28.4	28.1	27.1	24.0	18.5	8.6	-2.1	(28)
(29)		2%	WB	-10.3	-3.7	3.5	10.5	16.0	21.2	24.1	23.5	18.8	11.8	3.1	-7.2	(29)
(30)		2%	MCDWB	-9.3	-1.3	7.4	17.8	23.3	27.1	27.7	26.1	22.5	15.6	5.9	-6.4	(30)
(31)		5%	WB	-12.8	-6.1	1.7	8.7	14.6	20.2	23.2	22.5	17.4	10.0	0.9	-9.7	(31)
(32)		5%	MCDWB	-12.0	-4.3	5.2	15.4	22.1	25.7	26.6	25.2	21.2	13.3	2.8	-8.9	(32)
(33)		10%	WB	-14.7	-8.7	0.1	7.2	13.4	19.2	22.4	21.5	16.1	8.2	-1.0	-11.7	(33)
(34)		10%	MCDWB	-14.0	-7.2	3.3	12.9	20.6	24.5	25.7	24.3	19.8	11.7	1.0	-10.9	(34)
(35)	Mean Daily Temperature Range		MDBR	8.6	10.2	10.0	10.7	11.2	9.9	8.2	8.8	11.1	9.8	8.7	8.2	(35)
(36)		5% DB	MCDBR	9.9	11.5	12.0	15.4	15.0	13.0	10.4	10.4	13.5	13.0	11.0	9.4	(36)
(37)			MCWBR	9.1	9.7	7.9	8.4	6.6	4.9	4.4	5.1	6.5	7.7	8.1	8.7	(37)
(38)			MCDBR	9.8	11.4	11.0	13.4	12.7	10.3	8.2	8.3	10.6	11.3	10.3	9.5	(38)
(39)		5% WB	MCWBR	9.1	9.7	7.5	7.8	6.3	4.6	4.6	4.9	6.1	7.6	8.1	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.324	0.387	0.485	0.547	0.566	0.540	0.476	0.431	0.413	0.342	0.306	(40)	
(41)		taud	2.134	2.084	1.991	1.866	1.784	1.837	1.929	2.082	2.122	2.045	2.152	2.125	(41)	
(42)		Ebn at Noon	750	816	813	765	733	722	735	769	765	696	688	685	(42)	
(43)		Edh at Noon	87	115	149	187	211	201	181	149	130	120	87	79	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.96	3.13	4.35	4.87	5.47	5.67	5.24	4.82	4.07	2.78	1.82	1.50	(44)	
(45)		RadStd	0.13	0.18	0.32	0.44	0.49	0.69	0.53	0.36	0.35	0.20	0.15	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page