

FUJIN, China

WMO: 507880

Lat: 47.2278N

Lon: 131.9990E

Elev: 65

StdP: 100.55

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.7	-25.9	-31.5	0.2	-27.1	-29.9	0.2	-25.4	10.2	-17.8	9.3	-17.9	3.0	270	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	30.7	21.4	29.1	21.4	27.6	20.9	24.2	27.9	23.2	26.9	22.4	25.8	3.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	17.9	26.5	22.1	16.9	25.2	21.2	16.0	24.3	73.5	28.1	69.8	26.9	66.4	25.7	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.5	7.5	-30.9	33.9	2.2	1.8	-32.5	35.2	-33.8	36.3	-35.0	37.3	-36.6	38.6		
(5)			-31.0	25.6	2.2	1.0	-32.6	26.3	-33.9	26.9	-35.1	27.4	-36.7	28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.5	-18.6	-14.3	-5.2	5.7	13.9	19.7	22.4	20.7	14.7	5.7	-6.6	-16.7		
	DBStd	15.23	4.08	4.74	5.75	4.34	4.14	3.62	2.51	2.62	3.50	4.63	6.30	4.48		
	HDD10.0	3673	888	681	472	142	11	0	0	0	4	148	499	827		
	HDD18.3	5701	1146	914	731	379	148	27	2	9	116	393	749	1086		
	CDD10.0	1312	0	0	0	13	131	291	386	332	146	13	0	0		
	CDD18.3	297	0	0	0	0	10	68	129	82	8	0	0	0		
	CDH23.3	2087	0	0	0	8	135	555	871	453	64	1	0	0		
	CDH26.7	532	0	0	0	1	35	177	238	72	8	0	0	0		
(14) Wind	WSAvg	3.6	3.9	3.7	3.8	4.1	4.1	3.4	3.0	2.8	3.1	3.7	3.9	3.8		
(15) Precipitation	PrecAvg	513	4	5	9	27	46	81	105	124	64	31	11	7		
	PrecMax	711	12	20	24	139	133	152	183	232	178	104	31	23		
	PrecMin	338	0	0	1	2	8	25	20	16	9	2	0	1		
	PrecStd	117	3	5	5	24	26	34	40	57	43	25	8	5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-5.6	2.5	11.6	23.8	30.5	33.6	33.0	30.3	27.8	21.5	10.9	-0.9		
		MCWB	-7.2	-1.0	5.9	11.7	16.6	21.0	23.1	24.1	19.8	13.5	6.1	-2.6		
	2%	DB	-8.7	-0.7	8.1	19.7	26.9	30.7	30.8	28.6	25.1	18.0	7.3	-5.2		
		MCWB	-9.8	-3.0	3.3	10.2	15.4	20.1	22.7	23.0	18.3	11.3	3.8	-6.3		
	5%	DB	-10.7	-3.9	5.4	16.2	24.2	28.6	29.2	27.2	23.3	15.3	4.4	-7.9		
		MCWB	-11.7	-5.7	1.3	8.4	14.2	19.4	22.5	22.0	17.3	9.7	1.5	-9.0		
	10%	DB	-12.5	-6.7	3.0	13.4	21.6	26.6	27.7	26.0	21.4	12.8	2.0	-9.9		
		MCWB	-13.4	-8.2	0.0	7.1	13.3	18.6	22.0	21.3	16.3	8.3	-0.3	-10.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.2	-0.3	6.5	13.2	18.5	23.1	25.5	25.4	21.6	14.6	6.9	-2.4		
		MCDB	-5.7	2.2	10.9	21.9	26.9	29.4	29.4	28.8	25.1	19.6	10.1	-0.8		
	2%	WB	-9.8	-3.1	3.9	10.9	16.7	21.9	24.4	24.1	19.8	12.6	4.0	-6.2		
		MCDB	-8.7	-0.6	7.3	18.2	24.4	27.5	28.4	27.3	23.2	16.5	7.0	-5.2		
	5%	WB	-11.7	-5.7	1.7	9.2	15.4	20.8	23.6	23.1	18.4	10.5	1.8	-8.9		
		MCDB	-10.8	-4.0	4.7	15.3	22.3	26.0	27.5	26.2	22.1	14.2	4.0	-7.9		
	10%	WB	-13.4	-8.2	0.1	7.5	14.2	19.7	22.8	22.1	17.0	8.8	0.1	-10.9		
		MCDB	-12.6	-6.7	2.7	12.3	20.1	24.6	26.5	24.9	20.3	12.1	1.8	-9.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	10.2	9.7	10.3	10.3	9.2	8.1	8.2	10.5	9.8	8.1	7.6		
		MCDBR	9.2	11.9	11.2	15.5	14.8	12.9	10.8	10.2	13.4	13.8	11.0	9.4		
		MCWBR	8.4	10.1	7.4	8.0	6.2	4.8	4.5	5.2	6.7	7.8	7.9	8.6		
		MCDBR	9.3	11.7	10.3	13.9	12.6	10.9	8.9	8.9	11.1	12.3	10.4	9.3		
	5% WB	MCWBR	8.4	10.0	7.1	7.8	5.8	4.8	4.6	4.9	6.3	7.6	7.8	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.302	0.338	0.422	0.547	0.583	0.552	0.520	0.473	0.431	0.448	0.372	0.314		
	taud		2.119	1.996	1.848	1.723	1.718	1.887	2.005	2.117	2.140	1.945	2.048	2.087		
	Ebn at Noon		750	795	772	712	705	734	752	772	766	656	642	674		
	Edh at Noon		89	126	173	216	225	191	168	144	128	133	97	83		
(44) All-Sky Solar Radiation	RadAvg		2.01	3.26	4.52	4.80	5.31	5.58	5.24	4.79	4.04	2.77	1.84	1.55		
	RadStd		0.15	0.14	0.36	0.50	0.45	0.69	0.54	0.31	0.37	0.19	0.14	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page