

ANDA, China

WMO: 508540

Lat: 46.3855N

Lon: 125.3240E

Elev: 492

StdP: 14.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.3	-15.2	-25.5	1.4	-17.6	-22.0	1.7	-13.3	16.5	8.4	14.7	9.1	2.8	220	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	89.6	69.0	86.6	69.1	84.0	68.7	75.8	82.3	74.2	80.7	72.5	79.3	8.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	128.5	79.6	72.1	120.7	78.2	70.3	113.7	76.8	39.9	82.4	38.2	80.6	36.7	79.1	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	16.1	13.9	DB	-21.7	94.8	5.3	3.2	-25.5	97.1	-28.6	99.0	-31.5	100.8	-35.4	103.2	(4)
(5)			WB	-21.8	77.9	5.3	2.1	-25.6	79.4	-28.7	80.6	-31.7	81.8	-35.6	83.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.4	0.1	9.4	26.1	44.8	59.0	70.3	74.4	70.9	59.7	43.0	21.5	3.9	
	DBStd	27.38	7.91	9.66	10.61	8.83	7.54	6.21	4.31	4.59	6.81	8.57	10.96	8.41	
	HDD50	6178	1545	1137	742	206	10	0	0	0	7	247	854	1430	
	HDD65	9690	2010	1557	1206	608	217	21	1	7	183	681	1304	1895	
	CDD50	2684	0	0	1	49	290	608	757	647	300	32	0	0	
	CDD65	720	0	0	0	1	33	178	293	189	26	0	0	0	
	CDH74	5862	0	0	0	25	379	1635	2323	1281	214	5	0	0	
	CDH80	1714	0	0	0	4	107	578	714	280	31	0	0	0	
Wind	WSAvg	6.2	4.8	5.6	7.2	8.4	8.0	6.6	5.9	5.5	5.7	6.1	5.9	4.9	
Precipitation	PrecAvg	16.9	0.0	0.1	0.2	0.6	1.2	2.6	5.6	3.8	2.0	0.6	0.2	0.1	
	PrecMax	26.8	0.2	0.4	1.0	3.9	4.2	5.7	11.2	8.8	4.5	1.7	0.6	0.4	
	PrecMin	11.5	0.0	0.0	0.0	0.0	0.1	0.6	1.9	0.9	0.4	0.0	0.0	0.0	
	PrecStd	3.2	0.0	0.1	0.2	0.7	0.9	1.3	2.2	2.3	1.0	0.5	0.2	0.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.5	40.6	59.7	77.3	88.3	95.0	93.8	88.8	83.5	72.3	52.8	33.5	
		MCWB	21.3	31.7	44.2	54.1	60.9	66.8	71.4	72.6	66.5	56.7	43.7	30.4	
	2%	DB	19.5	34.5	52.5	71.1	83.1	90.0	89.6	85.6	79.4	66.1	47.5	24.8	
		MCWB	16.4	28.3	39.2	50.6	59.0	66.6	71.0	72.1	64.7	53.7	39.4	21.7	
	5%	DB	15.3	29.8	47.4	66.0	78.4	86.3	86.7	83.1	76.0	61.1	41.8	20.5	
		MCWB	12.7	24.7	36.1	48.4	58.1	65.9	71.8	70.6	62.2	50.0	35.4	17.8	
	10%	DB	12.1	24.9	42.5	61.0	73.7	82.9	83.9	80.8	72.8	57.1	36.6	16.4	
		MCWB	10.0	20.6	32.9	45.9	55.6	65.2	71.5	69.5	60.5	47.7	31.5	14.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	32.4	44.8	55.8	64.7	72.8	79.2	77.4	71.1	59.3	45.7	29.8
			MCDB	24.9	38.5	57.9	73.1	79.7	84.0	84.9	84.0	78.1	67.5	51.7	32.9
2%		WB	16.6	28.5	40.2	52.3	62.1	70.8	76.6	75.3	67.4	55.3	39.9	22.0	
		MCDB	19.5	34.5	50.3	67.5	75.9	82.0	82.9	81.8	74.9	64.0	46.2	24.5	
5%		WB	13.0	24.4	36.9	49.4	59.9	69.2	75.1	73.5	64.9	52.1	35.8	17.8	
		MCDB	15.4	29.7	46.6	64.1	73.1	79.6	81.7	79.4	72.8	59.4	41.3	20.3	
10%		WB	10.0	20.6	33.5	46.6	57.6	67.6	73.6	71.8	62.5	48.6	31.8	14.1	
		MCDB	12.0	24.8	41.9	59.5	71.6	77.6	80.2	77.9	70.3	55.8	36.0	16.4	
Mean Daily Temperature Range		5% DB	MDBR	18.0	19.9	19.4	20.8	19.9	17.8	15.1	16.3	20.0	18.6	16.1	16.3
			MCDBR	20.4	22.4	25.2	27.7	26.4	23.4	19.6	19.4	23.8	24.5	20.9	19.0
	MCWBR		17.9	17.2	15.2	14.6	11.1	8.1	7.4	8.2	11.0	13.8	14.5	16.3	
	5% WB	MCDBR	20.1	21.9	23.5	24.4	20.9	17.3	14.5	14.9	19.1	21.6	20.1	18.7	
		MCWBR	17.8	17.2	14.8	14.0	10.3	7.0	7.7	7.9	10.6	14.1	14.6	16.2	
Clear-Sky Solar Irradiance	taub	0.308	0.326	0.398	0.495	0.559	0.608	0.565	0.501	0.446	0.422	0.351	0.319		
	taud	2.155	2.135	1.997	1.822	1.740	1.731	1.872	2.015	2.065	2.010	2.124	2.140		
	Ebn at Noon	240	262	257	241	230	220	228	238	239	220	219	219		
	Edh at Noon	28	36	48	62	70	71	61	51	44	40	29	26		
All-Sky Solar Radiation	RadAvg	651	1017	1388	1649	1844	1846	1737	1627	1405	980	637	502		
	RadStd	72	68	96	112	144	171	172	111	114	55	50	43		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page