

JIXI, China

WMO: 509780

Lat: 45.3050N

Lon: 130.9089E

Elev: 897

StdP: 14.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-8.8	-21.5	1.7	-9.6	-18.6	2.1	-6.0	25.7	5.8	23.3	5.5	7.7	270	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	87.2	69.6	84.5	68.9	81.9	68.3	74.6	81.8	72.9	79.6	71.4	78.2	9.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.6	124.7	78.6	70.8	117.5	76.9	69.2	111.0	75.3	39.0	81.8	37.3	79.7	35.9	78.2	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	24.7	21.3	18.7	DB	-15.8	92.6	4.3	2.9	-18.9	94.7	-21.4	96.4	-23.8	98.0	-27.0	100.1
(5)				WB	-16.3	77.4	4.1	1.9	-19.2	78.7	-21.7	79.9	-24.0	80.9	-27.0	82.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.8	4.4	12.2	26.3	43.9	57.0	67.0	72.2	69.6	59.1	43.8	24.2	8.1	
	DBStd	25.09	7.12	8.82	9.78	8.61	7.60	6.53	4.70	4.86	6.27	8.26	11.03	8.08	
	HDD50	5758	1412	1057	736	225	20	0	0	6	227	776	1299		
	HDD65	9371	1877	1477	1201	634	269	53	4	15	195	657	1225	1764	
	CDD50	2399	0	0	1	42	236	510	687	608	279	35	1	0	
	CDD65	536	0	0	0	1	21	113	226	158	17	0	0	0	
	CDH74	3822	0	0	0	20	273	946	1560	890	130	3	0	0	
	CDH80	994	0	0	0	3	67	288	455	166	15	0	0	0	
Wind	WSAvg	8.2	9.2	9.4	9.9	9.8	8.9	7.0	6.1	5.8	6.5	8.1	8.7	8.8	
Precipitation	PrecAvg	21.5	0.2	0.3	0.3	0.9	2.1	3.4	4.9	4.9	2.3	1.2	0.6	0.3	
	PrecMax	32.3	0.5	0.9	1.0	2.1	4.4	8.4	11.5	11.5	5.6	4.3	2.0	1.2	
	PrecMin	12.6	0.0	0.0	0.0	0.1	0.4	0.8	1.3	1.6	0.5	0.0	0.0	0.0	
	PrecStd	4.6	0.1	0.3	0.2	0.6	1.0	1.9	2.3	2.6	1.4	0.9	0.5	0.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	40.7	58.0	76.7	86.3	90.9	92.0	87.3	82.1	71.8	56.3	37.7	
		MCWB	22.8	32.4	43.6	54.3	60.0	67.9	72.0	73.9	66.8	55.9	45.0	31.6	
	2%	DB	22.1	35.8	50.9	70.2	81.2	86.4	87.9	84.2	77.7	66.4	50.0	28.8	
		MCWB	18.4	28.8	39.1	50.0	58.6	66.3	72.5	71.9	64.4	52.4	40.8	24.8	
	5%	DB	18.6	30.4	45.4	64.9	76.2	83.3	84.8	81.6	74.2	61.6	44.5	24.3	
		MCWB	15.5	25.2	35.6	47.6	56.8	65.5	71.4	70.6	61.9	49.9	37.0	21.1	
	10%	DB	15.2	26.2	40.9	59.7	71.8	79.6	82.1	79.1	71.1	57.2	39.6	20.4	
		MCWB	12.6	21.9	33.0	45.1	55.1	64.4	70.8	69.3	60.0	47.6	33.7	17.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	33.0	44.4	55.0	64.1	72.4	77.7	76.7	69.9	57.8	46.1	32.3
			MCDB	26.3	39.9	56.1	73.7	80.1	83.5	85.9	83.9	77.5	68.1	54.4	37.0
2%		WB	18.6	29.0	40.0	51.2	60.6	70.0	75.5	74.3	66.9	54.4	41.7	25.1	
		MCDB	21.9	35.4	49.3	66.7	74.7	80.7	83.2	80.7	74.2	62.7	48.6	28.3	
5%		WB	15.6	25.4	36.3	48.6	58.5	68.1	73.7	72.8	64.2	51.6	37.5	21.2	
		MCDB	18.4	30.2	44.1	63.3	71.8	78.1	80.5	78.8	71.2	59.4	43.8	24.1	
10%		WB	12.6	22.0	33.3	45.9	56.5	66.4	72.1	71.2	62.1	48.7	33.9	17.5	
		MCDB	15.1	26.2	40.2	58.4	68.9	75.9	79.1	76.8	68.9	56.4	39.2	20.3	
Mean Daily Temperature Range		5% DB	MDBR	15.1	17.1	16.8	19.0	19.1	17.4	15.0	15.4	19.6	18.2	14.9	13.8
			MCDBR	17.8	20.8	21.9	27.4	27.3	23.1	20.1	19.1	23.6	24.4	20.6	17.6
	MCWBR		15.0	16.1	13.0	13.7	11.1	8.2	7.6	8.3	10.7	13.1	13.6	14.6	
	5% WB	MCDBR	17.7	20.2	20.6	25.4	22.7	18.9	16.3	15.9	19.0	21.9	19.6	17.3	
		MCWBR	15.0	16.0	13.1	13.7	10.3	8.0	7.6	8.0	9.8	13.1	13.9	14.7	
Clear-Sky Solar Irradiance	taub	0.311	0.349	0.425	0.528	0.559	0.554	0.516	0.474	0.427	0.439	0.369	0.324		
	taud	2.108	1.996	1.889	1.761	1.756	1.864	2.018	2.124	2.163	1.983	2.073	2.083		
	Ebn at Noon	242	253	249	233	232	234	241	247	248	218	215	220		
	Edh at Noon	30	42	54	67	69	62	53	46	41	42	32	28		
All-Sky Solar Radiation	RadAvg	692	1057	1401	1470	1626	1749	1599	1506	1333	936	638	547		
	RadStd	57	53	120	139	142	188	147	126	108	60	42	28		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page