

JIXI, China

WMO: 509780

Lat: 45.3050N

Lon: 130.9089E

Elev: 274

StdP: 98.08

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.6	-22.7	-29.7	0.2	-23.1	-28.1	0.3	-21.1	11.5	-14.6	10.4	-14.7	3.4	270	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	30.6	20.9	29.2	20.5	27.7	20.2	23.7	27.7	22.7	26.4	21.9	25.6	4.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.5	17.8	25.9	21.6	16.8	24.9	20.7	15.9	24.1	72.8	27.7	69.0	26.5	65.7	25.6	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.5	8.3	-26.6	33.7	2.4	1.6	-28.3	34.8	-29.7	35.8	-31.0	36.7	-32.8	37.8		
(5)			-26.8	25.2	2.3	1.1	-28.5	26.0	-29.8	26.6	-31.1	27.2	-32.8	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	-15.3	-11.0	-3.2	6.6	13.9	19.4	22.3	20.9	15.0	6.6	-4.4	-13.3	(6)
(7)		DBStd	13.94	3.96	4.90	5.43	4.78	4.22	3.63	2.61	2.70	3.48	4.59	6.13	4.49	(7)
(8)		HDD10.0	3199	784	587	409	125	11	0	0	0	3	126	431	722	(8)
(9)		HDD18.3	5206	1043	821	667	352	149	29	2	8	108	365	681	980	(9)
(10)		CDD10.0	1333	0	0	1	23	131	283	382	338	155	19	1	0	(10)
(11)		CDD18.3	298	0	0	0	1	12	63	126	88	9	0	0	0	(11)
(12)		CDH23.3	2123	0	0	0	11	152	526	867	494	72	2	0	0	(12)
(13)		CDH26.7	552	0	0	0	2	37	160	253	92	8	0	0	0	(13)
(14)	Wind	WSAvg	3.7	4.1	4.2	4.4	4.4	4.0	3.1	2.7	2.6	2.9	3.6	3.9	3.9	(14)
(15)	Precipitation	PrecAvg	546	4	7	8	24	54	86	125	124	59	31	14	8	(15)
(16)		PrecMax	821	13	23	26	53	113	213	293	292	142	108	52	31	(16)
(17)		PrecMin	320	0	1	0	3	10	21	33	40	12	0	0	0	(17)
(18)		PrecStd	117	3	7	6	14	26	48	58	67	35	24	12	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.9	4.9	14.4	24.8	30.2	32.7	33.3	30.7	27.8	22.1	13.5	3.2	(19)
(20)			MCWB	-5.1	0.2	6.4	12.4	15.5	20.0	22.2	23.3	19.3	13.3	7.2	-0.2	(20)
(21)		2%	DB	-5.5	2.1	10.5	21.2	27.4	30.2	31.0	29.0	25.4	19.1	10.0	-1.8	(21)
(22)			MCWB	-7.6	-1.8	4.0	10.0	14.8	19.1	22.5	22.2	18.0	11.3	4.9	-4.0	(22)
(23)		5%	DB	-7.5	-0.9	7.4	18.3	24.5	28.5	29.3	27.5	23.5	16.5	7.0	-4.3	(23)
(24)			MCWB	-9.2	-3.8	2.0	8.6	13.8	18.6	21.9	21.4	16.6	9.9	2.8	-6.0	(24)
(25)		10%	DB	-9.4	-3.2	5.0	15.4	22.1	26.5	27.8	26.2	21.7	14.0	4.2	-6.5	(25)
(26)			MCWB	-10.8	-5.6	0.6	7.3	12.8	18.0	21.5	20.7	15.5	8.7	0.9	-8.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.9	0.6	6.9	12.8	17.8	22.5	25.4	24.8	21.0	14.3	7.8	0.1	(27)
(28)			MCDWB	-3.2	4.4	13.4	23.2	26.7	28.6	30.0	28.8	25.3	20.1	12.4	2.8	(28)
(29)		2%	WB	-7.4	-1.7	4.4	10.7	15.9	21.1	24.2	23.5	19.4	12.5	5.4	-3.8	(29)
(30)			MCDWB	-5.6	1.9	9.6	19.3	23.7	27.0	28.4	27.1	23.5	17.1	9.2	-2.0	(30)
(31)		5%	WB	-9.1	-3.7	2.4	9.2	14.7	20.1	23.1	22.7	17.9	10.9	3.1	-6.0	(31)
(32)			MCDWB	-7.6	-1.0	6.7	17.4	22.1	25.6	27.0	26.0	21.8	15.2	6.5	-4.4	(32)
(33)		10%	WB	-10.8	-5.6	0.7	7.7	13.6	19.1	22.3	21.8	16.7	9.3	1.0	-8.1	(33)
(34)			MCDWB	-9.4	-3.2	4.5	14.7	20.5	24.4	26.2	24.9	20.5	13.5	4.0	-6.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	9.5	9.3	10.6	10.6	9.7	8.4	8.6	10.9	10.1	8.3	7.7	(35)
(36)			MCDBR	9.9	11.6	12.1	15.2	15.2	12.8	11.2	10.6	13.1	13.6	11.4	9.8	(36)
(37)			MCWBR	8.3	8.9	7.2	7.6	6.2	4.6	4.2	4.6	6.0	7.3	7.6	8.1	(37)
(38)		5% WB	MCDBR	9.8	11.2	11.5	14.1	12.6	10.5	9.1	8.8	10.6	12.2	10.9	9.6	(38)
(39)			MCWBR	8.3	8.9	7.3	7.6	5.7	4.5	4.2	4.5	5.5	7.3	7.7	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.349	0.425	0.528	0.559	0.554	0.516	0.474	0.427	0.439	0.369	0.324	(40)	
(41)		taud	2.108	1.996	1.889	1.761	1.756	1.864	2.018	2.124	2.163	1.983	2.073	2.083	(41)	
(42)		Ebn at Noon	763	799	784	736	730	737	761	779	782	687	677	693	(42)	
(43)		Edh at Noon	96	131	169	211	219	197	167	145	128	133	100	89	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.18	3.33	4.42	4.63	5.13	5.51	5.04	4.75	4.20	2.95	2.01	1.72	(44)	
(45)		RadStd	0.18	0.17	0.38	0.44	0.44	0.45	0.59	0.46	0.40	0.34	0.19	0.13	0.09	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page