

JINGHE XINJIANG, China

WMO: 513340

Lat: 44.5732N

Lon: 82.8196E

Elev: 1083

StdP: 14.13

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.2	-10.4	-20.3	1.9	-14.8	-15.7	2.4	-10.1	11.4	17.5	9.0	16.4	1.2	200	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	97.3	68.6	94.6	67.6	92.1	66.9	71.6	91.4	70.1	89.4	68.7	87.5	5.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	96.8	80.0	63.4	90.8	79.1	61.8	85.7	78.5	36.1	91.6	34.8	89.5	33.6	87.8	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
15.1	11.7	9.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-17.3	102.8	5.1	2.3	-20.9	104.4	-23.9	105.8	-26.8	107.1	-30.5	108.7		
			-17.6	74.5	5.1	2.5	-21.2	76.3	-24.2	77.7	-27.0	79.1	-30.7	80.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.3	4.5	13.9	35.9	56.4	68.6	78.0	79.9	76.5	65.7	50.1	33.3	14.1	(6)
(7)		DBStd	27.29	9.37	10.35	11.33	9.04	7.46	5.77	4.83	5.57	7.24	7.98	8.97	9.71	(7)
(8)		HDD50	4634	1411	1010	453	44	0	0	0	2	99	503	1112		(8)
(9)		HDD65	7606	1876	1430	902	278	49	1	0	77	462	952	1577		(9)
(10)		CDD50	3994	0	0	16	236	576	839	928	822	473	103	1	0	(10)
(11)		CDD65	1492	0	0	0	20	160	390	464	359	98	1	0	0	(11)
(12)		CDH74	16647	0	0	0	231	1632	4401	5395	3979	989	20	0	0	(12)
(13)		CDH80	7672	0	0	0	51	614	2147	2704	1845	310	1	0	0	(13)
(14)	Wind	WSAvg	3.4	2.0	2.6	3.5	4.6	4.7	4.4	4.1	3.9	3.3	2.9	2.7	2.3	(14)
(15)	Precipitation	PrecAvg	3.8	0.2	0.1	0.3	0.4	0.6	0.6	0.4	0.3	0.4	0.2	0.1	0.2	(15)
(16)		PrecMax	6.5	0.4	0.6	1.1	1.2	1.8	1.3	1.1	1.0	1.9	1.3	0.4	0.6	(16)
(17)		PrecMin	1.8	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.0	0.1	0.1	0.3	0.3	0.4	0.4	0.3	0.2	0.4	0.2	0.1	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.7	38.0	68.2	85.4	95.1	99.6	101.4	99.2	91.8	76.6	58.0	36.7	(19)
MCWB			27.9	33.6	51.8	58.8	63.9	67.0	70.6	70.1	65.2	57.0	47.4	34.3	(20)	
2%		DB	25.0	34.3	62.4	80.0	90.3	96.5	97.7	95.4	87.1	71.7	52.0	33.5	(21)	
		MCWB	22.9	31.1	49.3	56.4	62.1	66.6	69.8	69.2	63.2	55.0	44.4	31.5	(22)	
5%		DB	21.4	31.3	57.9	75.8	86.6	93.5	94.6	92.4	83.5	67.7	48.4	30.6	(23)	
		MCWB	19.8	28.4	47.1	54.8	60.8	65.8	68.9	68.1	61.7	53.1	42.7	28.8	(24)	
10%		DB	17.8	28.3	52.8	71.9	83.0	90.7	91.9	89.5	79.8	63.6	44.8	27.8	(25)	
		MCWB	16.5	25.8	44.5	53.5	59.2	65.1	68.0	67.0	60.3	51.4	40.2	26.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	34.5	52.5	60.6	66.2	70.6	74.4	73.4	67.2	58.4	49.2	35.0	(27)
MADB			30.0	36.9	66.1	79.8	91.0	91.6	94.7	91.9	86.5	73.0	54.2	36.7	(28)	
2%		WB	23.1	31.3	49.8	58.2	63.9	68.9	72.1	71.3	64.8	56.1	45.2	31.6	(29)	
		MADB	24.6	34.1	61.0	75.2	84.6	89.9	92.1	91.1	83.7	69.2	51.3	33.1	(30)	
5%		WB	19.8	28.5	47.5	56.3	62.3	67.6	70.7	69.8	62.9	54.0	42.7	29.0	(31)	
		MADB	21.3	31.1	57.3	72.3	82.1	87.9	90.0	88.5	80.5	66.0	47.8	30.7	(32)	
10%		WB	16.5	25.7	44.8	54.5	60.8	66.5	69.3	68.2	61.3	51.9	40.4	26.0	(33)	
		MADB	17.8	28.2	52.6	69.7	79.4	86.5	88.0	86.4	77.6	62.6	44.7	27.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.6	14.7	15.8	20.5	20.6	21.0	21.3	22.3	22.5	19.2	12.3	10.6	(35)
MCDBR			13.5	13.5	22.1	25.6	25.4	24.7	24.8	26.5	26.9	24.8	18.1	8.8	(36)	
MCWBR			11.7	10.8	11.8	10.3	8.8	8.2	9.1	10.3	10.6	11.8	11.7	7.1	(37)	
5% WB		MCDBR	12.9	12.7	21.0	22.9	22.5	21.6	22.5	24.1	24.6	22.6	16.9	7.9	(38)	
		MCWBR	11.2	10.2	11.4	9.7	8.2	7.9	9.3	10.1	10.3	11.0	11.2	6.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.372	0.414	0.469	0.509	0.475	0.473	0.464	0.441	0.425	0.419	0.396	0.368	(40)	
(41)		taud	1.997	1.948	1.882	1.849	1.997	2.075	2.135	2.185	2.153	2.065	2.051	2.027	(41)	
(42)		Ebn at Noon	217	232	237	240	254	255	256	257	250	228	208	204	(42)	
(43)		Edh at Noon	36	45	55	62	55	51	47	43	41	39	34	31	(43)	
(44)	All-Sky Solar Radiation	RadAvg	612	906	1252	1650	2027	2079	2064	1895	1528	987	580	486	(44)	
(45)		RadStd	29	49	107	136	111	84	110	90	86	93	63	45	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	-1.49	-1.64	N/A	N/A	N/A	N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page