

JINGHE XINJIANG, China

WMO: 513340

Lat: 44.5732N

Lon: 82.8196E

Elev: 330

StdP: 97.42

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -26.2	(c) -23.5	(d) -29.1	(e) 0.3	(f) -26.0	(g) -26.5	(h) 0.3	(i) -23.4	(j) 5.1	(k) -8.1	(l) 4.0	(m) -8.7	(n) 0.6	(o) 200	(p) 0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.8	(c) 36.3	(d) 20.3	(e) 34.8	(f) 19.8	(g) 33.4	(h) 19.4	(i) 22.0	(j) 33.0	(k) 21.2	(l) 31.9	(m) 20.4	(n) 30.9	(o) 2.2	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.8	26.6	17.4	13.0	26.2	16.5	12.2	25.8	66.1	33.1	63.0	32.0	60.3	31.0	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.8	(b) 5.2	(c) 4.3	(e) -27.4	(f) 39.3	(g) 2.8	(h) 1.3	(i) -29.4	(j) 40.2	(k) -31.1	(l) 41.0	(m) -32.7	(n) 41.7	(o) -34.7	(p) 42.6		
(a) 6.8	(b) 5.2	(c) 4.3	(e) -27.5	(f) 23.6	(g) 2.8	(h) 1.4	(i) -29.6	(j) 24.6	(k) -31.2	(l) 25.4	(m) -32.8	(n) 26.2	(o) -34.8	(p) 27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	-15.3	-10.0	2.2	13.6	20.3	25.5	26.6	24.7	18.7	10.1	0.7	-9.9		
	DBStd	15.16	5.20	5.75	6.29	5.02	4.14	3.20	2.68	3.10	4.02	4.43	4.98	5.40		
	HDD10.0	2574	784	561	252	24	0	0	0	0	1	55	279	618		
	HDD18.3	4226	1042	794	501	154	27	1	0	1	43	257	529	876		
	CDD10.0	2219	0	0	9	131	320	466	516	457	263	57	1	0		
	CDD18.3	829	0	0	0	11	89	217	258	199	54	1	0	0		
	CDH23.3	9248	0	0	0	128	907	2445	2997	2211	549	11	0	0		
	CDH26.7	4262	0	0	0	28	341	1193	1502	1025	172	1	0	0		
	WSAvg	1.5	0.9	1.2	1.6	2.0	2.1	2.0	1.8	1.7	1.5	1.3	1.2	1.0		
(15) Precipitation	PrecAvg	96	4	3	8	10	15	14	11	8	9	6	3	5		
	PrecMax	164	9	14	29	31	45	34	27	25	48	32	11	16		
	PrecMin	45	0	0	0	0	1	1	2	0	0	0	0	1		
	PrecStd	26	2	3	8	8	10	10	7	6	10	6	3	4		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.7	3.3	20.1	29.7	35.1	37.5	38.6	37.4	33.2	24.8	14.4	2.6		
		MCWB	-2.3	0.9	11.0	14.9	17.7	19.4	21.4	21.2	18.4	13.9	8.6	1.3		
	2%	DB	-3.9	1.3	16.9	26.7	32.4	35.8	36.5	35.2	30.6	22.1	11.1	0.9		
		MCWB	-5.1	-0.5	9.6	13.5	16.7	19.2	21.0	20.7	17.3	12.8	6.9	-0.3		
	5%	DB	-5.9	-0.4	14.4	24.3	30.4	34.2	34.8	33.6	28.6	19.8	9.1	-0.8		
		MCWB	-6.8	-2.0	8.4	12.7	16.0	18.8	20.5	20.1	16.5	11.7	6.0	-1.8		
	10%	DB	-7.9	-2.1	11.6	22.2	28.3	32.6	33.3	31.9	26.6	17.6	7.1	-2.4		
		MCWB	-8.6	-3.4	6.9	11.9	15.1	18.4	20.0	19.5	15.7	10.8	4.5	-3.3		
	0.4%	WB	-2.3	1.4	11.4	15.9	19.0	21.4	23.5	23.0	19.5	14.7	9.5	1.7		
		MCDB	-1.1	2.7	18.9	26.5	32.8	33.1	34.9	33.3	30.3	22.8	12.4	2.6		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-5.0	-0.4	9.9	14.5	17.7	20.5	22.3	21.9	18.2	13.4	7.3	-0.2		
		MCDB	-4.1	1.2	16.1	24.0	29.2	32.2	33.4	32.8	28.7	20.6	10.7	0.6		
	5%	WB	-6.8	-1.9	8.6	13.5	16.8	19.8	21.5	21.0	17.2	12.2	5.9	-1.7		
		MCDB	-5.9	-0.5	14.1	22.4	27.8	31.1	32.2	31.4	26.9	18.9	8.8	-0.7		
	10%	WB	-8.6	-3.5	7.1	12.5	16.0	19.1	20.7	20.1	16.3	11.1	4.6	-3.3		
		MCDB	-7.9	-2.1	11.4	20.9	26.3	30.3	31.1	30.2	25.3	17.0	7.0	-2.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	8.2	8.8	11.4	11.5	11.7	11.8	12.4	12.5	10.7	6.8	5.9		
		MCDBR	7.5	7.5	12.3	14.2	14.1	13.7	13.8	14.7	15.0	13.8	10.1	4.9		
		MCWBR	6.5	6.0	6.6	5.7	4.9	4.6	5.1	5.7	5.9	6.6	6.5	3.9		
	5% WB	MCDBR	7.2	7.0	11.7	12.7	12.5	12.0	12.5	13.4	13.7	12.6	9.4	4.4		
		MCWBR	6.2	5.7	6.3	5.4	4.5	4.4	5.2	5.6	5.7	6.1	6.2	3.6		
(40) Clear-Sky Solar Irradiance	taub		0.372	0.414	0.469	0.509	0.475	0.473	0.464	0.441	0.425	0.419	0.396	0.368		
	taud		1.997	1.948	1.882	1.849	1.997	2.075	2.135	2.185	2.153	2.065	2.051	2.027		
	Ebn at Noon		684	731	746	756	802	805	807	811	788	720	655	643		
	Edh at Noon		112	141	173	194	172	160	149	137	130	124	106	99		
(44) All-Sky Solar Radiation	RadAvg		1.93	2.86	3.95	5.20	6.39	6.55	6.51	5.97	4.82	3.11	1.83	1.53		
	RadStd		0.09	0.15	0.34	0.43	0.35	0.27	0.35	0.28	0.27	0.29	0.20	0.14		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	-0.83	-0.91	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page