

KORLA, China

WMO: 516560

Lat: 41.7302N

Lon: 85.8180E

Elev: 903

StdP: 90.94

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.2	-13.4	-21.3	0.6	-4.6	-19.2	0.8	-6.2	6.4	-5.7	5.8	-4.9	0.9	90	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	35.5	18.6	34.3	18.1	33.1	17.7	20.8	31.3	19.9	30.5	19.2	29.7	2.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.5	14.0	25.6	16.4	13.0	24.8	15.4	12.2	24.6	64.7	31.5	61.3	30.6	58.6	29.6	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.5	5.6	DB	-17.1	37.8	2.4	1.1	-18.8	38.6	-20.2	39.2	-21.5	39.9	-23.3	40.7	(4)
(5)			WB	-17.5	22.6	2.3	1.8	-19.1	23.9	-20.4	24.9	-21.7	25.9	-23.4	27.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	-6.8	0.0	8.5	16.1	21.3	25.6	27.1	25.9	20.5	12.5	3.7	-4.8	(6)	
	DBStd	12.24	3.25	4.01	4.47	4.29	3.76	3.08	2.87	2.94	3.11	3.86	3.80	3.33	(7)	
	HDD10.0	1555	519	281	83	6	0	0	0	0	0	18	189	458	(8)	
	HDD18.3	3054	778	514	304	91	16	1	0	1	13	183	438	716	(9)	
	CDD10.0	2482	0	0	38	189	351	467	529	494	316	97	1	0	(10)	
	CDD18.3	939	0	0	1	24	108	217	271	236	79	3	0	0	(11)	
	CDH23.3	10585	0	0	2	234	1100	2479	3273	2764	700	32	0	0	(12)	
	CDH26.7	4603	0	0	0	48	366	1097	1638	1267	184	2	0	0	(13)	
(14) Wind	WSAvg	2.3	1.7	2.1	2.6	2.9	2.8	2.6	2.6	2.4	2.3	2.0	1.7	1.6	(14)	
(15) Precipitation	PrecAvg	78	3	2	2	4	8	16	18	12	6	3	2	4	(15)	
	PrecMax	131	7	8	10	10	23	42	42	37	28	10	7	11	(16)	
	PrecMin	41	0	0	0	0	1	2	5	1	0	0	0	0	(17)	
	PrecStd	18	2	2	2	3	6	9	9	6	3	2	2	3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.6	11.8	23.2	30.6	33.5	35.8	37.9	36.5	32.2	26.3	17.2	5.8	(19)	
		MCWB	-1.4	3.8	9.4	14.0	15.6	17.9	18.9	19.2	17.5	13.3	7.5	1.2	(20)	
	2%	DB	1.4	9.6	20.5	27.9	31.8	34.4	36.1	34.8	30.3	23.9	14.6	3.4	(21)	
		MCWB	-2.6	2.6	8.0	12.6	15.2	17.5	19.0	18.5	16.5	12.2	6.0	-0.5	(22)	
	5%	DB	-0.2	8.0	18.5	26.0	30.4	33.2	34.8	33.5	28.8	22.0	12.6	1.8	(23)	
		MCWB	-3.6	1.6	7.3	11.8	14.6	17.3	18.7	18.2	15.9	11.2	5.3	-1.6	(24)	
	10%	DB	-1.7	6.3	16.5	24.2	28.7	32.0	33.2	32.2	27.2	20.1	10.6	0.3	(25)	
		MCWB	-4.6	0.5	6.3	10.7	13.9	16.8	18.2	17.8	15.2	10.2	4.3	-2.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.1	4.2	9.7	14.6	17.8	20.5	22.5	22.1	19.5	14.1	7.9	1.5	(27)	
		MCDB	3.1	10.7	22.1	29.2	29.9	31.0	33.2	31.6	29.1	23.6	16.0	5.3	(28)	
	2%	WB	-2.5	2.9	8.4	13.1	16.1	19.2	21.0	20.7	17.9	13.0	6.4	-0.2	(29)	
		MCDB	1.1	9.1	19.6	26.7	29.7	30.7	31.9	31.0	27.4	22.4	13.6	2.9	(30)	
	5%	WB	-3.5	1.8	7.4	12.1	15.2	18.3	20.1	19.9	16.9	11.9	5.4	-1.4	(31)	
		MCDB	-0.5	7.4	18.0	25.0	28.5	30.0	30.9	30.1	26.3	20.6	12.0	1.4	(32)	
	10%	WB	-4.5	0.8	6.5	11.1	14.4	17.7	19.3	19.1	16.0	10.8	4.5	-2.5	(33)	
		MCDB	-1.8	5.9	16.1	23.1	27.2	29.4	30.0	29.1	25.3	19.0	10.1	0.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	9.7	10.9	11.5	11.4	10.4	10.4	11.0	12.2	13.5	10.9	7.9	(35)	
		MCDBR	10.0	11.3	12.9	14.2	13.5	12.6	12.0	13.0	14.5	14.9	14.1	9.5	(36)	
		MCWBR	6.9	6.4	5.8	5.2	4.9	4.6	4.6	5.2	5.6	5.8	7.0	6.3	(37)	
	5% WB	MCDBR	9.5	10.8	12.7	13.6	12.3	11.5	11.7	12.6	14.0	14.4	13.6	9.1	(38)	
		MCWBR	6.7	6.2	5.9	5.2	5.0	4.9	5.2	5.7	6.0	5.7	6.9	6.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.342	0.397	0.482	0.532	0.556	0.572	0.533	0.548	0.544	0.475	0.397	0.355	(40)	
	taud		2.102	1.982	1.782	1.708	1.715	1.735	1.853	1.800	1.756	1.838	1.987	2.055	(41)	
	Ebn at Noon		769	776	748	745	741	730	754	724	684	677	685	705	(42)	
	Edh at Noon		107	142	196	227	231	227	200	205	200	163	120	104	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.27	3.28	4.54	5.64	6.42	6.56	6.47	5.92	5.11	3.89	2.65	1.94	(44)	
	RadStd		0.20	0.17	0.19	0.35	0.32	0.41	0.28	0.32	0.17	0.18	0.16	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	-0.89	-1.09	N/A	N/A	+118	+60	(46)	
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+108	+59	(47)	

Nomenclature: See separate page