

KASHI, China

WMO: 517090

Lat: 39.4862N

Lon: 75.7548E

Elev: 4550

StdP: 12.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	10.9	-4.5	5.1	31.5	-0.4	6.4	30.3	12.5	20.9	11.8	19.5	4.9	320	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	93.8	63.2	91.6	62.5	89.6	61.7	68.3	84.2	66.6	83.5	65.1	82.7	7.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.6	104.5	75.7	61.0	95.1	75.0	58.9	88.0	73.9	35.6	85.3	34.0	83.5	32.7	83.2	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	18.4	14.7	4.7	98.4	5.6	2.3	0.7	100.1	-2.6	101.5	-5.7	102.7	-9.7	104.4		
(5)			3.8	70.7	5.3	3.1	-0.1	72.9	-3.2	74.7	-6.2	76.4	-10.1	78.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.2	22.9	32.8	48.8	61.4	69.1	75.6	78.9	76.5	68.4	56.7	42.1	27.5		
	DBStd	20.04	6.46	7.14	7.71	7.11	5.91	4.91	4.69	4.70	4.82	6.08	6.88	5.82		
	HDD50	2408	841	481	118	9	0	0	0	0	0	11	250	698		
	HDD65	5026	1306	901	504	146	30	1	0	1	22	264	688	1163		
	CDD50	4290	0	0	80	350	591	769	894	822	553	219	12	0		
	CDD65	1433	0	0	0	37	156	320	430	358	125	7	0	0		
	CDH74	15531	0	0	12	416	1434	3480	5114	3868	1113	94	0	0		
	CDH80	6086	0	0	1	92	396	1382	2352	1582	273	8	0	0		
	WSAvg	6.2	4.1	4.8	5.9	7.5	8.2	8.3	7.5	7.0	6.4	5.8	4.8	4.1		
	PrecAvg	3.3	0.1	0.2	0.3	0.2	0.4	0.4	0.4	0.4	0.4	0.2	0.1	0.1		
(15) Precipitation	PrecMax	7.7	0.7	0.9	1.7	1.8	1.7	1.3	1.7	3.0	2.6	1.5	0.6	0.9		
(16) PrecipMin		0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
(17) PrecStd		1.8	0.2	0.3	0.4	0.4	0.4	0.4	0.4	0.6	0.5	0.3	0.2	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	47.5	56.5	75.2	87.6	89.8	95.1	98.3	96.2	89.1	80.7	68.5	53.4			
	0.4% MCWB	34.2	39.7	49.2	55.5	57.6	62.1	63.5	64.2	61.7	53.6	47.0	36.9			
	2% DB	39.8	51.4	70.0	82.4	87.2	91.8	95.0	92.5	85.9	76.7	62.8	43.3			
	2% MCWB	30.3	37.6	46.3	53.5	56.9	61.0	63.3	63.7	59.5	53.6	44.4	33.6			
	5% DB	35.9	47.8	66.3	78.8	84.4	89.7	92.8	89.9	83.2	73.2	58.8	39.3			
	5% MCWB	28.1	35.9	45.0	52.0	56.2	60.3	63.3	63.1	58.5	51.9	42.7	31.4			
	10% DB	32.4	44.4	62.6	75.2	82.0	87.6	90.0	87.8	80.5	69.8	54.7	36.0			
	10% MCWB	26.0	33.6	43.4	50.5	55.5	59.6	62.6	62.7	58.1	50.1	40.7	29.2			
	0.4% WB	34.5	41.5	50.3	57.2	62.2	68.6	71.4	71.0	66.1	57.3	48.9	37.9			
	0.4% MCDB	46.0	51.8	71.9	81.5	81.0	84.6	86.1	85.5	82.3	72.7	66.0	50.7			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	30.8	38.4	47.7	55.0	60.2	65.3	68.5	68.4	63.0	55.4	45.2	34.0			
	2% MCDB	39.1	49.2	66.6	78.1	79.2	83.6	84.9	83.6	79.1	71.8	60.6	41.9			
	5% WB	28.4	36.2	45.8	53.3	58.6	63.5	66.7	66.6	61.2	53.7	43.2	31.7			
	5% MCDB	35.2	46.4	63.2	75.6	78.0	82.8	84.2	82.9	76.9	69.3	56.0	38.5			
	10% WB	26.3	34.2	44.3	51.7	57.2	62.0	65.3	65.1	59.8	51.8	41.4	29.7			
	10% MCDB	31.9	43.2	60.4	71.4	77.1	81.6	83.5	81.9	75.3	65.6	53.1	35.5			
(35) Mean Daily Temperature Range	MDBR	16.6	17.0	18.5	20.4	20.4	20.6	20.1	19.7	20.7	22.1	19.4	14.9			
	5% DB MCDBR	21.7	21.3	24.6	26.3	24.3	22.8	22.7	22.5	24.8	26.1	26.2	19.3			
	5% DB MCWBR	13.7	11.4	10.8	10.0	9.3	9.3	9.9	9.8	9.4	10.1	12.0	11.5			
	5% WB MCDBR	20.9	20.3	22.3	24.7	22.0	21.2	20.8	20.8	22.8	23.8	24.5	18.7			
	5% WB MCWBR	13.5	11.2	10.2	9.8	9.0	9.6	9.5	9.7	9.2	9.5	11.3	11.2			
(40) Clear-Sky Solar Irradiance	taub	0.328	0.377	0.489	0.540	0.544	0.519	0.518	0.565	0.547	0.467	0.393	0.339			
	taud	2.168	2.041	1.769	1.685	1.735	1.832	1.858	1.743	1.729	1.852	1.996	2.127			
	Ebn at Noon	259	259	239	237	239	246	245	228	220	223	227	242			
	Edh at Noon	33	44	64	75	72	66	64	69	66	53	40	32			
	RadAvg	799	1072	1452	1816	2093	2271	2182	1946	1645	1304	918	719			
(45) All-Sky Solar Radiation	RadStd	82	96	118	82	114	101	108	101	108	70	69	72			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.99	N/A	N/A	+1.06	-2.29	-3.55	N/A	N/A	+301	+153
(47) Regional (1 neighbor)		+0.88	N/A	N/A	+0.95	-2.43	-3.73	N/A	N/A	+261	+135

Nomenclature: See separate page