

KASHI, China

WMO: 517090

Lat: 39.4862N

Lon: 75.7548E

Elev: 1387

StdP: 85.74

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.9	-11.7	-20.3	0.7	-0.3	-18.0	0.9	-1.0	5.6	-6.2	5.3	-7.0	2.2	320	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	34.3	17.3	33.1	16.9	32.0	16.5	20.2	29.0	19.2	28.6	18.4	28.2	3.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	14.9	24.3	16.1	13.6	23.9	14.9	12.6	23.3	64.9	29.6	61.1	28.6	58.2	28.4	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.3	8.2	6.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-15.2	36.9	3.1	1.3	-17.4	37.8	-19.2	38.6	-20.9	39.3	-23.2	40.2
			-15.7	21.5	3.0	1.7	-17.8	22.7	-19.6	23.7	-21.2	24.7	-23.4	25.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	-5.1	0.5	9.3	16.3	20.6	24.2	26.0	24.7	20.2	13.7	5.6	-2.5	(6)
(7)		DBStd	11.13	3.59	3.97	4.28	3.95	3.28	2.73	2.60	2.61	2.68	3.38	3.82	3.23	(7)
(8)		HDD10.0	1338	467	267	66	5	0	0	0	0	6	139	388		(8)
(9)		HDD18.3	2792	726	501	280	81	17	1	0	1	12	147	382	646	(9)
(10)		CDD10.0	2383	0	0	44	194	328	427	497	457	307	122	7	0	(10)
(11)		CDD18.3	796	0	0	0	21	87	178	239	199	69	4	0	0	(11)
(12)		CDH23.3	8628	0	0	7	231	797	1933	2841	2149	618	52	0	0	(12)
(13)		CDH26.7	3381	0	0	1	51	220	768	1307	879	152	4	0	0	(13)
(14)	Wind	WSAvg	2.8	1.9	2.1	2.6	3.3	3.7	3.4	3.1	2.8	2.6	2.1	1.8		(14)
(15)	Precipitation	PrecAvg	83	3	6	7	6	11	10	11	10	9	5	2	3	(15)
(16)		PrecMax	195	17	23	43	45	42	34	42	77	66	37	16	24	(16)
(17)		PrecMin	18	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	45	4	7	11	10	11	9	10	15	13	8	4	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	13.6	24.0	30.9	32.1	35.1	36.8	35.7	31.7	27.0	20.3	11.9	(19)
(20)			MCWB	1.2	4.3	9.5	13.1	14.2	16.7	17.5	17.9	16.5	12.0	8.4	2.7	(20)
(21)		2%	DB	4.3	10.8	21.1	28.0	30.7	33.2	35.0	33.6	29.9	24.9	17.1	6.3	(21)
(22)			MCWB	-0.9	3.1	8.0	11.9	13.8	16.1	17.4	17.6	15.3	12.0	6.9	0.9	(22)
(23)		5%	DB	2.1	8.8	19.0	26.0	29.1	32.1	33.8	32.2	28.4	22.9	14.9	4.0	(23)
(24)			MCWB	-2.2	2.1	7.2	11.1	13.5	15.7	17.4	17.3	14.7	11.0	5.9	-0.3	(24)
(25)		10%	DB	0.2	6.9	17.0	24.0	27.8	30.9	32.2	31.0	27.0	21.0	12.6	2.2	(25)
(26)			MCWB	-3.3	0.9	6.3	10.3	13.1	15.3	17.0	17.1	14.5	10.0	4.8	-1.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.4	5.3	10.2	14.0	16.8	20.3	21.9	21.7	18.9	14.1	9.4	3.3	(27)
(28)			MCDWB	7.8	11.0	22.2	27.5	27.2	29.2	30.1	29.7	28.0	22.6	18.9	10.4	(28)
(29)		2%	WB	-0.7	3.6	8.7	12.8	15.7	18.5	20.3	20.2	17.2	13.0	7.4	1.1	(29)
(30)			MCDWB	3.9	9.6	19.2	25.6	26.2	28.7	29.4	28.7	26.2	22.1	15.9	5.5	(30)
(31)		5%	WB	-2.0	2.4	7.7	11.9	14.8	17.5	19.3	19.2	16.2	12.0	6.2	-0.2	(31)
(32)			MCDWB	1.8	8.0	17.3	24.2	25.5	28.2	29.0	28.3	24.9	20.7	13.4	3.6	(32)
(33)		10%	WB	-3.1	1.2	6.8	10.9	14.0	16.7	18.5	18.4	15.4	11.0	5.2	-1.3	(33)
(34)			MCDWB	0.0	6.2	15.8	21.9	25.1	27.5	28.6	27.7	24.0	18.7	11.7	2.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.2	9.4	10.3	11.3	11.4	11.4	11.2	10.9	11.5	12.3	10.8	8.3	(35)
(36)			MCDBR	12.0	11.8	13.7	14.6	13.5	12.7	12.6	12.5	13.8	14.5	14.5	10.7	(36)
(37)			MCWBR	7.6	6.4	6.0	5.6	5.1	5.2	5.5	5.5	5.2	5.6	6.7	6.4	(37)
(38)		5% WB	MCDWR	11.6	11.3	12.4	13.7	12.2	11.8	11.6	11.6	12.7	13.2	13.6	10.4	(38)
(39)			MCWBR	7.5	6.2	5.7	5.5	5.0	5.3	5.3	5.4	5.1	5.3	6.3	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.328	0.377	0.489	0.540	0.544	0.519	0.518	0.565	0.547	0.467	0.393	0.339	(40)	
(41)		taud	2.168	2.041	1.769	1.685	1.735	1.832	1.858	1.743	1.729	1.852	1.996	2.127	(41)	
(42)		Ebn at Noon	815	818	753	746	755	775	771	718	693	703	717	763	(42)	
(43)		Edh at Noon	105	138	203	235	228	208	201	219	209	166	125	102	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.52	3.38	4.58	5.72	6.60	7.16	6.88	6.13	5.19	4.11	2.89	2.27	(44)	
(45)		RadStd	0.26	0.30	0.37	0.26	0.36	0.32	0.34	0.32	0.34	0.22	0.22	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.55	N/A	N/A	+0.59	-1.27	-1.97	N/A	N/A	+167	+85
(47)	Regional (1 neighbor)	+0.49	N/A	N/A	+0.53	-1.35	-2.07	N/A	N/A	+145	+75

Nomenclature: See separate page