

TAZHONG, China

WMO: 517470

Lat: 38.9676N

Lon: 83.6597E

Elev: 3609

StdP: 12.88

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.6	-5.6	-18.3	2.3	-2.4	-14.8	2.8	2.5	11.9	29.0	10.5	28.1	0.5	200	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.0	102.1	61.9	99.5	61.2	97.1	60.5	64.4	85.5	63.5	87.0	62.6	88.4	8.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.8	87.7	68.5	57.1	79.5	70.2	54.2	71.4	71.7	31.5	84.1	30.7	86.9	30.0	88.0	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	15.7	13.5	-12.4	106.3	4.5	2.3	-15.6	108.0	-18.3	109.3	-20.8	110.6	-24.1	112.2		
(5)			-13.1	66.5	4.4	2.4	-16.2	68.2	-18.8	69.7	-21.3	71.0	-24.4	72.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	14.2	27.1	46.1	60.5	69.7	78.5	82.0	80.1	68.9	52.7	34.3	18.2	(6)
(7)		DBStd	24.44	7.30	9.29	8.28	7.48	6.31	5.32	4.69	5.08	5.49	7.34	7.52	5.99	(7)
(8)		HDD50	3448	1111	642	175	10	0	0	0	0	54	471	985		(8)
(9)		HDD65	6206	1576	1062	587	174	30	0	0	23	384	920	1450		(9)
(10)		CDD50	4474	0	0	53	324	612	854	992	932	567	139	1	0	(10)
(11)		CDD65	1756	0	0	0	37	177	404	527	467	141	3	0	0	(11)
(12)		CDH74	26625	0	0	51	968	2794	5608	7586	6871	2458	289	0	0	(12)
(13)		CDH80	14392	0	0	6	333	1256	3145	4531	4022	1040	59	0	0	(13)
(14)	Wind	WSAvg	5.0	2.4	3.5	4.9	6.3	6.9	7.0	7.1	6.6	5.6	4.0	2.8	2.4	(14)
(15)	Precipitation	PrecAvg	1.0	0.0	0.0	0.0	0.0	0.2	0.4	0.2	0.1	0.0	0.0	0.0	0.0	(15)
(16)		PrecMax	1.8	0.1	0.0	0.0	0.4	0.9	0.9	0.5	0.7	0.3	0.2	0.1	0.0	(16)
(17)		PrecMin	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	0.4	0.0	0.0	0.0	0.1	0.3	0.4	0.2	0.2	0.1	0.0	0.0	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	58.4	80.3	92.9	96.5	102.6	106.7	104.2	95.3	85.5	67.9	45.1	(19)
(20)			MCWB	29.9	39.7	49.2	55.1	57.1	60.8	62.8	62.6	58.7	54.0	45.0	32.6	(20)
(21)		2%	DB	37.0	53.8	74.6	87.7	93.5	99.7	103.2	100.9	92.0	81.1	60.9	39.9	(21)
(22)			MCWB	27.2	37.2	46.9	53.3	56.4	60.2	62.4	61.9	57.4	52.3	41.4	29.6	(22)
(23)		5%	DB	32.7	49.9	70.6	83.8	90.6	97.0	100.3	98.5	89.4	76.9	56.5	35.7	(23)
(24)			MCWB	24.6	35.1	45.3	51.7	55.5	59.5	62.0	61.0	56.8	50.3	39.7	27.0	(24)
(25)		10%	DB	28.9	45.6	66.3	79.9	87.6	94.4	97.3	96.1	86.5	72.5	51.8	31.7	(25)
(26)			MCWB	22.4	32.7	43.3	50.1	54.5	59.1	61.4	60.5	56.1	48.5	37.6	24.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.2	40.1	49.5	55.5	59.4	64.5	65.9	65.7	61.2	54.6	45.2	32.9	(27)
(28)			MCD B	41.7	56.9	78.3	89.8	87.1	77.0	86.7	83.7	84.1	82.9	67.4	45.2	(28)
(29)		2%	WB	27.3	37.7	47.2	54.0	57.7	63.1	64.6	64.2	59.6	52.7	41.7	29.7	(29)
(30)			MCD B	36.2	52.6	73.1	86.2	87.8	80.3	87.1	86.3	83.6	79.3	59.4	39.6	(30)
(31)		5%	WB	24.9	35.3	45.5	52.2	56.6	62.0	63.7	63.1	58.3	50.9	39.9	27.2	(31)
(32)			MCD B	32.4	49.4	69.7	81.9	86.2	82.5	88.4	88.2	83.6	75.9	55.7	35.1	(32)
(33)		10%	WB	22.5	32.9	43.6	50.5	55.4	61.1	62.9	62.1	56.9	48.8	37.7	24.9	(33)
(34)			MCD B	28.9	45.1	65.8	78.2	83.8	84.4	89.9	88.9	82.9	71.6	51.4	31.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	29.7	30.5	32.3	31.2	28.9	25.7	26.0	27.8	31.8	36.4	33.6	29.8	(35)
(36)			MCD BR	33.5	35.2	39.1	38.3	36.5	32.9	33.7	33.8	37.4	39.8	39.1	34.2	(36)
(37)			MCWBR	25.2	22.2	20.5	16.5	12.8	9.2	8.8	9.7	12.7	17.6	23.1	25.2	(37)
(38)		5% WB	MCD BR	32.5	33.9	37.1	34.9	29.6	22.8	24.7	26.1	31.4	38.4	37.4	32.9	(38)
(39)			MCWBR	24.6	21.4	19.5	14.8	10.3	6.1	6.2	7.2	10.4	16.9	22.4	24.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.348	0.417	0.515	0.599	0.632	0.663	0.632	0.644	0.608	0.478	0.397	0.357	(40)	
(41)		taud	2.054	1.887	1.670	1.519	1.514	1.507	1.583	1.551	1.577	1.766	1.939	2.024	(41)	
(42)		Ebn at Noon	250	245	232	222	219	212	217	209	204	220	226	234	(42)	
(43)		Edh at Noon	38	52	71	89	91	91	84	85	78	58	42	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	868	1168	1574	1904	2155	2194	2131	1973	1742	1421	1009	796	(44)	
(45)		RadStd	102	65	80	94	95	100	85	119	49	47	41	50	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		-1.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-250	-211
(47) Regional (2 neighbors)		-1.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-250	-211

Nomenclature: See separate page