

PISHAN, China

WMO: 518180

Lat: 37.6147N

Lon: 78.2760E

Elev: 1376

StdP: 85.85

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-12.1	-20.4	0.7	-5.0	-18.7	0.8	-3.8	4.5	1.2	4.1	-0.6	0.7	270	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	36.0	17.8	34.5	17.4	33.2	16.8	19.5	31.8	18.7	30.8	18.0	29.8	1.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.7	13.2	23.0	14.9	12.6	22.8	14.1	11.9	22.9	61.9	32.0	59.0	30.8	56.8	29.8	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.3	4.4	3.9	DB	-15.5	38.5	2.8	1.2	-17.6	39.4	-19.2	40.1	-20.8	40.7	-22.9	41.6	(4)
(5)			WB	-16.0	21.2	2.7	1.7	-18.0	22.4	-19.6	23.4	-21.1	24.3	-23.0	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	-4.8	0.9	9.9	16.8	21.2	24.7	26.3	25.1	20.6	13.7	5.5	-2.4	(6)	
	DBStd	11.26	4.14	4.10	4.23	4.03	3.29	2.80	2.85	2.85	2.81	3.53	3.93	3.42	(7)	
	HDD10.0	1311	460	255	56	4	0	0	0	0	0	7	143	385	(8)	
	HDD18.3	2743	718	488	262	72	13	1	0	1	10	148	386	643	(9)	
	CDD10.0	2470	0	0	52	209	348	440	504	469	318	122	8	0	(10)	
	CDD18.3	860	0	0	1	26	102	191	246	211	78	5	0	0	(11)	
	CDH23.3	9541	0	0	15	329	1098	2082	2912	2287	754	64	0	0	(12)	
	CDH26.7	4182	0	0	2	84	381	936	1491	1062	222	5	0	0	(13)	
(14) Wind	WSAvg	1.6	1.2	1.4	1.8	2.0	2.0	2.1	1.8	1.7	1.6	1.4	1.3	1.2	(14)	
(15) Precipitation	PrecAvg	50	1	4	3	4	10	6	7	4	5	2	1	1	(15)	
	PrecMax	109	8	20	23	39	50	24	34	18	27	18	7	6	(16)	
	PrecMin	15	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	25	2	6	6	9	14	7	9	6	7	5	1	2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	15.0	25.1	31.7	33.9	36.6	38.2	37.4	32.7	27.2	20.6	12.0	(19)	
		MCWB	2.1	5.0	9.4	13.3	15.1	17.4	18.5	18.2	16.6	12.8	8.1	3.0	(20)	
	2%	DB	6.8	12.4	22.3	29.0	31.8	34.5	36.5	35.2	30.9	25.1	17.5	8.1	(21)	
		MCWB	-0.4	3.5	8.2	12.3	14.2	16.6	18.1	17.8	15.7	12.2	6.5	0.8	(22)	
	5%	DB	3.9	10.1	20.3	27.1	30.4	33.2	35.0	33.7	29.2	23.2	15.2	5.6	(23)	
		MCWB	-1.8	2.2	7.5	11.4	13.8	16.1	17.8	17.4	15.0	11.2	5.5	-0.4	(24)	
	10%	DB	1.7	8.0	18.1	25.0	28.9	31.7	33.5	32.1	27.6	21.2	13.0	3.5	(25)	
		MCWB	-3.0	1.0	6.4	10.6	13.3	15.8	17.4	17.2	14.5	10.2	4.5	-1.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	5.8	10.0	14.1	16.3	19.1	21.1	20.6	18.5	14.0	8.7	3.1	(27)	
		MCDB	10.8	13.3	23.6	29.3	29.8	32.3	33.8	32.7	30.0	24.2	19.4	11.3	(28)	
	2%	WB	-0.3	3.9	8.7	12.8	15.3	17.8	19.7	19.2	16.9	12.7	6.8	1.0	(29)	
		MCDB	6.3	11.3	21.1	27.4	28.6	30.8	32.0	31.6	26.8	23.8	16.7	7.7	(30)	
	5%	WB	-1.7	2.5	7.7	12.0	14.6	17.1	18.9	18.5	16.1	11.7	5.6	-0.3	(31)	
		MCDB	3.6	9.2	19.3	25.2	27.5	30.1	31.1	30.5	25.8	21.9	14.4	5.1	(32)	
	10%	WB	-2.9	1.3	6.7	11.1	13.9	16.5	18.2	18.0	15.3	10.8	4.6	-1.5	(33)	
		MCDB	1.5	7.5	17.1	23.5	26.5	29.0	30.1	29.3	25.0	20.2	12.6	3.3	(34)	
(35) Mean Daily Temperature Range	MDBR		10.3	10.3	11.5	12.0	12.2	11.7	12.0	11.5	12.3	13.8	12.8	10.2	(35)	
	5% DB	MCDBR	13.8	13.3	14.4	15.4	14.8	14.0	15.1	14.8	14.9	15.1	15.5	13.4	(36)	
		MCWBR	8.7	7.2	6.7	6.4	5.6	4.7	4.9	5.1	5.7	6.4	7.8	8.0	(37)	
	5% WB	MCDBR	13.2	12.5	13.4	13.4	13.2	12.4	12.6	12.5	12.8	13.9	14.7	12.7	(38)	
		MCWBR	8.4	6.9	6.3	5.6	5.0	4.3	4.7	4.7	5.3	6.1	7.5	7.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.334	0.401	0.521	0.600	0.616	0.626	0.616	0.659	0.615	0.471	0.388	0.350	(40)	
	taud		2.109	1.933	1.653	1.537	1.554	1.571	1.611	1.532	1.571	1.791	1.966	2.057	(41)	
	Ebn at Noon		821	800	732	704	704	697	699	653	646	711	739	765	(42)	
	Edh at Noon		116	158	232	275	275	271	258	274	249	180	133	114	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.71	3.60	5.05	6.04	6.87	7.05	6.62	5.89	5.32	4.52	3.31	2.62	(44)	
	RadStd		0.40	0.34	0.34	0.26	0.35	0.31	0.44	0.46	0.32	0.14	0.18	0.21	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	-0.80	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	+0.42	N/A	N/A	N/A	-1.04	-1.28	N/A	-132	+144	+67

Nomenclature: See separate page