

ANDIR, China

WMO: 518480

Lat: 37.933N

Lon: 83.650E

Elev: 4147

StdP: 12.62

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.3	3.4	-10.4	3.7	20.3	-8.0	4.2	18.8	12.0	27.6	9.6	31.9	1.0	200	0.461

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.4	98.9	62.8	96.6	61.9	94.1	61.3	66.3	88.6	64.8	87.7	63.7	86.8	4.3	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.0	90.3	71.8	58.0	83.9	71.5	56.0	78.1	71.8	33.4	88.5	32.2	88.1	31.2	86.9	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.5	9.0	-4.4	104.0	2.6	2.7	-6.3	106.0	-7.8	107.6	-9.2	109.1	-11.1	111.1		
(5)			-5.0	71.5	2.5	2.5	-6.8	73.3	-8.2	74.8	-9.6	76.2	-11.4	78.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	18.7	29.3	44.2	59.0	68.2	76.0	79.0	76.5	67.3	51.1	36.2	22.3	(6)
(7)		DBStd	21.79	5.57	5.74	6.32	7.22	6.32	4.53	4.48	4.87	5.32	6.23	7.39	5.73	(7)
(8)		HDD50	3093	970	581	196	8	1	0	0	0	0	61	417	859	(8)
(9)		HDD65	5983	1435	1001	644	205	41	1	0	1	36	430	865	1324	(9)
(10)		CDD50	3980	0	0	17	280	564	779	900	821	520	97	2	0	(10)
(11)		CDD65	1392	0	0	0	26	139	330	435	357	105	0	0	0	(11)
(12)		CDH74	19943	0	0	0	614	2144	4363	5922	4921	1876	103	0	0	(12)
(13)		CDH80	9995	0	0	0	190	851	2217	3310	2694	728	5	0	0	(13)
(14)	Wind	WSAvg	3.3	2.4	3.0	4.3	4.5	4.1	3.7	3.4	3.6	3.1	2.7	2.4	2.1	(14)
(15)	Precipitation	PrecAvg	0.8	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.1	0.0	0.0	0.0	0.0	(15)
(16)		PrecMax	1.7	0.1	0.2	0.3	0.8	0.9	0.7	1.2	0.3	0.2	0.2	0.0	0.1	(16)
(17)		PrecMin	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	0.4	0.0	0.0	0.0	0.2	0.2	0.2	0.3	0.1	0.0	0.0	0.0	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	54.4	71.1	90.7	95.0	99.3	103.2	101.5	95.2	80.0	67.4	47.2	(19)
(20)			MCWB	30.1	37.3	44.6	55.5	58.9	63.2	65.3	63.0	59.9	52.0	44.6	34.4	(20)
(21)		2%	DB	37.8	50.2	67.7	85.2	91.4	96.1	99.5	98.3	91.4	77.1	61.9	41.3	(21)
(22)			MCWB	27.7	35.6	43.6	53.6	57.6	61.2	63.5	62.2	58.9	50.4	41.9	30.8	(22)
(23)		5%	DB	34.2	46.4	63.6	81.2	88.1	93.7	97.0	95.9	87.2	73.4	57.2	37.5	(23)
(24)			MCWB	25.7	33.3	41.8	52.2	56.1	60.8	63.0	61.3	57.1	49.4	39.9	28.3	(24)
(25)		10%	DB	31.0	42.9	60.0	76.7	85.1	91.1	94.2	93.0	84.2	68.8	52.2	34.1	(25)
(26)			MCWB	23.6	31.1	40.3	50.0	55.2	60.2	62.7	61.0	56.0	47.0	37.6	26.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.8	38.3	45.7	57.7	62.2	67.3	69.3	67.4	62.8	53.4	45.0	34.7	(27)
(28)			MCD B	41.6	52.7	68.7	85.0	82.5	90.1	90.7	87.2	88.4	76.2	66.2	46.0	(28)
(29)		2%	WB	27.9	35.9	43.8	54.6	59.4	64.9	66.6	65.2	60.5	51.3	42.2	31.3	(29)
(30)			MCD B	37.2	49.6	65.2	83.5	85.9	88.1	89.5	87.3	85.2	74.4	60.9	39.4	(30)
(31)		5%	WB	25.9	33.5	42.3	52.7	58.0	63.3	65.3	63.8	58.9	49.6	40.1	29.0	(31)
(32)			MCD B	34.0	45.7	62.3	79.7	83.9	86.9	88.3	87.2	81.7	72.3	56.4	36.5	(32)
(33)		10%	WB	23.8	31.2	40.7	50.6	56.5	61.9	64.2	62.7	57.5	47.5	38.0	26.9	(33)
(34)			MCD B	30.9	42.2	58.8	74.8	81.4	85.1	87.2	87.2	79.0	67.8	51.8	34.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	24.8	26.5	26.2	27.6	27.9	26.5	26.4	29.1	32.3	33.4	30.2	24.9	(35)
(36)			MCDBR	28.9	29.9	33.3	34.4	34.9	33.6	33.9	36.4	37.7	38.7	36.3	28.8	(36)
(37)			MCWBR	20.8	18.7	16.7	15.0	12.8	11.1	11.0	11.6	14.2	17.1	20.1	19.8	(37)
(38)		5% WB	MCD BR	27.9	28.4	30.8	32.2	29.5	26.0	25.5	29.1	32.8	36.1	35.6	27.0	(38)
(39)			MCWBR	20.1	18.0	15.7	14.5	12.5	10.0	9.8	10.3	13.0	15.8	19.7	18.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.342	0.408	0.511	0.601	0.635	0.654	0.632	0.632	0.585	0.451	0.380	0.349	(40)	
(41)		taud	2.062	1.898	1.662	1.503	1.497	1.513	1.578	1.566	1.613	1.820	1.975	2.041	(41)	
(42)		Ebn at Noon	255	250	234	222	219	214	218	213	212	231	236	241	(42)	
(43)		Edh at Noon	38	52	73	90	92	91	85	84	75	55	42	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	908	1202	1645	1960	2196	2211	2144	1986	1782	1478	1056	841	(44)	
(45)		RadStd	101	67	78	87	90	89	104	128	57	35	47	42	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (3 neighbors)		-1.55	N/A	N/A	N/A	N/A	N/A	N/A	-250	-211

Nomenclature: See separate page