

YUTIAN KERIYA, China

WMO: 519310

Lat: 36.850N

Lon: 81.650E

Elev: 5098

StdP: 12.18

Time Zone: 8.00 (E08)

Period: 82-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	11.9	-5.2	5.0	25.1	-2.1	5.9	25.6	13.7	35.1	9.4	29.0	1.8	N/A	0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.8	94.8	66.6	92.2	66.3	89.6	65.1	72.0	88.6	69.7	87.3	67.5	85.5	2.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.8	119.6	84.9	63.7	106.9	81.9	61.2	97.6	77.8	39.7	87.8	37.2	87.2	35.2	85.2	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	9.3	7.6	DB	3.2	99.7	5.5	1.9	-0.8	101.1	-4.0	102.2	-7.1	103.3	-11.0	104.7	(4)
			WB	3.0	77.8	3.7	1.8	0.4	79.1	-1.8	80.2	-3.8	81.2	-6.5	82.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.0	24.1	32.6	45.5	58.2	67.0	72.7	76.1	74.1	65.4	52.7	39.5	26.6	(6)
		DBStd	18.97	5.49	5.41	6.65	6.10	5.88	4.54	4.04	4.65	4.56	6.23	6.40	6.47	(7)
		HDD50	2554	802	488	170	8	1	0	0	0	43	317	725		(8)
		HDD65	5431	1267	908	603	216	46	3	0	49	382	764	1190		(9)
		CDD50	3643	0	0	32	253	527	682	810	748	463	126	2	0	(10)
		CDD65	1047	0	0	0	11	107	236	345	286	62	0	0	0	(11)
		CDH74	12448	0	0	0	336	1356	2612	3878	3232	951	83	0	0	(12)
		CDH80	5035	0	0	0	82	425	1025	1820	1443	233	7	0	0	(13)
(14)	Wind	WSAvg	2.9	2.7	3.0	3.6	3.7	3.4	3.3	2.8	2.3	2.5	2.5	2.6	2.2	(14)
(15)	Precipitation	PrecAvg	2.4	0.1	0.1	0.1	0.1	0.2	0.6	0.4	0.3	0.3	0.0	0.0	0.0	(15)
(16)		PrecMax	7.2	0.4	0.4	0.6	1.3	1.1	3.3	1.7	2.8	2.7	0.3	0.1	0.2	(16)
(17)		PrecMin	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.5	0.1	0.1	0.2	0.4	0.3	0.7	0.4	0.6	0.7	0.1	0.0	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	46.3	57.5	71.3	87.2	91.9	96.8	97.8	97.4	89.0	80.4	66.6	51.4		(19)
(20)		MCWB	32.6	38.8	46.4	56.8	60.7	64.6	67.0	68.9	61.2	53.1	44.7	35.7		(20)
(21)		DB	40.5	51.0	67.5	81.7	88.0	92.8	94.8	93.9	85.3	76.0	61.0	44.4		(21)
(22)		MCWB	29.5	35.6	44.8	54.0	60.0	63.9	67.2	68.1	60.8	52.4	41.9	32.5		(22)
(23)		DB	37.3	47.3	64.2	77.9	85.0	89.0	92.4	91.3	82.6	71.6	56.8	40.4		(23)
(24)		MCWB	27.8	33.4	43.5	51.9	58.6	62.3	66.9	67.9	59.3	50.6	40.5	30.3		(24)
(25)		DB	34.2	43.8	60.3	73.8	81.8	86.4	89.5	88.4	79.7	67.6	52.7	36.7		(25)
(26)		MCWB	26.1	31.8	41.7	49.7	57.5	61.5	66.0	66.6	57.6	48.4	38.7	28.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	32.8	39.5	47.6	58.5	66.4	69.7	74.8	76.5	68.8	56.7	45.6	36.5		(27)
(28)		MCDB	45.5	55.1	68.4	84.5	85.7	88.0	89.7	90.5	82.3	71.6	62.8	51.0		(28)
(29)		WB	29.7	36.0	45.6	55.3	62.8	66.6	71.8	72.9	64.6	53.9	42.9	32.8		(29)
(30)		MCDB	39.0	49.7	65.9	79.9	83.3	86.8	88.9	88.9	79.9	73.6	59.7	43.1		(30)
(31)		WB	28.0	33.9	43.9	52.7	60.5	64.6	69.5	70.3	62.0	51.6	40.9	30.7		(31)
(32)		MCDB	36.3	45.8	63.1	75.6	80.7	85.1	87.9	87.2	78.6	71.0	56.1	39.3		(32)
(33)		WB	26.5	32.0	42.1	50.2	58.5	62.8	67.3	68.2	59.7	49.0	38.9	28.7		(33)
(34)		MCDB	34.0	43.1	59.6	71.6	79.3	82.7	85.9	85.7	76.4	65.3	52.4	36.5		(34)
(35)	Mean Daily Temperature Range	MDBR	18.6	19.3	22.7	24.9	24.1	23.7	23.8	25.0	28.9	29.1	23.3	18.4		(35)
(36)		5% DB	22.9	25.6	28.2	33.6	31.6	30.2	31.1	32.7	33.8	34.0	30.3	24.3		(36)
(37)		MCWBR	14.5	13.8	13.3	15.7	16.2	13.5	14.2	17.0	15.3	16.2	16.0	14.8		(37)
(38)		5% WB	21.9	23.6	26.9	30.7	25.8	25.7	27.1	30.0	29.1	34.1	30.3	22.6		(38)
(39)		MCWBR	14.1	13.0	13.1	15.0	14.7	13.3	14.4	18.1	16.0	16.4	15.9	13.9		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.314	0.374	0.484	0.581	0.614	0.632	0.626	0.641	0.576	0.438	0.356	0.326		(40)
(41)		taud	2.179	1.998	1.718	1.544	1.534	1.551	1.588	1.553	1.634	1.859	2.058	2.130		(41)
(42)		Ebn at Noon	272	266	244	228	224	220	220	212	216	238	251	257		(42)
(43)		Edh at Noon	35	47	69	87	89	88	84	85	75	54	39	34		(43)
(44)	All-Sky Solar Radiation	RadAvg	928	1208	1651	1940	2139	2085	1970	1831	1685	1497	1098	882		(44)
(45)		RadStd	94	75	93	76	104	103	160	151	94	39	53	49		(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (2 neighbors)	+1.03	N/A	N/A	N/A	-1.73	-2.30	N/A	-252	+272	+110	(47)

Nomenclature: See separate page