

EJIN QI, China

WMO: 522670

Lat: 41.950N

Lon: 101.067E

Elev: 3087

StdP: 13.13

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.6	(c) -1.3	(d) -24.4	(e) 1.6	(f) 9.6	(g) -20.9	(h) 2.0	(i) 12.0	(j) 19.3	(k) 21.6	(l) 16.9	(m) 20.9	(n) 3.2	(o) 90	(p) 0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	99.5	63.2	96.8	62.1	94.2	61.2	66.8	87.2	65.2	86.4	63.8	86.1	6.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.2	90.5	71.7	58.4	81.9	73.3	55.5	73.5	74.8	33.2	88.1	31.9	86.4	30.8	85.6	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	16.6	14.6	-10.2	103.7	5.4	2.3	-14.1	105.4	-17.2	106.8	-20.3	108.1	-24.2	109.8
			-11.1	69.2	5.1	2.6	-14.8	71.0	-17.8	72.5	-20.6	73.9	-24.3	75.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	14.3	24.6	39.2	55.4	67.2	77.5	82.4	78.4	66.6	50.3	32.6	17.7	(6)
(7)		DBStd	24.64	7.31	8.37	9.41	8.75	7.31	5.60	5.25	5.46	6.95	7.98	8.40	7.86	(7)
(8)		HDD50	3841	1108	711	351	47	1	0	0	0	1	97	523	1002	(8)
(9)		HDD65	6835	1573	1131	801	302	64	2	0	1	65	457	972	1467	(9)
(10)		CDD50	4072	0	0	15	210	534	826	1003	881	497	106	0	0	(10)
(11)		CDD65	1589	0	0	0	14	131	377	538	417	111	1	0	0	(11)
(12)		CDH74	19560	0	0	0	227	1619	4643	7064	4845	1125	37	0	0	(12)
(13)		CDH80	9828	0	0	0	46	603	2364	3990	2455	367	3	0	0	(13)
(14)	Wind	WSAvg	6.4	5.3	5.9	7.2	8.0	7.6	6.9	6.6	6.2	5.9	5.7	6.0	5.5	(14)
(15)	Precipitation	PrecAvg	1.2	0.0	0.0	0.0	0.0	0.1	0.2	0.4	0.3	0.1	0.1	0.0	0.0	(15)
(16)		PrecMax	3.1	0.1	0.2	0.2	0.4	1.5	0.5	1.9	0.8	0.9	0.7	0.3	0.1	(16)
(17)		PrecMin	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	0.7	0.0	0.0	0.0	0.1	0.3	0.1	0.4	0.3	0.2	0.2	0.0	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.9	51.3	70.3	85.1	94.2	100.7	104.4	100.7	92.6	78.3	60.2	41.0	(19)
MCWB			28.6	36.0	45.9	53.4	57.1	61.8	65.4	64.0	60.4	52.0	42.1	30.3	(20)	
2%		DB	33.6	46.5	65.1	79.9	90.0	97.1	100.9	97.0	87.5	73.3	54.9	36.3	(21)	
		MCWB	25.4	33.0	42.9	50.5	56.1	60.5	63.9	62.8	57.6	49.7	39.3	27.3	(22)	
5%		DB	29.8	43.0	60.3	75.9	86.6	94.4	98.1	94.1	84.2	69.1	50.9	33.1	(23)	
		MCWB	22.8	31.2	40.6	49.0	54.5	59.7	63.3	61.8	56.3	47.5	37.1	25.3	(24)	
10%		DB	26.6	39.3	55.9	72.0	82.9	91.6	95.4	91.4	80.8	65.1	46.5	30.0	(25)	
		MCWB	20.3	28.6	38.5	47.1	52.9	58.9	62.4	61.1	55.3	45.7	34.7	23.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.0	36.5	46.5	54.5	59.1	65.0	70.1	69.2	64.4	53.5	42.8	30.6	(27)
MCD B			38.4	49.5	66.4	81.3	88.6	85.5	95.0	88.3	77.6	73.5	59.0	40.6	(28)	
2%		WB	25.6	33.5	43.7	51.7	56.9	63.3	67.4	66.5	60.8	50.7	39.6	27.6	(29)	
		MCD B	33.3	45.4	63.1	76.4	86.1	86.4	89.6	84.5	82.0	70.5	53.8	35.8	(30)	
5%		WB	22.9	31.3	41.2	49.5	55.4	62.0	65.8	64.8	58.3	48.4	37.4	25.4	(31)	
		MCD B	29.6	42.7	58.9	73.9	83.9	87.0	88.0	84.3	78.4	67.0	50.5	32.8	(32)	
10%		WB	20.4	28.8	38.8	47.6	53.7	60.6	64.5	63.2	56.4	46.3	34.8	23.3	(33)	
		MCD B	26.4	39.1	55.4	70.6	80.6	86.0	87.8	85.0	77.5	63.6	46.3	29.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.3	23.8	24.6	24.1	23.9	23.2	22.2	22.5	23.7	24.5	21.7	19.9	(35)
MCDBR			23.1	26.8	28.9	28.7	28.5	27.1	25.1	25.6	27.0	28.5	25.7	21.2	(36)	
MCWBR			17.0	17.2	15.6	13.9	12.2	9.7	8.1	8.8	10.4	13.9	15.4	14.9	(37)	
5% WB		MCD BR	23.0	26.3	27.3	27.1	25.6	22.8	21.2	21.7	23.5	27.3	25.4	20.9	(38)	
		MCWBR	16.9	16.9	15.0	13.2	11.2	8.2	7.5	7.8	9.9	13.4	15.4	14.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.359	0.401	0.446	0.458	0.475	0.471	0.449	0.417	0.367	0.331	0.311	(40)	
taud		2.165	2.054	1.958	1.888	1.920	1.949	2.008	2.048	2.071	2.136	2.165	2.154	(41)		
Ebn at Noon		258	260	263	260	261	256	256	257	256	254	246	244	(42)		
Edh at Noon		31	42	52	60	60	58	54	50	46	38	31	29	(43)		
(44)	All-Sky Solar Radiation	RadAvg	789	1130	1577	1980	2270	2275	2155	1972	1681	1298	885	699	(44)	
(45)		RadStd	55	56	93	82	101	135	103	95	76	34	42	50	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+162	+101
(47) Regional (2 neighbors)		+0.61	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+162	+101

Nomenclature: See separate page