

JIUQUAN SUZHOU, China

WMO: 525330

Lat: 39.767N

Lon: 98.483E

Elev: 1478

StdP: 84.78

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.9	-17.4	-25.9	0.4	-13.7	-24.1	0.5	-11.4	6.8	-3.0	5.4	-3.8	1.7	250	0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	32.0	17.1	30.6	16.3	29.3	15.7	19.1	28.1	18.1	27.2	17.3	26.0	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	13.9	21.8	15.4	13.1	21.3	14.4	12.3	21.2	61.1	28.0	57.7	27.3	54.9	26.1	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.2	5.1	DB	-22.9	35.0	3.0	1.5	-25.0	36.1	-26.7	36.9	-28.4	37.8	-30.5	38.9	(4)
			WB	-23.3	22.0	2.8	1.2	-25.3	22.8	-26.9	23.5	-28.5	24.2	-30.6	25.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-8.5	-3.6	3.4	11.1	16.5	21.0	22.7	21.3	16.0	8.9	1.1	-6.5
	DBStd	11.44	4.23	4.50	4.85	4.59	3.60	2.65	2.49	2.61	3.36	3.85	4.32	4.25
	HDD10.0	2050	572	381	207	41	2	0	0	0	1	67	268	512
	HDD18.3	3882	831	614	462	218	77	8	1	6	84	294	517	770
	CDD10.0	1568	0	0	3	75	203	329	395	350	181	31	0	0
	CDD18.3	358	0	0	0	2	20	88	138	97	14	0	0	0
	CDH23.3	3598	0	0	0	35	264	848	1341	941	167	3	0	0
	CDH26.7	1123	0	0	0	4	47	239	507	301	25	0	0	0
Wind	WSAvg	2.3	2.0	2.2	2.6	3.0	2.6	2.3	2.2	2.1	2.0	2.0	2.1	1.9
Precipitation	PrecAvg	87	2	2	4	4	8	14	20	17	11	3	2	2
	PrecMax	166	13	7	22	21	64	67	93	68	47	18	12	13
	PrecMin	40	0	0	0	0	0	0	1	0	0	0	0	0
	PrecStd	32	2	2	5	5	12	12	18	15	13	4	3	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	11.1	19.6	26.9	29.8	32.3	34.5	33.2	29.4	23.4	15.3	7.1
		MCWB	-0.8	1.9	6.4	10.3	12.9	16.0	18.6	17.6	14.1	9.9	5.1	0.1
	2%	DB	3.2	8.2	16.7	23.8	27.9	30.6	32.6	31.3	26.9	20.9	13.1	4.3
		MCWB	-2.6	0.3	5.1	9.0	12.3	15.3	17.6	16.5	13.0	8.9	4.1	-1.5
	5%	DB	0.7	6.2	14.3	21.8	26.3	29.3	31.1	29.8	25.2	18.7	11.0	2.2
		MCWB	-4.0	-0.7	4.0	8.1	11.5	14.9	17.3	16.0	12.7	8.1	3.0	-2.8
	10%	DB	-1.4	4.2	12.0	19.8	24.5	28.0	29.7	28.3	23.5	16.6	8.7	0.3
		MCWB	-5.3	-1.7	3.0	7.3	10.8	14.5	16.9	15.8	12.2	7.0	1.9	-3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.6	2.2	7.1	11.1	14.6	18.8	21.1	20.1	16.7	11.6	6.0	0.4
		MCDB	5.7	10.0	18.2	25.0	26.9	26.8	31.1	29.5	21.8	18.5	13.6	6.6
	2%	WB	-2.4	0.6	5.5	9.7	13.3	17.3	19.5	18.7	15.1	9.8	4.4	-1.3
		MCDB	2.9	7.6	15.4	21.7	25.7	26.5	29.0	27.1	23.0	19.1	12.3	4.0
	5%	WB	-3.8	-0.5	4.4	8.7	12.2	16.5	18.5	17.7	14.0	8.7	3.2	-2.6
		MCDB	0.6	5.8	13.3	20.2	24.1	25.9	28.0	26.1	21.2	17.5	10.5	1.9
	10%	WB	-5.2	-1.6	3.3	7.7	11.4	15.7	17.8	16.9	13.1	7.5	2.0	-3.8
		MCDB	-1.6	4.0	11.6	18.4	22.5	25.0	27.0	25.0	21.0	15.8	8.6	0.2
Mean Daily Temperature Range	5% DB	MDBR	11.6	12.2	12.5	12.5	12.3	11.9	11.8	12.4	12.6	12.9	11.2	10.9
		MCDBR	14.1	14.5	15.6	14.9	15.0	14.3	14.9	15.2	15.0	15.0	13.9	12.8
		MCWBR	9.7	8.8	8.0	6.5	6.5	6.2	6.3	6.1	5.7	6.8	7.9	8.6
	5% WB	MCDBR	13.7	13.6	14.5	13.6	13.4	12.4	13.0	12.8	12.3	14.1	13.3	12.4
		MCWBR	9.5	8.4	7.6	6.1	6.3	5.9	6.2	5.7	5.3	6.5	7.7	8.4
Clear-Sky Solar Irradiance	taub	0.306	0.356	0.420	0.473	0.479	0.488	0.474	0.461	0.432	0.386	0.338	0.305	
	taud	2.210	2.073	1.912	1.818	1.866	1.915	2.024	2.038	2.051	2.073	2.145	2.218	
	Ebn at Noon	844	841	820	803	808	800	807	806	801	794	789	812	
	Edh at Noon	100	133	175	205	200	191	170	163	151	131	106	92	
All-Sky Solar Radiation	RadAvg	2.65	3.60	4.85	5.96	6.62	6.57	6.33	5.85	5.09	4.19	2.99	2.38	
	RadStd	0.15	0.15	0.34	0.35	0.31	0.49	0.34	0.41	0.34	0.19	0.14	0.16	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+68	N/A
	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+99	+45

Nomenclature: See separate page