

DA-QAIDAM, China

WMO: 527130

Lat: 37.8523N

Lon: 95.3528E

Elev: 3174

StdP: 68.57

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.2	-20.2	-33.4	0.2	-12.5	-31.3	0.3	-12.2	7.5	-6.6	5.9	-5.3	0.6	40	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	26.2	10.9	24.4	10.0	22.8	9.3	13.0	21.6	12.1	20.3	11.1	19.2	2.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	11.4	15.7	8.8	10.4	15.8	7.4	9.5	15.5	47.8	21.5	44.9	20.2	41.9	19.0	16.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	8.1	6.8	5.7	DB	-25.9	29.2	2.6	1.9	-27.8	30.6	-29.3	31.7	-30.7	32.7	-32.6	34.1
(5)				WB	-26.5	14.0	2.4	1.2	-28.2	14.9	-29.6	15.6	-31.0	16.3	-32.8	17.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.5	-10.9	-6.9	-1.9	4.3	9.5	14.0	16.9	16.1	10.8	2.9	-4.1	-9.6
	DBStd	10.21	3.52	3.95	3.82	3.76	3.11	2.74	3.05	2.90	3.13	3.41	3.38	3.02
	HDD10.0	2990	649	473	369	173	46	3	0	1	24	219	424	607
	HDD18.3	5458	908	706	628	421	273	133	66	81	226	477	674	866
	CDD10.0	610	0	0	0	3	31	123	213	190	49	1	0	0
	CDD18.3	36	0	0	0	0	0	2	21	13	1	0	0	0
	CDH23.3	278	0	0	0	0	1	15	161	97	5	0	0	0
	CDH26.7	39	0	0	0	0	0	0	27	12	0	0	0	0
Wind	WSAvg	2.0	1.2	1.7	2.3	2.6	2.7	2.4	2.3	2.1	1.9	1.7	1.4	1.2
Precipitation	PrecAvg	86	2	2	3	2	12	21	21	15	7	1	1	1
	PrecMax	167	6	9	18	20	66	59	77	66	34	9	5	6
	PrecMin	34	0	0	0	0	0	0	3	0	0	0	0	0
	PrecStd	33	2	2	4	4	16	13	18	15	8	2	1	1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.0	7.8	14.0	18.8	22.1	25.2	29.7	28.2	23.8	17.0	9.2	3.2
		MCWB	-4.4	-1.7	1.5	4.4	6.3	10.2	13.5	12.3	10.2	4.1	-0.6	-3.8
	2%	DB	0.1	5.2	10.4	16.4	19.8	23.1	26.9	25.9	21.2	14.2	6.9	0.7
		MCWB	-6.1	-3.2	-0.4	3.2	5.5	8.6	11.5	10.7	8.4	2.6	-1.7	-5.6
	5%	DB	-2.0	2.8	8.1	14.4	18.2	21.6	25.0	24.0	19.1	12.2	5.1	-1.3
		MCWB	-7.4	-4.5	-1.4	2.3	4.8	7.7	10.3	10.1	7.0	1.6	-2.8	-6.8
	10%	DB	-3.9	0.7	5.9	12.4	16.6	20.2	23.2	22.4	17.4	10.4	3.3	-3.0
		MCWB	-8.5	-5.6	-2.4	1.4	4.0	7.1	9.7	9.3	6.0	0.7	-3.8	-7.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.2	-1.6	1.6	5.1	7.5	12.8	14.6	13.9	11.8	5.4	-0.2	-3.5
		MCDB	2.7	7.2	13.2	16.9	17.5	20.8	26.4	24.5	21.0	13.7	8.2	2.8
	2%	WB	-6.1	-3.1	-0.1	3.6	6.5	10.7	13.2	12.8	10.0	3.3	-1.5	-5.4
		MCDB	-0.3	4.7	9.2	14.9	16.4	18.6	22.3	21.4	17.6	12.8	6.3	0.3
	5%	WB	-7.3	-4.3	-1.1	2.7	5.6	9.5	12.2	12.0	8.6	2.0	-2.7	-6.7
		MCDB	-2.5	2.5	7.6	13.4	15.3	17.4	20.8	19.8	16.7	11.5	4.7	-1.6
	10%	WB	-8.5	-5.5	-2.3	1.7	4.9	8.6	11.3	11.1	7.3	0.9	-3.7	-7.8
		MCDB	-4.0	0.4	5.6	11.7	14.4	16.6	19.8	18.8	15.3	10.0	3.0	-3.2
Mean Daily Temperature Range	5% DB	MDBR	14.3	13.9	13.6	13.1	11.7	10.4	10.1	10.9	12.0	13.7	14.0	14.1
		MCDBR	16.1	16.3	16.7	15.6	14.0	12.4	12.2	12.8	13.5	15.2	15.8	15.6
		MCWBR	11.3	10.3	9.3	7.7	6.2	4.8	4.5	4.8	5.7	7.6	9.3	10.7
	5% WB	MCDBR	15.5	15.5	15.5	14.1	11.4	9.3	9.5	9.3	10.8	14.0	15.1	15.0
		MCWBR	11.0	9.9	8.8	7.0	5.0	3.7	3.6	3.5	4.5	7.1	8.9	10.3
Clear-Sky Solar Irradiance	taub	0.224	0.262	0.314	0.368	0.385	0.387	0.372	0.357	0.324	0.273	0.240	0.217	
	taud	2.433	2.314	2.126	1.979	2.005	2.089	2.219	2.247	2.308	2.368	2.415	2.461	
	Ebn at Noon	990	977	944	907	895	891	901	908	924	951	957	977	
	Edh at Noon	81	106	142	176	175	161	140	133	117	99	82	73	
All-Sky Solar Radiation	RadAvg	3.00	3.95	5.40	6.64	7.22	6.95	6.81	6.47	5.57	4.68	3.39	2.76	
	RadStd	0.17	0.18	0.26	0.28	0.35	0.48	0.38	0.38	0.30	0.20	0.20	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	+0.56	+0.67	N/A	N/A	N/A	N/A	-151	-198	+53	N/A
		+0.38	N/A	N/A	N/A	N/A	N/A	-127	-168	+54	N/A

Nomenclature: See separate page