

DELINGHA, China

WMO: 527370

Lat: 37.3745N

Lon: 97.3757E

Elev: 9783

StdP: 10.19

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.1	(c) 2.3	(d) -26.2	(e) 1.8	(f) 14.9	(g) -22.3	(h) 2.3	(i) 16.0	(j) 14.7	(k) 18.2	(l) 12.1	(m) 16.0	(n) 1.6	(o) 40	(p) 0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 17.4	(c) 80.9	(d) 54.1	(e) 77.7	(f) 52.5	(g) 74.9	(h) 51.1	(i) 57.5	(j) 73.5	(k) 55.8	(l) 70.3	(m) 54.3	(n) 68.6	(o) 4.7	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.6	85.5	62.0	50.5	79.1	61.1	48.6	73.5	60.4	29.6	72.9	28.3	70.3	27.1	68.6	63.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	12.1	10.5	-7.2	86.0	3.6	3.1	-9.7	88.2	-11.8	90.0	-13.8	91.7	-16.4	94.0
			-8.6	59.6	3.2	2.0	-10.9	61.0	-12.8	62.1	-14.6	63.2	-17.0	64.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.0	16.5	24.1	33.8	44.9	53.0	59.0	63.7	63.4	55.0	41.9	29.1	18.5		
	DBStd	17.68	6.36	7.34	6.92	6.81	5.79	5.57	5.96	5.33	5.75	6.18	6.78	5.61		
	HDD50	4370	1039	726	502	182	35	5	0	0	15	261	628	977		
	HDD65	8514	1504	1146	966	604	371	190	97	95	305	716	1078	1442		
	CDD50	1448	0	0	1	28	129	275	425	416	164	10	0	0		
	CDD65	120	0	0	0	0	1	11	57	46	5	0	0	0		
	CDH74	813	0	0	0	1	7	71	412	292	30	0	0	0		
	CDH80	129	0	0	0	0	0	3	81	42	3	0	0	0		
(14) Wind	WSAvg	4.1	3.1	3.8	4.4	4.9	5.2	5.1	4.9	4.5	3.7	3.3	3.2	3.0		
(15) Precipitation	PrecAvg	6.3	0.1	0.1	0.2	0.3	0.9	1.4	1.4	1.0	0.6	0.2	0.0	0.1		
	PrecMax	11.2	0.5	0.4	1.3	1.6	3.0	4.1	4.0	2.8	1.8	1.3	0.3	0.4		
	PrecMin	3.2	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.9	0.2	0.1	0.3	0.4	0.8	0.9	0.8	0.7	0.5	0.3	0.1	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.9	49.2	60.7	69.4	74.8	79.7	86.7	84.2	78.0	65.6	51.3	41.4		
		MCWB	25.5	30.7	37.0	42.3	45.8	52.3	57.3	55.5	52.9	41.8	32.9	26.8		
	2%	DB	34.7	43.9	54.0	65.3	70.8	75.9	82.0	80.4	72.5	60.3	46.9	35.9		
		MCWB	22.8	28.1	33.5	40.3	44.0	50.3	54.7	54.0	50.4	39.5	30.3	23.7		
	5%	DB	31.1	40.0	50.3	61.6	67.9	73.1	78.5	77.3	68.8	57.1	43.9	32.2		
		MCWB	20.7	26.2	31.7	38.4	43.0	48.4	53.1	52.6	47.7	37.7	28.9	21.5		
	10%	DB	27.7	36.2	46.8	58.2	65.0	70.4	75.4	74.2	65.7	53.9	40.6	29.1		
		MCWB	18.6	24.1	30.0	37.0	41.8	47.6	51.7	51.6	45.7	36.4	27.3	19.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.8	30.9	37.4	43.8	48.3	56.6	59.7	59.7	56.2	45.2	33.5	26.9		
		MCDB	38.7	47.7	58.4	65.0	64.6	72.4	80.9	76.7	72.2	56.5	49.5	40.4		
	2%	WB	23.1	28.5	34.3	41.2	46.3	53.9	57.7	57.5	53.0	41.7	30.9	24.0		
		MCDB	33.9	42.8	51.5	62.2	63.9	69.1	75.4	72.3	66.8	56.3	45.7	35.4		
	5%	WB	20.9	26.5	32.3	39.5	44.9	51.7	56.0	55.9	51.0	39.4	29.2	21.7		
		MCDB	30.4	39.6	48.5	59.0	61.9	66.3	70.9	69.9	64.0	53.9	43.0	31.8		
	10%	WB	18.8	24.3	30.5	37.7	43.5	50.0	54.4	54.4	48.9	37.3	27.5	19.8		
		MCDB	27.3	35.6	45.8	56.2	60.2	64.3	68.7	68.4	61.8	52.4	40.2	28.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.4	21.0	22.0	21.5	19.5	17.4	17.4	18.1	19.5	21.7	20.7	20.3		
		MCDBR	23.3	23.9	25.4	24.5	23.4	21.5	21.2	21.1	21.9	23.9	22.5	22.4		
		MCWBR	15.6	14.3	13.4	11.2	9.2	7.6	6.9	7.1	7.9	10.9	12.9	14.9		
		MCDBR	22.4	22.8	23.6	22.2	18.6	16.8	16.9	17.3	18.1	19.8	21.7	21.7		
	5% WB	MCWBR	15.2	13.9	12.4	10.2	7.4	6.6	6.3	6.1	6.8	9.4	12.4	14.6		
(40) Clear-Sky Solar Irradiance	taub		0.222	0.259	0.311	0.365	0.385	0.385	0.373	0.361	0.329	0.276	0.236	0.215		
	taud		2.459	2.346	2.169	2.026	2.051	2.149	2.274	2.291	2.345	2.409	2.456	2.486		
	Ebn at Noon		316	312	301	289	284	283	286	287	292	302	307	313		
	Edh at Noon		25	33	43	53	53	48	42	41	36	30	25	23		
(44) All-Sky Solar Radiation	RadAvg		956	1235	1675	2029	2131	2048	2036	1920	1662	1443	1079	907		
	RadStd		69	70	97	99	131	140	146	126	101	71	70	49		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	-140	N/A	N/A	N/A

Nomenclature: See separate page