

ERENHOT, China

WMO: 530680

Lat: 43.6304N

Lon: 111.9385E

Elev: 3169

StdP: 13.09

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.9	-14.1	-26.3	1.4	-10.4	-22.7	1.8	-7.9	25.1	20.0	22.3	16.3	4.9	270	0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	94.4	62.5	91.2	61.4	88.1	60.5	67.5	81.9	65.6	80.6	64.1	79.3	8.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	99.1	71.7	61.2	90.7	70.8	59.0	83.8	70.6	33.9	81.6	32.3	80.4	31.1	79.2	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.9	22.2	18.9	DB	-22.1	99.2	4.7	3.6	-25.5	101.8	-28.2	103.9	-30.8	105.9	-34.2	108.6	(4)
			WB	-22.4	70.6	4.6	3.3	-25.7	73.0	-28.4	74.9	-31.0	76.8	-34.4	79.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.1	2.6	12.2	28.9	46.3	59.3	70.3	76.2	72.2	60.5	43.5	23.4	7.5	(6)
(7)		DBStd	26.84	9.03	10.81	10.47	9.82	8.63	6.84	5.50	5.92	7.99	9.21	10.95	9.25	(7)
(8)		HDD50	5752	1469	1059	654	182	19	0	0	13	240	797	1319		(8)
(9)		HDD65	9223	1934	1479	1118	562	219	27	1	10	175	667	1247	1784	(9)
(10)		CDD50	2857	0	0	1	72	306	611	812	690	327	38	0	0	(10)
(11)		CDD65	854	0	0	0	3	41	187	347	235	40	1	0	0	(11)
(12)		CDH74	9450	0	0	0	67	661	2113	3826	2330	443	10	0	0	(12)
(13)		CDH80	3822	0	0	0	12	216	836	1755	894	108	1	0	0	(13)
(14)	Wind	WSAvg	8.5	7.3	7.7	9.2	10.4	10.7	8.7	7.8	7.4	8.0	8.3	8.3	7.7	(14)
(15)	Precipitation	PrecAvg	5.3	0.0	0.0	0.1	0.2	0.4	0.8	1.3	1.3	0.6	0.2	0.1	0.0	(15)
(16)		PrecMax	10.1	0.4	0.2	0.7	0.8	1.4	3.1	3.1	4.6	2.4	1.5	0.4	0.2	(16)
(17)		PrecMin	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.9	0.1	0.0	0.1	0.2	0.4	0.6	0.8	1.0	0.6	0.3	0.1	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.5	46.8	64.4	81.5	90.9	96.5	100.3	95.7	87.7	74.9	55.6	36.5	(19)
(20)			MCWB	24.9	34.0	42.6	51.5	56.4	60.8	66.2	64.0	57.8	51.8	39.3	28.3	(20)
(21)		2%	DB	26.3	39.9	57.2	74.6	86.0	92.2	96.0	91.7	83.0	68.8	49.6	29.6	(21)
(22)			MCWB	20.6	29.3	38.8	48.2	54.6	59.9	63.8	62.7	56.8	48.9	36.9	23.4	(22)
(23)		5%	DB	21.6	34.8	52.0	69.4	81.2	88.4	92.3	88.3	79.0	63.9	44.5	25.3	(23)
(24)			MCWB	17.2	26.6	36.3	46.2	52.5	58.8	62.8	61.6	55.0	46.2	33.6	20.2	(24)
(25)		10%	DB	17.2	30.1	46.8	64.6	76.9	84.8	89.0	85.1	75.3	59.1	39.8	21.5	(25)
(26)			MCWB	13.7	23.5	33.4	44.0	50.8	58.0	62.1	60.5	53.9	43.3	31.1	17.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.3	34.8	43.3	53.0	58.9	65.4	71.1	70.0	63.4	54.6	41.1	28.4	(27)
(28)			MCD B	32.5	44.9	62.3	73.6	79.5	77.9	86.0	83.3	72.1	69.5	54.5	36.4	(28)
(29)		2%	WB	20.7	30.2	39.5	49.9	56.6	63.0	68.2	67.0	59.8	50.2	36.9	23.5	(29)
(30)			MCD B	26.0	39.4	55.7	70.6	78.9	79.5	83.0	80.5	74.8	65.8	48.7	29.2	(30)
(31)		5%	WB	17.3	26.9	36.7	47.1	54.4	61.6	66.4	65.2	57.8	47.3	34.1	20.4	(31)
(32)			MCD B	21.4	34.9	51.0	68.0	76.2	79.7	82.2	79.2	73.8	61.0	43.8	25.1	(32)
(33)		10%	WB	13.8	23.5	33.7	44.5	52.4	60.3	64.9	63.6	55.7	44.5	31.3	17.5	(33)
(34)			MCD B	17.3	30.1	46.5	63.3	73.7	78.8	80.9	78.3	71.4	57.4	39.6	21.4	(34)
(35)	Mean Daily Temperature Range	MDBR	20.3	24.2	24.9	24.7	24.4	22.0	20.6	20.8	22.3	22.1	20.5	18.7	(35)	
(36)		5% DB	MCD BR	24.5	28.6	31.2	30.9	31.0	26.6	24.8	24.7	26.4	27.7	24.9	21.7	(36)
(37)			MCWBR	20.0	20.5	18.6	15.6	13.6	9.0	7.5	8.1	10.5	14.2	15.6	17.0	(37)
(38)		5% WB	MCD BR	24.4	28.0	30.3	28.8	26.2	21.1	19.4	19.2	21.5	25.3	24.0	21.5	(38)
(39)			MCWBR	20.0	20.2	18.6	14.9	12.2	7.5	7.0	7.5	10.0	13.9	15.5	17.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.271	0.303	0.343	0.395	0.440	0.468	0.438	0.423	0.384	0.336	0.290	0.272	(40)	
(41)		taud	2.278	2.192	2.119	2.023	1.952	1.973	2.122	2.129	2.167	2.234	2.273	2.249	(41)	
(42)		Ebn at Noon	272	280	281	274	265	257	264	263	265	263	260	258	(42)	
(43)		Edh at Noon	27	35	43	52	57	56	48	46	41	33	27	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	688	1052	1575	1980	2182	2109	2088	1935	1613	1200	816	588	(44)	
(45)		RadStd	83	79	101	94	110	123	84	74	62	60	61	77	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	(47)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	-2.75	N/A	N/A	-1.28	N/A	N/A	N/A	N/A
Regional (5 neighbors)		N/A	N/A	-1.78	N/A	-0.95	-1.31	N/A	N/A	N/A	N/A

Nomenclature: See separate page