

ABAG QI, China

WMO: 531920

Lat: 44.0168N

Lon: 115.0033E

Elev: 1148

StdP: 88.28

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.8	-28.8	-34.2	0.2	-29.9	-32.4	0.2	-27.8	11.6	-13.7	10.1	-15.0	1.2	290	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	32.2	16.4	30.3	15.8	28.6	15.3	19.3	25.8	18.3	25.2	17.4	24.5	4.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.4	14.3	21.9	16.2	13.2	21.2	15.1	12.3	20.4	60.4	25.9	56.9	25.1	53.8	24.4	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.0	8.5	-32.8	35.0	2.7	1.8	-34.8	36.3	-36.4	37.4	-37.9	38.4	-39.9	39.8		
(5)			-32.9	20.5	2.7	1.0	-34.9	21.3	-36.5	21.9	-38.0	22.4	-39.9	23.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.9	-19.7	-14.4	-4.5	5.4	12.7	18.7	22.0	19.9	13.5	4.0	-7.3	-16.8	(6)
(7)		DBStd	15.22	5.25	6.14	6.14	5.37	4.79	3.76	3.08	3.25	4.48	5.12	6.18	5.10	(7)
(8)		HDD10.0	3804	921	684	451	156	27	0	0	0	18	195	519	832	(8)
(9)		HDD18.3	5898	1179	918	709	388	183	39	4	20	153	444	769	1090	(9)
(10)		CDD10.0	1201	0	0	1	18	110	263	371	306	123	9	0	0	(10)
(11)		CDD18.3	253	0	0	0	0	8	52	117	68	8	0	0	0	(11)
(12)		CDH23.3	2606	0	0	0	11	162	566	1128	634	103	1	0	0	(12)
(13)		CDH26.7	851	0	0	0	1	41	178	420	192	18	0	0	0	(13)
(14)	Wind	WSAvg	3.3	2.4	2.6	3.7	4.4	4.6	3.6	3.2	3.0	3.2	3.3	3.0	2.5	(14)
(15)	Precipitation	PrecAvg	242	1	2	3	8	19	41	68	59	25	11	3	2	(15)
(16)		PrecMax	306	4	7	12	31	68	77	152	142	69	38	13	11	(16)
(17)		PrecMin	127	0	0	0	0	3	7	23	10	1	0	0	0	(17)
(18)		PrecStd	49	1	2	3	8	16	18	31	37	16	8	3	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.3	5.3	15.7	24.9	30.9	33.1	35.1	33.7	29.0	21.2	10.8	0.3	(19)
(20)			MCWB	-5.6	-0.1	4.7	9.6	12.7	15.4	17.6	17.2	13.9	9.8	3.1	-3.2	(20)
(21)		2%	DB	-6.2	1.2	11.4	20.8	27.2	30.6	32.9	30.8	26.2	18.2	7.1	-4.3	(21)
(22)			MCWB	-8.4	-2.9	2.6	7.6	11.4	14.7	17.3	16.4	12.8	8.5	1.3	-6.6	(22)
(23)		5%	DB	-9.0	-1.5	8.2	18.0	24.9	28.7	30.9	28.7	24.0	15.3	4.5	-7.0	(23)
(24)			MCWB	-10.6	-4.7	0.8	6.4	10.5	14.2	16.8	15.7	12.0	6.6	-0.4	-8.7	(24)
(25)		10%	DB	-11.4	-4.5	5.3	15.4	22.4	26.7	29.0	26.8	21.9	12.6	1.8	-9.2	(25)
(26)			MCWB	-12.6	-7.0	-0.6	5.1	9.6	13.7	16.3	15.3	11.4	5.3	-1.9	-10.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.4	-0.1	5.3	10.5	14.1	17.5	21.2	20.3	16.5	11.3	3.9	-3.1	(27)
(28)			MCDWB	-2.5	4.0	13.4	22.8	23.2	25.6	26.8	26.4	23.5	19.2	9.8	0.1	(28)
(29)		2%	WB	-8.3	-2.5	3.0	8.4	12.7	16.6	19.9	19.0	14.6	9.2	1.5	-6.6	(29)
(30)			MCDWB	-6.3	1.0	10.7	18.3	23.6	25.1	26.2	25.3	21.7	16.5	6.5	-4.4	(30)
(31)		5%	WB	-10.5	-4.7	1.2	7.0	11.6	15.9	18.9	18.0	13.5	7.5	-0.2	-8.7	(31)
(32)			MCDWB	-9.0	-1.5	7.7	16.8	21.9	24.3	25.9	23.9	21.1	13.9	4.1	-7.1	(32)
(33)		10%	WB	-12.6	-7.0	-0.6	5.5	10.5	15.1	18.0	17.1	12.5	5.8	-1.8	-10.6	(33)
(34)			MCDWB	-11.4	-4.5	5.0	14.8	20.6	23.2	25.7	23.5	20.0	12.2	1.9	-9.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.6	12.3	12.5	13.0	13.2	11.8	11.1	11.5	12.4	12.0	11.0	9.9	(35)
(36)			MCDBR	12.9	14.6	15.7	16.7	16.9	14.7	13.8	13.9	14.6	15.5	13.6	12.1	(36)
(37)			MCWBR	11.1	11.1	9.5	8.2	6.9	4.8	4.1	4.6	5.9	8.1	9.0	10.2	(37)
(38)		5% WB	MCDBR	12.7	14.3	15.2	15.3	14.0	11.4	10.6	10.4	12.0	13.7	13.2	11.9	(38)
(39)			MCWBR	11.0	11.1	9.4	8.0	6.3	4.1	4.1	4.4	5.8	8.0	8.9	10.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.262	0.296	0.338	0.391	0.452	0.473	0.436	0.423	0.373	0.335	0.287	0.268	(40)	
(41)		taud	2.296	2.209	2.140	2.046	1.923	1.972	2.150	2.147	2.223	2.251	2.284	2.263	(41)	
(42)		Ebn at Noon	868	889	891	868	822	805	832	829	845	830	822	816	(42)	
(43)		Edh at Noon	81	108	133	159	186	178	147	143	121	102	82	76	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.12	3.27	4.79	5.96	6.63	6.45	6.35	5.90	4.90	3.57	2.38	1.76	(44)	
(45)		RadStd	0.24	0.26	0.32	0.35	0.40	0.41	0.22	0.19	0.26	0.22	0.19	0.17	(45)	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(47) Regional (2 neighbors)		N/A	N/A	-1.67	N/A	-0.35	-0.64	N/A	N/A

Nomenclature: See separate page