

HAI LI SU, China

WMO: 532310

Lat: 41.4007N

Lon: 106.4070E

Elev: 4954

StdP: 12.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-8.2	-26.8	1.5	0.0	-22.6	1.9	2.2	28.7	17.8	25.4	16.0	8.8	160	0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	89.2	59.0	86.7	57.9	84.2	57.1	64.4	79.0	62.5	77.0	60.9	74.9	12.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.2	93.8	68.6	57.9	86.2	67.6	55.6	79.2	67.3	32.4	78.6	30.8	76.7	29.5	74.8	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.4	25.6	22.6	-18.7	94.2	5.1	3.2	-22.4	96.4	-25.4	98.3	-28.3	100.1	-32.0	102.3
			-19.1	66.9	5.1	2.6	-22.7	68.8	-25.7	70.3	-28.6	71.7	-32.3	73.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.2	9.2	17.9	31.4	46.4	58.0	68.2	73.4	69.8	59.2	44.2	26.9	12.8
	DBStd	23.69	8.65	9.91	10.36	9.63	8.25	6.48	5.33	5.90	7.63	9.21	9.78	9.05
	HDD50	5031	1266	899	579	177	25	0	0	16	224	693	1152	
	HDD65	8567	1731	1319	1041	559	243	41	4	22	201	646	1143	1617
	CDD50	2567	0	0	3	70	273	547	725	615	291	43	0	0
	CDD65	628	0	0	0	2	26	138	264	172	26	0	0	0
	CDH74	5798	0	0	0	20	297	1345	2548	1409	176	3	0	0
	CDH80	1768	0	0	0	1	49	379	915	397	27	0	0	0
	WSAvg	11.9	11.4	11.7	12.6	13.4	13.4	12.0	11.2	10.9	11.2	11.5	12.2	11.8
	PrecAvg	4.3	0.0	0.0	0.1	0.2	0.3	0.5	1.3	1.1	0.5	0.2	0.1	0.0
Precipitation	PrecMax	9.4	0.2	0.1	0.2	0.8	1.1	2.6	4.5	3.8	1.5	0.9	0.6	0.2
	PrecMin	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0
	PrecStd	1.7	0.0	0.0	0.1	0.2	0.3	0.5	1.0	0.8	0.4	0.2	0.1	0.0
	PrecStd	1.7	0.0	0.0	0.1	0.2	0.3	0.5	1.0	0.8	0.4	0.2	0.1	0.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.0	47.0	62.7	76.9	84.6	90.4	95.0	90.9	84.1	71.9	54.5	39.8
		MCWB	27.3	32.9	41.4	48.2	52.7	56.7	62.8	60.3	54.9	48.4	37.6	29.0
	2%	DB	30.9	41.3	56.6	71.7	80.8	87.0	90.4	87.4	78.3	66.5	49.2	33.9
		MCWB	23.4	29.6	37.7	45.6	51.1	55.6	60.0	58.8	52.7	45.9	35.3	25.6
	5%	DB	26.0	37.2	51.8	67.1	77.4	84.4	87.7	84.4	75.4	62.6	45.2	29.8
		MCWB	20.2	27.5	35.3	43.8	49.7	55.1	59.2	58.0	52.2	43.9	33.2	22.8
	10%	DB	21.9	33.0	47.4	63.0	73.6	81.8	85.2	81.6	72.1	58.6	41.2	25.7
		MCWB	17.2	25.0	33.1	42.1	47.9	54.1	58.5	57.3	51.2	42.0	31.0	20.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	34.1	42.0	50.2	55.6	62.6	67.7	67.3	60.5	50.8	39.3	29.4
		MCDB	36.8	44.9	61.1	70.4	75.0	74.1	86.0	76.7	70.5	65.9	51.9	38.9
	2%	WB	23.6	30.4	38.5	47.5	53.0	59.8	65.1	64.4	57.7	47.5	36.0	25.7
		MCDB	30.3	40.3	53.8	66.9	73.9	74.0	81.5	78.0	69.6	63.8	48.1	33.5
	5%	WB	20.2	27.7	36.1	45.2	51.2	58.2	63.0	62.5	55.5	45.0	33.4	23.0
		MCDB	25.7	36.4	50.4	64.6	72.3	74.7	78.2	76.8	68.1	59.6	44.4	29.2
	10%	WB	17.3	25.2	33.8	42.8	49.4	56.8	61.5	60.7	53.3	42.9	31.2	20.3
		MCDB	21.8	33.1	46.4	61.8	70.3	74.6	76.2	74.4	67.6	57.0	40.9	25.6
Mean Daily Temperature Range	5% DB	MDBR	18.8	20.1	20.0	20.6	20.9	19.7	18.6	18.3	18.4	18.7	17.8	17.2
		MCDBR	21.7	22.7	23.8	24.2	24.0	22.0	20.9	20.3	20.4	21.2	21.2	20.3
		MCWBR	16.5	14.9	13.3	12.0	10.7	7.8	6.4	6.4	7.6	10.7	12.7	14.5
	5% WB	MCDBR	21.1	21.2	21.6	22.0	20.5	18.0	17.6	16.8	16.7	19.6	20.1	19.6
		MCWBR	16.3	14.2	12.5	11.3	10.3	7.1	6.5	6.7	8.0	10.5	12.4	14.3
Clear-Sky Solar Irradiance	taub		0.283	0.326	0.374	0.425	0.453	0.466	0.449	0.434	0.396	0.353	0.308	0.284
	taud		2.221	2.115	1.991	1.900	1.889	1.927	2.041	2.062	2.103	2.142	2.191	2.197
	Ebn at Noon		272	275	273	267	262	259	262	262	263	261	258	260
	Edh at Noon		30	39	50	59	62	60	53	50	44	38	31	28
All-Sky Solar Radiation	RadAvg		790	1146	1583	1976	2235	2205	2076	1923	1620	1300	890	702
	RadStd		75	65	102	94	96	128	98	81	87	50	58	62

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page