

HALIUT, China

WMO: 533360

Lat: 41.5661N

Lon: 108.5078E

Elev: 4232

StdP: 12.58

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.7	-4.9	-22.1	1.9	-0.1	-18.8	2.3	3.4	23.2	8.3	19.8	12.5	3.7	40	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	88.8	61.7	86.5	61.2	84.1	60.3	68.0	80.0	66.0	78.4	64.4	76.8	8.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	105.1	74.5	61.9	97.0	71.9	60.0	90.6	70.6	35.1	79.5	33.3	78.3	31.9	76.5	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.8	18.6	16.1	DB	-13.3	93.3	4.6	3.1	-16.7	95.5	-19.4	97.3	-22.0	99.0	-25.3	101.2	(4)
			WB	-13.7	70.2	4.3	2.1	-16.7	71.7	-19.2	72.9	-21.6	74.0	-24.7	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	10.1	18.4	32.5	47.8	59.3	69.1	73.7	69.9	59.1	44.5	27.3	13.6	(6)
(7)		DBStd	23.24	7.32	8.93	9.53	9.09	7.51	5.56	4.50	5.12	6.80	7.96	8.50	7.41	(7)
(8)		HDD50	4848	1238	885	544	144	14	0	0	11	204	680	1128		(8)
(9)		HDD65	8333	1703	1305	1006	517	205	25	1	14	198	636	1130	1593	(9)
(10)		CDD50	2623	0	0	3	78	303	572	735	617	282	33	0	0	(10)
(11)		CDD65	635	0	0	0	2	29	147	271	166	20	0	0	0	(11)
(12)		CDH74	5792	0	0	0	40	375	1423	2497	1288	167	2	0	0	(12)
(13)		CDH80	1698	0	0	0	4	72	411	866	321	24	0	0	0	(13)
(14)	Wind	WSAvg	6.3	5.1	5.8	7.1	8.2	8.3	7.1	6.2	5.7	5.8	5.5	5.1	(14)	
(15)	Precipitation	PrecAvg	7.9	0.1	0.0	0.1	0.3	0.4	0.9	2.4	2.2	0.9	0.4	0.1	0.0	(15)
(16)		PrecMax	17.0	0.2	0.2	0.6	1.5	2.2	4.4	8.2	6.2	2.5	1.3	0.7	0.2	(16)
(17)		PrecMin	3.4	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.4	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.0	0.1	0.1	0.2	0.4	0.6	0.9	1.9	1.3	0.7	0.4	0.2	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.9	45.7	64.5	79.3	86.1	90.7	93.1	89.4	83.2	71.1	52.9	35.7	(19)
MCWB			26.4	32.6	43.2	51.1	55.0	59.4	66.1	63.0	58.2	51.0	40.1	27.6	(20)	
2%		DB	29.7	40.8	57.5	73.2	81.8	87.4	89.8	86.3	78.2	66.2	48.4	31.5	(21)	
		MCWB	22.8	30.1	40.0	48.8	53.8	58.6	62.9	63.1	57.0	48.3	36.4	24.7	(22)	
5%		DB	25.9	36.9	52.9	68.4	78.3	84.8	87.5	83.7	75.1	62.3	44.8	28.6	(23)	
		MCWB	20.1	28.0	37.0	46.2	52.2	57.8	62.8	62.0	55.0	46.6	34.3	23.0	(24)	
10%		DB	22.7	33.2	48.4	64.1	74.6	81.9	85.1	81.0	71.9	58.5	41.0	25.7	(25)	
		MCWB	17.8	25.9	34.7	44.3	50.4	57.1	61.9	61.1	54.1	44.6	32.6	20.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	35.0	44.6	54.2	58.7	65.1	71.4	70.8	64.1	54.2	41.6	28.6	(27)
MCDWB			34.0	41.5	61.0	70.5	74.6	77.5	86.9	82.1	72.1	64.7	50.7	33.9	(28)	
2%		WB	23.0	31.5	40.6	50.7	56.2	62.9	68.6	68.2	60.8	50.9	37.9	25.4	(29)	
		MCDWB	29.2	38.8	55.6	66.8	74.3	76.4	82.8	78.4	71.4	62.3	46.1	30.7	(30)	
5%		WB	20.3	28.6	37.9	48.0	54.4	61.4	66.5	66.0	58.5	48.3	35.1	23.2	(31)	
		MCDWB	25.7	36.6	51.2	65.8	72.2	76.0	79.9	77.3	69.5	59.0	44.0	28.4	(32)	
10%		WB	17.8	25.7	35.3	45.3	52.5	60.0	65.0	64.1	56.6	46.0	32.6	20.8	(33)	
		MCDWB	22.5	33.2	47.4	62.9	70.5	75.5	78.0	76.1	68.2	56.1	40.5	25.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.7	20.8	21.9	22.1	22.0	20.3	18.9	18.5	19.8	20.8	18.6	17.5	(35)
MCDBR			21.8	24.0	27.1	27.6	26.6	24.6	22.4	21.4	23.5	24.7	22.3	19.4	(36)	
MCWBR			16.5	16.4	15.8	13.9	11.7	8.5	7.6	7.9	9.8	12.4	13.7	14.5	(37)	
5% WB		MCDBR	21.3	22.7	25.0	23.8	22.0	19.6	17.8	16.7	18.7	21.3	21.0	19.1	(38)	
		MCWBR	16.3	15.8	15.0	12.9	10.7	7.8	7.5	8.4	9.3	12.1	13.5	14.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.290	0.331	0.377	0.430	0.464	0.492	0.465	0.458	0.423	0.368	0.316	0.291	(40)	
(41)		taud	2.230	2.129	2.013	1.923	1.897	1.900	2.043	2.040	2.058	2.135	2.204	2.209	(41)	
(42)		Ebn at Noon	269	273	272	266	259	252	257	255	254	255	255	257	(42)	
(43)		Edh at Noon	30	39	49	58	61	61	52	51	47	38	30	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	759	1104	1568	1954	2213	2141	2048	1890	1567	1261	857	676	(44)	
(45)		RadStd	77	76	100	99	113	133	112	69	75	52	75	77	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	-2.21	N/A	N/A	N/A	N/A	N/A	+149	N/A	
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.81	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page