

HOHHOT, China

WMO: 534630

Lat: 40.8559N

Lon: 111.5714E

Elev: 3784

StdP: 12.79

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.7	-4.5	-22.0	1.9	-2.4	-18.1	2.4	2.8	22.2	13.4	19.4	12.9	4.4	70	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	89.7	63.3	87.2	62.8	84.5	62.2	70.1	81.3	68.6	78.8	67.0	77.3	7.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.2	115.4	74.6	65.2	107.4	73.9	63.1	99.5	73.0	36.7	81.4	35.3	78.6	33.9	76.9	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	20.5	17.4	14.8	DB	-16.2	94.1	8.8	2.6	-22.5	96.0	-27.6	97.5	-32.5	98.9	-38.9	100.8
(5)				WB	-16.6	72.9	8.6	1.8	-22.8	74.2	-27.8	75.2	-32.7	76.2	-38.9	77.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	10.9	20.3	34.0	49.2	60.6	69.6	73.3	69.8	59.9	46.3	29.3	14.8
	DBStd	22.73	7.87	9.38	8.76	8.52	7.04	5.16	4.31	4.51	6.22	7.34	8.35	8.15
	HDD50	4541	1211	831	500	116	7	0	0	0	5	159	622	1090
	HDD65	7949	1676	1251	962	478	170	18	1	12	173	581	1072	1555
	CDD50	2700	0	0	4	91	337	587	722	613	302	44	0	0
	CDD65	630	0	0	0	2	35	155	258	160	20	0	0	0
	CDH74	6281	0	0	0	77	580	1640	2424	1333	224	3	0	0
	CDH80	1940	0	0	0	13	148	541	875	328	35	0	0	0
Wind	WSAvg	5.7	5.0	5.6	6.7	7.4	7.3	6.1	5.0	4.8	5.0	5.3	5.1	5.0
Precipitation	PrecAvg	15.7	0.1	0.2	0.4	0.7	1.0	1.7	3.8	4.9	1.9	0.9	0.2	0.0
	PrecMax	27.0	0.6	0.8	1.6	3.3	2.9	3.7	7.6	14.2	3.8	3.4	1.8	0.4
	PrecMin	6.1	0.0	0.0	0.0	0.0	0.0	0.4	0.5	1.2	0.3	0.0	0.0	0.0
	PrecStd	4.7	0.2	0.2	0.4	0.7	0.8	1.0	1.8	3.1	1.0	0.6	0.4	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.1	49.8	66.6	81.6	88.2	92.0	94.3	89.3	84.3	72.5	55.6	39.3
		MCWB	29.3	36.2	45.4	53.8	57.0	60.8	66.8	65.0	61.4	54.4	42.5	29.5
	2%	DB	32.5	44.1	60.3	75.3	84.2	89.0	90.5	86.2	79.5	67.9	50.4	34.2
		MCWB	25.1	32.8	41.7	50.7	55.5	60.3	65.5	65.3	59.2	51.2	38.9	27.1
	5%	DB	28.5	39.7	55.1	70.9	80.5	86.0	87.8	83.9	76.2	64.1	46.7	31.5
		MCWB	22.7	30.4	39.0	48.3	54.1	59.7	64.8	64.2	57.8	49.4	36.9	25.9
	10%	DB	25.0	35.8	50.1	66.4	76.8	82.8	84.9	81.0	73.0	60.2	42.9	28.4
		MCWB	20.0	28.2	36.3	46.3	52.5	59.0	64.6	63.8	57.0	46.9	34.9	23.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.4	38.0	46.9	56.2	60.5	67.3	73.0	72.6	66.1	57.0	44.7	31.3
		MCDB	36.7	46.0	63.2	74.9	77.0	78.1	84.2	82.5	76.7	69.0	50.4	35.4
	2%	WB	25.6	34.0	42.7	53.0	58.3	65.3	70.8	69.9	63.0	53.8	40.9	28.4
		MCDB	31.9	42.0	56.4	68.7	75.7	78.0	83.0	79.1	73.3	63.9	47.7	33.5
	5%	WB	22.8	31.1	40.0	50.3	56.5	63.6	69.3	68.3	60.9	51.3	38.0	25.8
		MCDB	28.4	38.6	52.9	66.5	73.3	77.4	81.3	77.2	71.4	60.0	45.3	31.1
	10%	WB	20.1	28.5	37.2	47.8	54.8	62.1	67.8	66.6	59.0	49.0	35.4	23.2
		MCDB	24.8	36.1	48.5	64.4	72.0	76.0	78.4	76.3	69.2	57.3	42.7	28.4
Mean Daily Temperature Range	5% DB	MDBR	22.7	23.8	24.2	25.9	25.3	22.9	20.4	20.6	22.1	22.5	20.4	20.9
		MCDBR	25.9	26.7	31.4	32.4	31.3	28.4	25.2	24.2	26.2	26.9	23.7	22.8
		MCWBR	19.9	17.9	17.9	15.9	13.5	10.7	9.6	10.0	11.6	14.2	14.9	17.0
	5% WB	MCDBR	25.1	24.3	28.0	27.6	25.3	21.5	19.9	18.6	20.7	22.5	21.0	21.4
		MCWBR	19.6	16.8	16.6	14.4	12.2	9.6	9.6	9.5	10.9	13.1	14.1	16.2
Clear-Sky Solar Irradiance	taub	0.304	0.359	0.394	0.444	0.484	0.540	0.513	0.510	0.469	0.402	0.336	0.312	
	taud	2.244	2.095	2.036	1.966	1.916	1.842	1.972	1.955	1.985	2.101	2.215	2.231	
	Ebn at Noon	266	263	268	263	254	240	245	241	241	245	250	251	
	Edh at Noon	30	41	49	56	60	65	56	56	51	40	31	28	
All-Sky Solar Radiation	RadAvg	813	1126	1566	1921	2134	2017	1948	1797	1516	1228	870	705	
	RadStd	64	73	112	109	129	151	91	103	90	71	90	60	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	-2.07	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page