

HOHHOT, China

WMO: 534630

Lat: 40.8559N

Lon: 111.5714E

Elev: 1154

StdP: 88.21

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.2	-20.3	-30.0	0.3	-19.1	-27.8	0.3	-16.2	9.9	-10.4	8.7	-10.6	2.0	70	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	32.0	17.4	30.6	17.1	29.2	16.8	21.2	27.4	20.3	26.0	19.4	25.2	3.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.6	16.5	23.6	18.4	15.3	23.3	17.3	14.2	22.8	67.6	27.5	64.1	25.9	60.9	25.0	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	7.8	6.6	-26.8	34.5	4.9	1.4	-30.3	35.5	-33.1	36.4	-35.9	37.2	-39.4	38.2		
			-27.0	22.7	4.8	1.0	-30.4	23.4	-33.2	24.0	-35.9	24.6	-39.4	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-11.7	-6.5	1.1	9.5	15.9	20.9	22.9	21.0	15.5	7.9	-1.5	-9.5
	DBStd	12.63	4.37	5.21	4.86	4.74	3.91	2.87	2.40	2.50	3.45	4.08	4.64	4.53
	HDD10.0	2523	673	462	278	64	4	0	0	0	3	88	346	606
	HDD18.3	4416	931	695	534	266	94	10	1	7	96	323	596	864
	CDD10.0	1500	0	0	2	51	187	326	401	341	168	24	0	0
	CDD18.3	350	0	0	0	1	19	86	143	89	11	0	0	0
	CDH23.3	3489	0	0	0	43	322	911	1347	741	124	2	0	0
	CDH26.7	1078	0	0	0	7	82	301	486	182	19	0	0	0
Wind	WSAvg	2.5	2.2	2.5	3.0	3.3	3.2	2.7	2.2	2.1	2.2	2.4	2.3	2.2
Precipitation	PrecAvg	400	3	5	10	17	25	43	96	125	48	22	6	1
	PrecMax	686	15	21	40	85	74	95	193	361	97	86	46	9
	PrecMin	155	0	0	0	1	1	10	12	30	8	1	0	0
	PrecStd	119	4	5	9	17	20	25	45	80	25	16	9	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.9	9.9	19.2	27.5	31.2	33.3	34.6	31.9	29.1	22.5	13.1	4.0
		MCWB	-1.5	2.3	7.4	12.1	13.9	16.0	19.3	18.4	16.3	12.4	5.8	-1.4
	2%	DB	0.3	6.7	15.7	24.1	29.0	31.7	32.5	30.1	26.4	19.9	10.2	1.2
		MCWB	-3.8	0.5	5.4	10.4	13.1	15.7	18.6	18.5	15.1	10.6	3.8	-2.7
	5%	DB	-2.0	4.3	12.8	21.6	26.9	30.0	31.0	28.8	24.6	17.8	8.2	-0.3
		MCWB	-5.2	-0.9	3.9	9.1	12.3	15.4	18.2	17.9	14.3	9.6	2.7	-3.4
	10%	DB	-3.9	2.1	10.0	19.1	24.9	28.2	29.4	27.2	22.8	15.6	6.1	-2.0
		MCWB	-6.7	-2.1	2.4	7.9	11.4	15.0	18.1	17.7	13.9	8.3	1.6	-4.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.5	3.3	8.3	13.4	15.8	19.6	22.8	22.6	19.0	13.9	7.0	-0.4
		MCDB	2.6	7.8	17.3	23.8	25.0	25.6	29.0	28.0	24.8	20.5	10.2	1.9
	2%	WB	-3.5	1.1	5.9	11.6	14.6	18.5	21.5	21.1	17.2	12.1	5.0	-2.0
		MCDB	0.0	5.5	13.5	20.4	24.3	25.6	28.3	26.2	22.9	17.7	8.7	0.8
	5%	WB	-5.1	-0.5	4.4	10.2	13.6	17.6	20.7	20.1	16.1	10.7	3.3	-3.5
		MCDB	-2.0	3.7	11.6	19.2	22.9	25.2	27.4	25.1	21.9	15.6	7.4	-0.5
	10%	WB	-6.6	-2.0	2.9	8.8	12.7	16.7	19.9	19.2	15.0	9.4	1.9	-4.9
		MCDB	-4.0	2.3	9.1	18.0	22.2	24.5	25.8	24.6	20.7	14.1	5.9	-2.0
Mean Daily Temperature Range	5% DB	MDBR	12.6	13.2	13.5	14.4	14.0	12.7	11.4	11.4	12.3	12.5	11.4	11.6
		MCDBR	14.4	14.8	17.5	18.0	17.4	15.8	14.0	13.5	14.6	15.0	13.2	12.7
		MCWBR	11.1	10.0	9.9	8.8	7.5	5.9	5.3	5.5	6.5	7.9	8.3	9.4
	5% WB	MCDBR	13.9	13.5	15.6	15.3	14.1	12.0	11.0	10.3	11.5	12.5	11.7	11.9
		MCWBR	10.9	9.3	9.2	8.0	6.8	5.3	5.4	5.3	6.1	7.3	7.8	9.0
Clear-Sky Solar Irradiance	taub	0.304	0.359	0.394	0.444	0.484	0.540	0.513	0.510	0.469	0.402	0.336	0.312	
	taud	2.244	2.095	2.036	1.966	1.916	1.842	1.972	1.955	1.985	2.101	2.215	2.231	
	Ebn at Noon	838	830	845	828	802	756	773	761	760	771	787	791	
	Edh at Noon	94	128	153	176	190	205	178	176	160	126	97	88	
All-Sky Solar Radiation	RadAvg	2.56	3.55	4.94	6.06	6.73	6.36	6.14	5.67	4.78	3.87	2.74	2.22	
	RadStd	0.20	0.23	0.35	0.34	0.41	0.48	0.29	0.33	0.28	0.22	0.28	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	-1.15	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page