

LINHE, China

WMO: 535130

Lat: 40.7218N

Lon: 107.3706E

Elev: 1042

StdP: 89.42

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.4	-17.2	-28.7	0.3	-12.2	-26.6	0.4	-11.8	7.5	-4.4	6.7	-5.2	1.2	220	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	33.5	18.2	32.2	17.8	30.8	17.2	21.4	28.9	20.4	27.8	19.5	26.9	2.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	15.8	25.4	18.0	14.7	24.2	17.0	13.7	23.5	67.7	28.8	64.0	27.8	60.6	26.9	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.1	5.1	-21.8	36.2	2.8	1.4	-23.8	37.2	-25.4	38.0	-27.0	38.8	-29.0	39.9		
			-22.2	22.8	2.7	1.2	-24.1	23.7	-25.7	24.4	-27.2	25.1	-29.1	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-9.0	-4.3	3.3	11.6	17.7	22.8	24.8	22.7	17.3	9.7	0.8	-6.7	(6)
(7)		DBStd	12.32	4.11	4.86	4.97	4.74	3.92	2.99	2.49	2.84	3.58	4.21	4.38	4.22	(7)
(8)		HDD10.0	2093	589	401	212	38	2	0	0	0	1	57	277	517	(8)
(9)		HDD18.3	3849	847	634	466	207	59	3	0	3	59	269	527	775	(9)
(10)		CDD10.0	1834	0	0	5	84	240	383	460	395	220	47	0	0	(10)
(11)		CDD18.3	550	0	0	0	4	39	136	202	140	28	1	0	0	(11)
(12)		CDH23.3	5338	0	0	0	73	461	1362	1989	1196	247	9	0	0	(12)
(13)		CDH26.7	1962	0	0	0	14	131	523	839	404	51	1	0	0	(13)
(14)	Wind	WSAvg	2.0	1.8	2.0	2.4	2.5	2.4	2.1	2.0	1.9	1.8	1.7	1.9	1.9	(14)
(15)	Precipitation	PrecAvg	146	1	1	3	5	15	23	30	36	23	6	2	1	(15)
(16)		PrecMax	235	6	10	22	38	64	97	79	120	74	22	17	9	(16)
(17)		PrecMin	50	0	0	0	0	1	0	5	0	3	0	0	0	(17)
(18)		PrecStd	43	1	2	5	8	15	24	18	29	20	7	4	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.4	10.5	20.1	28.8	32.1	34.7	35.7	33.8	31.0	24.5	14.8	5.5	(19)
(20)		MCWB	-1.5	2.2	8.1	12.3	14.3	16.8	20.9	19.2	16.5	11.9	5.8	-0.5	(20)	
(21)		2%	DB	1.6	7.6	16.7	25.4	30.0	33.0	33.8	32.0	27.9	21.5	12.0	2.9	(21)
(22)		MCWB	-3.2	0.7	5.8	10.4	13.6	16.5	19.2	18.7	15.4	10.6	4.6	-2.1	(22)	
(23)		5%	DB	-0.3	5.6	14.2	22.8	27.9	31.4	32.5	30.5	26.0	19.3	9.8	1.1	(23)
(24)		MCWB	-4.5	-0.5	4.5	9.3	12.7	16.0	18.9	18.2	14.4	9.6	3.3	-3.2	(24)	
(25)		10%	DB	-2.1	3.5	11.7	20.3	26.0	29.8	31.1	29.0	24.4	17.1	7.6	-0.4	(25)
(26)		MCWB	-5.7	-1.8	3.2	8.3	11.9	15.7	18.5	17.7	14.1	8.6	2.2	-4.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.3	3.2	8.6	13.7	16.1	20.3	23.4	22.6	19.2	13.9	7.2	0.0	(27)
(28)		MCDWB	4.0	8.2	18.1	23.0	26.0	27.7	32.7	29.5	24.4	20.2	12.4	4.8	(28)	
(29)		2%	WB	-3.1	1.0	6.4	11.7	15.0	18.9	21.7	21.3	17.4	12.1	5.0	-1.7	(29)
(30)		MCDWB	1.3	6.9	15.5	22.2	26.0	27.5	30.2	27.9	24.0	18.9	10.8	2.3	(30)	
(31)		5%	WB	-4.4	-0.2	5.0	10.3	13.9	18.0	20.7	20.3	16.4	10.7	3.8	-2.9	(31)
(32)		MCDWB	-0.6	4.9	13.0	20.7	24.9	26.7	28.7	27.1	23.1	17.3	9.2	0.9	(32)	
(33)		10%	WB	-5.6	-1.5	3.7	9.1	13.0	17.2	19.9	19.3	15.3	9.4	2.5	-4.0	(33)
(34)		MCDWB	-2.2	3.4	11.0	19.3	23.3	25.9	27.6	26.2	22.0	15.8	7.3	-0.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.2	11.7	11.9	12.5	12.5	11.6	10.8	10.7	11.5	11.5	9.2	9.0	(35)	
(36)		5% DB	MCDBR	11.6	13.4	15.1	16.3	15.5	14.1	13.1	12.6	13.7	14.3	11.4	10.0	(36)
(37)		MCWBR	8.2	8.4	7.9	7.0	5.9	4.6	4.3	4.4	5.1	6.4	6.3	6.8	(37)	
(38)		5% WB	MCDBR	11.3	12.7	13.5	13.4	13.0	11.3	10.9	10.0	11.0	12.3	10.9	9.4	(38)
(39)		MCWBR	8.1	8.0	7.3	6.3	5.6	4.2	4.4	4.5	4.8	6.3	6.4	6.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.314	0.360	0.408	0.459	0.490	0.514	0.489	0.482	0.451	0.398	0.349	0.318	(40)	
(41)		taud	2.179	2.069	1.950	1.869	1.859	1.868	2.004	1.998	2.003	2.067	2.121	2.144	(41)	
(42)		Ebn at Noon	821	829	828	813	797	777	793	785	778	774	764	776	(42)	
(43)		Edh at Noon	101	132	167	194	201	200	173	169	157	131	106	96	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.56	3.64	4.99	6.14	6.92	6.78	6.36	5.85	4.93	4.07	2.88	2.32	(44)	
(45)		RadStd	0.27	0.21	0.31	0.33	0.31	0.44	0.36	0.28	0.27	0.16	0.21	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	-1.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page