

YULIN, China

WMO: 536460

Lat: 38.2687N

Lon: 109.7804E

Elev: 3799

StdP: 12.79

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	1.9	-20.3	2.1	15.9	-16.0	2.6	14.7	18.6	24.0	15.6	25.4	3.2	340	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	90.8	63.8	88.2	62.9	85.6	62.5	71.1	80.1	69.6	78.6	68.2	77.8	6.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	122.6	75.0	67.0	114.4	74.0	65.2	107.3	73.1	37.8	80.3	36.3	78.6	34.9	77.9	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.0	12.8	DB	-9.3	95.2	4.9	4.1	-12.8	98.2	-15.7	100.6	-18.4	102.9	-21.9	105.9	(4)
(5)			WB	-10.1	73.3	4.6	1.7	-13.4	74.5	-16.1	75.5	-18.7	76.4	-22.0	77.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	18.5	27.2	40.1	53.6	63.6	71.7	75.2	71.7	62.4	50.4	35.8	22.3		
	DBStd	20.66	7.83	8.96	9.08	8.53	6.65	5.25	4.59	4.90	6.03	6.90	7.74	7.48		
	HDD50	3367	976	637	325	59	2	0	0	0	1	80	427	860		
	HDD65	6514	1441	1057	771	351	106	10	1	8	115	454	875	1325		
	CDD50	3182	0	0	19	168	424	651	782	671	374	92	1	0		
	CDD65	855	0	0	0	10	63	211	318	214	38	1	0	0		
	CDH74	7428	0	0	4	140	708	2006	2780	1507	276	7	0	0		
	CDH80	2454	0	0	0	31	172	708	1069	413	61	0	0	0		
(14) Wind	WSAvg	5.4	4.3	5.2	6.2	6.7	6.5	5.8	5.5	5.2	4.9	4.9	4.8	4.6		
(15) Precipitation	PrecAvg	15.9	0.1	0.2	0.5	0.9	1.2	1.7	3.5	4.2	2.4	0.9	0.5	0.1		
	PrecMax	26.0	0.4	0.4	2.5	2.3	3.0	6.1	8.3	9.8	5.3	3.5	2.8	0.4		
	PrecMin	10.1	0.0	0.0	0.0	0.0	0.1	0.2	0.7	0.7	0.6	0.3	0.0	0.0		
	PrecStd	3.7	0.1	0.1	0.6	0.7	0.7	1.2	1.9	2.5	1.2	0.7	0.7	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.9	54.7	71.9	84.2	88.8	93.1	95.4	90.7	87.1	74.3	61.8	45.6		
		MCWB	32.1	38.4	47.4	53.6	56.4	61.6	65.9	65.9	62.1	54.4	44.3	32.8		
	2%	DB	39.6	49.5	64.6	77.8	84.4	89.5	91.7	87.3	80.2	69.7	57.1	41.2		
		MCWB	29.0	35.6	44.2	51.6	55.6	60.7	65.6	65.5	60.8	52.6	42.0	30.3		
	5%	DB	35.7	45.6	60.1	73.4	81.3	87.0	88.9	84.5	76.7	66.5	52.9	37.6		
		MCWB	26.9	33.5	41.6	49.4	54.7	60.0	64.8	65.5	59.2	51.2	40.3	28.5		
	10%	DB	32.1	42.0	55.5	69.2	78.0	84.3	86.1	81.9	73.5	62.9	48.9	34.5		
		MCWB	24.4	31.6	39.3	48.1	53.4	59.4	65.1	64.9	58.3	49.3	38.9	26.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.2	40.1	49.1	58.2	61.7	68.4	73.5	73.1	69.3	58.1	48.3	34.2		
		MCDB	42.9	50.4	64.5	71.2	75.9	78.8	83.0	80.9	74.9	68.8	52.4	43.0		
	2%	WB	29.6	37.2	45.5	54.6	59.6	66.1	71.5	71.1	65.9	55.8	44.9	31.4		
		MCDB	38.6	46.7	60.9	70.0	74.0	77.5	81.8	78.9	73.6	65.0	52.3	38.6		
	5%	WB	27.2	34.7	43.0	52.3	57.8	64.4	70.0	69.7	63.0	53.8	42.3	29.5		
		MCDB	34.7	43.7	56.8	67.7	72.7	77.6	80.1	77.5	71.5	62.4	50.8	36.1		
	10%	WB	24.9	32.2	40.5	50.3	56.2	63.0	68.7	68.1	60.9	51.7	39.8	27.6		
		MCDB	31.8	40.7	53.9	64.7	71.3	76.6	78.9	77.1	69.2	59.2	47.9	34.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.8	21.8	21.5	22.2	21.8	20.8	17.8	16.8	17.5	19.3	19.3	19.8		
		MCDBR	25.4	25.2	27.0	28.1	27.3	25.6	22.7	21.3	22.7	23.8	24.8	23.5		
	5% WB	MCWBR	17.5	15.2	13.7	11.9	10.0	8.1	6.7	7.0	8.4	11.2	13.7	15.5		
		MCDWR	24.1	22.0	24.3	22.7	20.7	19.8	16.7	15.5	16.6	18.9	20.6	21.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.353	0.430	0.460	0.495	0.514	0.564	0.550	0.558	0.519	0.470	0.385	0.347		
		taud	2.055	1.877	1.848	1.809	1.833	1.775	1.879	1.836	1.870	1.907	2.031	2.107		
	Ebn at Noon	Ebn at Noon	250	242	250	250	248	235	237	231	231	226	235	243		
		Edh at Noon	38	53	60	66	66	70	62	64	58	50	39	34		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	876	1137	1557	1867	2066	2005	1894	1686	1388	1194	948	797		
	RadStd	RadStd	75	86	118	137	124	127	117	123	114	109	112	77		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	-2.77	-1.51	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page