

YULIN, China

WMO: 536460

Lat: 38.2687N

Lon: 109.7804E

Elev: 1158

StdP: 88.17

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.2	-16.7	-29.0	0.3	-9.0	-26.7	0.4	-9.6	8.3	-4.5	7.0	-3.7	1.4	340	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	32.7	17.7	31.2	17.1	29.8	16.9	21.7	26.7	20.9	25.9	20.1	25.4	3.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	17.5	23.9	19.4	16.3	23.3	18.4	15.3	22.8	69.9	26.9	66.6	25.9	63.4	25.5	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.1	6.7	5.7	-22.9	35.1	2.7	2.3	-24.9	36.8	-26.5	38.1	-28.0	39.4	-30.0	41.0
			-23.4	22.9	2.6	0.9	-25.2	23.6	-26.7	24.2	-28.2	24.7	-30.0	25.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-7.5	-2.6	4.5	12.0	17.6	22.1	24.0	22.0	16.9	10.2	2.1	-5.4
	DBStd	11.48	4.35	4.98	5.05	4.74	3.69	2.92	2.55	2.72	3.35	3.84	4.30	4.16
	HDD10.0	1871	542	354	181	33	1	0	0	0	1	44	237	478
	HDD18.3	3619	801	587	428	195	59	6	1	4	64	252	486	736
	CDD10.0	1768	0	0	11	93	236	362	434	373	208	51	1	0
	CDD18.3	475	0	0	0	6	35	117	177	119	21	1	0	0
	CDH23.3	4127	0	0	2	78	393	1114	1544	837	153	4	0	0
	CDH26.7	1363	0	0	0	17	96	393	594	229	34	0	0	0
Wind	WSAvg	2.4	1.9	2.3	2.8	3.0	2.9	2.6	2.5	2.3	2.2	2.2	2.1	2.0
Precipitation	PrecAvg	405	3	4	12	22	30	43	88	106	60	22	12	2
	PrecMax	660	11	11	64	58	76	154	211	250	134	89	71	11
	PrecMin	256	0	0	0	1	3	5	17	18	16	7	0	0
	PrecStd	94	3	3	14	17	17	30	49	64	30	18	17	3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	12.6	22.1	29.0	31.6	33.9	35.2	32.6	30.6	23.5	16.6	7.6
		MCWB	0.1	3.6	8.6	12.0	13.5	16.5	18.8	18.8	16.7	12.5	6.9	0.4
	2%	DB	4.2	9.7	18.1	25.5	29.1	32.0	33.2	30.7	26.8	21.0	13.9	5.1
		MCWB	-1.6	2.0	6.8	10.9	13.1	16.0	18.7	18.6	16.0	11.5	5.6	-0.9
	5%	DB	2.1	7.5	15.6	23.0	27.4	30.5	31.6	29.2	24.8	19.2	11.6	3.1
		MCWB	-2.8	0.8	5.3	9.7	12.6	15.6	18.2	18.6	15.1	10.7	4.6	-1.9
	10%	DB	0.1	5.6	13.0	20.7	25.6	29.1	30.1	27.7	23.0	17.2	9.4	1.4
		MCWB	-4.2	-0.2	4.0	8.9	11.9	15.2	18.4	18.3	14.6	9.6	3.8	-3.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.7	4.5	9.5	14.6	16.5	20.2	23.1	22.8	20.7	14.5	9.0	1.2
		MCDB	6.1	10.2	18.1	21.8	24.4	26.0	28.4	27.2	23.9	20.4	11.3	6.1
	2%	WB	-1.4	2.9	7.5	12.6	15.4	18.9	22.0	21.7	18.8	13.2	7.2	-0.3
		MCDB	3.7	8.2	16.0	21.1	23.3	25.3	27.7	26.0	23.1	18.3	11.3	3.7
	5%	WB	-2.7	1.5	6.1	11.3	14.4	18.0	21.1	20.9	17.2	12.1	5.7	-1.4
		MCDB	1.5	6.5	13.8	19.8	22.6	25.3	26.7	25.3	22.0	16.9	10.4	2.3
	10%	WB	-3.9	0.1	4.7	10.1	13.4	17.2	20.4	20.1	16.0	10.9	4.3	-2.5
		MCDB	-0.1	4.8	12.2	18.2	21.8	24.8	26.1	25.1	20.7	15.1	8.8	1.2
Mean Daily Temperature Range	5% DB	MDBR	12.1	12.1	11.9	12.3	12.1	11.5	9.9	9.4	9.7	10.7	10.7	11.0
		MCDBR	14.1	14.0	15.0	15.6	15.2	14.2	12.6	11.9	12.6	13.2	13.8	13.0
		MCWBR	9.7	8.5	7.6	6.6	5.6	4.5	3.7	3.9	4.7	6.2	7.6	8.6
	5% WB	MCDBR	13.4	12.2	13.5	12.6	11.5	11.0	9.3	8.6	9.2	10.5	11.4	11.6
		MCWBR	9.4	7.6	7.3	6.0	4.9	4.1	3.7	3.9	4.5	5.7	6.9	7.9
Clear-Sky Solar Irradiance	taub	0.353	0.430	0.460	0.495	0.514	0.564	0.550	0.558	0.519	0.470	0.385	0.347	
	taud	2.055	1.877	1.848	1.809	1.833	1.775	1.879	1.836	1.870	1.907	2.031	2.107	
	Ebn at Noon	788	763	788	788	782	741	748	729	727	713	741	765	
	Edh at Noon	121	166	189	209	208	220	197	201	183	159	123	107	
All-Sky Solar Radiation	RadAvg	2.76	3.58	4.91	5.89	6.51	6.32	5.97	5.31	4.38	3.77	2.99	2.51	
	RadStd	0.24	0.27	0.37	0.43	0.39	0.40	0.37	0.39	0.36	0.34	0.35	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	-1.54	-0.84	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page