

YUANPING, China

WMO: 536730

Lat: 38.7383N

Lon: 112.7143E

Elev: 838

StdP: 91.65

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-13.0	-28.2	0.3	-7.5	-26.3	0.4	-7.2	8.8	-5.8	7.9	-5.2	1.2	0	0.422

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	32.5	18.3	31.1	18.6	29.9	18.4	22.9	28.2	22.1	27.2	21.3	26.4	2.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	17.8	25.8	20.5	16.8	24.9	19.6	15.9	24.4	72.9	28.1	69.3	27.2	66.3	26.6	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
8.0	6.8	5.7	-18.3	35.1	2.6	1.8	-20.2	36.4	-21.7	37.4	-23.2	38.4	-25.1	39.7		
			-19.1	24.2	2.4	1.0	-20.8	24.9	-22.2	25.4	-23.5	26.0	-25.2	26.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-5.6	-1.3	5.6	12.9	18.8	22.5	24.3	22.7	17.7	11.0	2.7	-4.2
	DBStd	11.02	3.28	3.85	4.38	4.43	3.37	2.71	2.39	2.52	2.98	3.41	4.00	3.49
	HDD10.0	1660	484	317	148	22	1	0	0	0	0	29	219	439
	HDD18.3	3337	742	551	396	168	35	3	1	2	45	227	469	698
	CDD10.0	1898	0	0	11	109	274	376	443	392	232	61	1	0
	CDD18.3	533	0	0	0	6	50	129	185	136	27	0	0	0
	CDH23.3	4566	0	0	2	103	554	1176	1570	959	197	6	0	0
	CDH26.7	1464	0	0	0	24	158	424	566	258	34	0	0	0
Wind	WSAvg	2.0	1.9	2.0	2.4	2.5	2.6	2.0	1.7	1.6	1.6	1.7	1.6	1.8
Precipitation	PrecAvg	424	2	5	8	19	29	52	104	114	58	23	8	2
	PrecMax	761	9	22	42	78	73	160	235	392	178	68	46	8
	PrecMin	162	0	0	0	0	1	3	17	22	3	1	0	0
	PrecStd	136	3	5	8	18	21	35	52	77	42	19	9	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.9	12.3	22.2	29.7	32.5	34.7	34.7	32.2	29.9	24.2	16.5	7.2
		MCWB	-0.1	3.6	9.0	12.8	14.7	17.5	19.6	20.3	17.7	13.2	7.0	0.5
	2%	DB	4.1	9.7	18.5	26.1	30.2	32.4	32.5	30.7	27.3	21.8	14.0	5.1
		MCWB	-1.9	1.9	7.1	11.6	14.1	16.6	20.1	20.5	16.6	11.9	5.7	-0.8
	5%	DB	2.2	7.6	15.9	23.6	28.4	30.7	31.1	29.4	25.5	19.7	11.7	3.5
		MCWB	-3.0	0.8	5.7	10.5	13.5	16.6	20.4	20.0	16.0	11.0	4.4	-1.7
	10%	DB	0.6	5.6	13.3	21.4	26.5	29.2	29.8	28.1	23.8	17.6	9.5	1.8
		MCWB	-3.8	-0.4	4.4	9.5	12.9	16.6	20.3	19.8	15.6	10.1	3.6	-2.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.2	4.3	9.7	15.3	17.9	20.9	24.2	24.2	20.7	15.4	8.3	1.2
		MCDB	6.4	11.0	19.9	22.6	25.6	28.3	29.8	28.2	26.1	21.2	12.5	5.9
	2%	WB	-1.5	2.5	7.7	13.4	16.5	19.9	23.2	22.7	19.2	13.7	6.9	-0.4
		MCDB	3.5	8.2	16.4	22.5	24.7	26.7	28.7	27.8	23.5	18.7	11.6	4.5
	5%	WB	-2.7	1.2	6.3	12.0	15.5	19.1	22.5	21.9	17.7	12.6	5.4	-1.4
		MCDB	2.0	6.6	14.8	21.0	24.0	25.6	27.8	26.8	22.3	17.2	10.7	2.9
	10%	WB	-3.8	0.0	5.0	10.7	14.5	18.4	21.7	21.1	16.7	11.4	4.1	-2.5
		MCDB	0.4	5.3	12.3	19.2	23.3	25.2	27.0	25.8	21.7	16.1	8.9	1.6
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.9	11.5	12.2	12.4	11.2	9.4	9.2	10.2	10.7	10.0	9.6
		MCDBR	12.6	13.7	15.3	16.4	15.8	14.4	12.1	11.2	13.2	13.9	13.5	11.8
		MCWBR	8.5	8.3	7.9	6.9	5.8	4.8	4.1	4.1	5.2	6.3	7.5	7.7
	5% WB	MCDBR	12.1	12.6	14.3	13.8	12.4	10.6	9.3	8.9	9.9	10.8	11.6	11.0
		MCWBR	8.4	7.8	7.7	6.3	5.3	4.2	3.9	3.8	4.7	5.6	6.9	7.2
Clear-Sky Solar Irradiance	taub	0.349	0.425	0.449	0.495	0.531	0.633	0.619	0.608	0.541	0.475	0.374	0.342	
	taud	2.148	1.966	1.939	1.887	1.845	1.685	1.764	1.766	1.858	1.946	2.143	2.207	
	Ebn at Noon	796	769	799	788	768	690	696	688	706	707	758	774	
	Edh at Noon	110	151	172	193	205	241	221	216	185	153	110	97	
All-Sky Solar Radiation	RadAvg	2.81	3.50	4.84	5.70	6.29	5.68	5.25	4.89	4.23	3.63	2.87	2.49	
	RadStd	0.21	0.27	0.39	0.38	0.45	0.45	0.31	0.39	0.33	0.30	0.36	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page