

YUSHE, China

WMO: 537870

Lat: 37.0687N

Lon: 112.9826E

Elev: 3419

StdP: 12.97

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.6	6.1	-19.4	2.1	17.7	-14.9	2.8	20.2	16.0	26.0	13.6	28.8	2.9	70	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	88.6	64.7	86.2	64.7	83.9	64.5	72.7	80.7	71.2	78.7	69.8	77.3	7.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.4	127.3	77.0	68.9	120.9	75.6	67.4	114.5	74.2	39.0	81.2	37.5	79.0	36.2	77.2	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.9	13.3	11.2	DB	-3.7	93.6	3.7	2.6	-6.4	95.5	-8.6	97.0	-10.7	98.4	-13.4	100.3	(4)
			WB	-4.9	74.9	3.6	1.4	-7.5	75.9	-9.6	76.7	-11.6	77.4	-14.2	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.6	22.2	28.9	40.5	52.5	62.0	69.3	73.4	70.5	61.7	50.4	37.0	25.0
	DBStd	18.64	6.18	7.02	7.40	7.50	5.39	4.40	3.95	4.75	5.54	5.73	6.99	6.37
	HDD50	3052	861	590	306	59	2	0	0	0	2	66	390	776
	HDD65	6281	1326	1010	761	379	121	13	1	11	126	453	839	1241
	CDD50	2891	0	0	11	134	374	579	725	637	352	78	1	0
	CDD65	641	0	0	0	3	28	142	260	182	26	0	0	0
	CDH74	5744	0	0	4	120	569	1513	2015	1260	258	5	0	0
	CDH80	1649	0	0	0	25	117	479	663	318	47	0	0	0
Wind	WSAvg	4.4	3.7	4.1	5.1	5.6	5.5	4.9	4.2	3.9	3.8	4.0	3.8	3.7
Precipitation	PrecAvg	23.1	0.2	0.3	0.6	1.0	1.5	2.8	6.0	5.3	3.1	1.4	0.6	0.2
	PrecMax	34.5	0.6	1.0	1.9	3.9	5.1	8.7	10.6	9.6	8.2	3.7	1.8	0.9
	PrecMin	12.5	0.0	0.0	0.0	0.1	0.1	0.7	1.0	0.9	0.5	0.0	0.0	0.0
	PrecStd	5.3	0.2	0.3	0.4	0.9	1.2	2.0	2.6	2.6	1.9	1.1	0.5	0.2
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.9	56.2	71.9	84.0	87.3	91.7	93.2	88.8	85.6	74.2	63.7
MCWB			33.6	39.7	48.2	55.7	57.6	62.6	66.3	68.2	63.0	54.6	46.5	35.5
2%		DB	42.5	50.3	64.7	77.1	83.3	87.9	89.1	86.0	80.2	70.4	58.8	44.2
		MCWB	30.5	36.6	44.5	52.5	56.6	61.4	66.9	68.0	61.6	52.5	43.1	32.4
5%		DB	38.6	46.6	60.0	72.7	80.2	85.3	86.2	83.6	76.6	66.9	54.5	40.4
		MCWB	28.6	34.2	42.5	50.6	55.6	61.1	67.7	67.5	60.4	51.1	41.3	30.3
10%		DB	35.0	42.6	55.6	68.5	77.0	82.6	83.7	81.1	73.3	63.0	50.2	37.1
		MCWB	27.0	32.0	40.4	48.9	54.7	61.1	67.9	66.9	59.4	49.4	39.6	28.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.8	41.5	50.7	60.5	62.8	69.7	75.0	74.3	70.0	58.7	49.0	37.5
		MCDB	42.5	51.7	64.5	71.3	74.7	79.5	83.4	83.2	76.4	67.6	58.4	45.9
	2%	WB	32.0	38.0	46.5	56.4	61.0	67.5	73.3	72.4	66.0	56.1	45.8	33.7
		MCDB	40.7	47.3	61.0	70.0	73.4	77.7	81.3	80.6	74.2	64.5	53.5	42.2
	5%	WB	29.3	35.5	43.8	53.6	59.4	65.7	71.9	71.0	63.9	54.2	43.4	31.1
		MCDB	38.3	44.5	57.8	68.0	72.4	76.8	79.5	78.4	71.3	61.5	51.2	38.8
	10%	WB	27.0	33.0	41.2	51.1	57.7	64.3	70.5	69.5	61.6	52.2	40.8	29.3
		MCDB	34.6	41.7	54.1	64.7	70.6	75.3	78.2	76.6	68.7	59.4	49.2	36.0
Mean Daily Temperature Range	5% DB	MDBR	23.4	22.6	23.8	24.9	25.5	23.5	18.7	18.2	20.0	21.7	21.9	21.7
		MCDBR	28.9	28.8	32.3	32.9	32.7	29.8	24.3	22.6	26.2	28.8	28.9	26.7
		MCWBR	19.2	17.5	16.9	14.1	12.3	9.5	7.6	8.0	10.0	13.3	16.1	17.1
	5% WB	MCDBR	26.7	25.7	28.8	26.7	23.8	21.3	16.9	16.8	18.4	19.9	23.6	23.7
		MCWBR	18.0	15.9	15.7	12.1	10.4	8.2	7.1	7.3	8.5	10.3	14.1	15.6
Clear-Sky Solar Irradiance	taub	0.402	0.486	0.510	0.545	0.577	0.684	0.672	0.651	0.589	0.538	0.427	0.382	
	taud	1.973	1.796	1.788	1.755	1.736	1.573	1.645	1.664	1.743	1.789	1.964	2.046	
	Ebn at Noon	234	226	237	238	233	208	210	210	213	208	223	232	
	Edh at Noon	43	58	64	70	73	86	79	76	67	58	43	37	
All-Sky Solar Radiation	RadAvg	855	1042	1435	1707	1868	1707	1540	1454	1238	1080	881	780	
	RadStd	84	126	139	134	143	136	105	128	109	127	129	75	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page