

JIEXIU, China

WMO: 538630

Lat: 37.0628N

Lon: 111.9450E

Elev: 2444

StdP: 13.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.1	12.9	-14.8	2.7	23.7	-10.6	3.4	24.9	20.7	29.6	18.4	31.7	3.0	250	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	92.9	67.6	90.3	67.8	87.9	67.8	75.8	84.5	74.3	83.0	72.8	81.3	7.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.7	137.3	80.0	71.8	128.7	78.9	70.1	121.5	77.9	41.4	85.0	39.8	82.8	38.3	81.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	16.0	13.7	DB	2.6	97.9	4.7	2.5	-0.8	99.7	-3.6	101.1	-6.2	102.6	-9.7	104.4	(4)
(5)			WB	1.3	78.1	4.4	1.9	-1.8	79.5	-4.4	80.6	-6.9	81.6	-10.1	83.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	26.3	33.3	45.3	56.9	66.3	73.6	77.1	73.7	64.8	53.9	40.7	29.7	(6)
(7)		DBStd	18.45	6.44	6.90	7.80	7.70	5.77	4.94	4.42	4.88	5.55	5.87	6.98	6.34	(7)
(8)		HDD50	2355	733	469	186	24	0	0	0	0	0	30	284	629	(8)
(9)		HDD65	5254	1198	889	610	258	53	4	0	4	69	347	728	1094	(9)
(10)		CDD50	3666	0	0	42	233	507	707	840	735	445	150	7	0	(10)
(11)		CDD65	1088	0	0	1	17	95	261	375	274	63	2	0	0	(11)
(12)		CDH74	10466	0	0	17	273	1185	2777	3477	2175	530	32	0	0	(12)
(13)		CDH80	3911	0	0	1	62	356	1180	1454	730	126	2	0	0	(13)
(14)	Wind	WSAvg	5.3	5.3	5.6	6.5	6.6	6.3	5.4	4.7	4.2	4.1	4.5	5.1	5.4	(14)
(15)	Precipitation	PrecAvg	19.6	0.1	0.2	0.6	1.0	1.5	2.1	5.2	3.8	3.0	1.3	0.6	0.2	(15)
(16)		PrecMax	28.9	0.6	1.0	1.9	3.5	5.7	5.2	12.5	7.6	9.3	4.0	1.8	0.6	(16)
(17)		PrecMin	10.9	0.0	0.0	0.0	0.0	0.0	0.4	1.3	0.9	0.4	0.0	0.0	0.0	(17)
(18)		PrecStd	4.8	0.2	0.2	0.4	0.8	1.3	1.4	2.9	1.7	2.2	1.0	0.5	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	59.3	76.2	86.4	91.1	96.0	97.1	92.2	89.0	77.7	65.6	51.5	(19)
MCWB			36.6	42.0	51.4	59.2	60.5	65.2	71.1	71.7	66.5	57.4	47.0	37.5	(20)	
2%		DB	44.7	53.9	69.2	80.8	86.9	92.7	93.3	89.1	83.3	73.5	61.0	46.8	(21)	
		MCWB	32.7	38.9	47.6	56.1	59.8	64.4	70.2	71.9	64.8	55.9	45.5	34.8	(22)	
5%		DB	41.1	50.3	64.6	76.6	83.9	89.8	90.5	86.9	79.7	69.7	57.0	43.2	(23)	
		MCWB	30.7	37.6	45.6	53.7	59.1	64.0	70.7	71.2	63.4	53.7	43.9	32.7	(24)	
10%		DB	37.5	46.2	60.2	72.3	80.9	87.2	87.8	84.3	76.4	66.1	52.9	40.0	(25)	
		MCWB	28.8	35.0	43.6	52.4	58.1	63.9	70.7	70.2	62.4	52.6	42.5	31.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.0	43.8	53.0	63.5	66.4	72.5	78.9	77.9	72.2	61.9	51.3	39.5	(27)
MCD B			48.5	54.5	71.4	77.1	81.1	84.3	87.5	86.4	80.3	71.6	58.4	47.8	(28)	
2%		WB	33.6	40.5	49.7	59.4	63.8	70.3	76.3	75.8	68.4	59.1	48.6	36.1	(29)	
		MCD B	42.9	51.0	64.8	75.3	78.3	82.1	85.0	84.2	76.8	67.4	55.5	44.1	(30)	
5%		WB	31.3	38.2	47.2	56.6	62.2	68.4	74.7	74.3	66.3	57.1	46.2	33.9	(31)	
		MCD B	39.9	48.3	62.3	71.0	77.0	80.9	83.9	82.4	74.6	64.2	53.3	41.3	(32)	
10%		WB	29.3	35.9	44.7	54.3	60.6	67.0	73.4	72.7	64.4	55.1	43.8	32.0	(33)	
		MCD B	36.8	45.6	58.0	67.5	75.1	79.8	82.5	80.3	72.4	62.5	51.8	38.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.7	20.1	21.5	22.8	23.5	23.0	18.0	17.9	19.3	20.2	18.9	17.0	(35)
MCDBR			23.5	26.0	29.0	29.8	29.6	28.9	23.7	22.0	25.8	27.5	26.0	21.9	(36)	
MCWBR			14.7	14.8	13.9	12.0	11.0	8.4	7.3	8.0	10.1	11.9	13.6	13.2	(37)	
5% WB		MCDBR	21.8	23.8	26.6	25.1	23.8	21.5	17.8	17.6	20.0	19.7	21.9	20.3	(38)	
		MCWBR	14.0	13.9	13.5	11.8	10.2	8.0	7.3	7.8	9.3	10.3	12.7	12.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.406	0.488	0.509	0.539	0.571	0.659	0.651	0.648	0.583	0.538	0.431	0.384	(40)	
taud		2.000	1.824	1.818	1.789	1.783	1.650	1.718	1.703	1.795	1.822	1.989	2.074	(41)		
Ebn at Noon		234	226	238	240	235	214	214	211	215	209	222	232	(42)		
Edh at Noon		42	57	62	68	69	79	74	73	63	56	42	36	(43)		
(44)	All-Sky Solar Radiation	RadAvg	883	1083	1476	1755	1919	1803	1631	1505	1265	1113	915	805	(44)	
(45)		RadStd	87	122	137	139	140	138	127	118	112	133	128	77	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page