

XIFENGZHEN, China

WMO: 539230

Lat: 35.7267N

Lon: 107.6283E

Elev: 1423

StdP: 85.36

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.0	-10.1	-24.5	0.5	-6.0	-22.1	0.6	-5.3	6.8	-1.8	6.0	-1.1	2.2	320	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	30.1	17.1	28.6	17.3	27.3	17.2	21.2	25.5	20.6	24.8	19.9	23.9	3.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	17.6	23.2	19.4	16.9	22.8	18.7	16.1	22.4	69.4	25.7	66.9	24.7	64.3	23.9	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.5	4.8	DB	-14.6	32.4	2.6	1.4	-16.5	33.4	-18.1	34.3	-19.5	35.1	-21.4	36.1	(4)
(5)			WB	-15.8	22.2	2.4	0.7	-17.5	22.6	-18.9	23.0	-20.3	23.4	-22.0	23.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-3.4	-0.1	5.8	12.1	16.6	20.6	22.3	20.9	16.0	10.2	4.1	-1.8
	DBStd	9.56	3.80	4.06	4.75	4.45	3.51	3.00	2.56	2.81	3.31	3.55	3.76	3.46
	HDD10.0	1458	415	284	144	28	2	0	0	0	1	41	179	365
	HDD18.3	3255	673	517	387	192	76	12	2	9	84	251	427	623
	CDD10.0	1579	0	0	16	90	205	319	382	337	182	48	2	0
	CDD18.3	334	0	0	0	4	21	81	126	88	15	0	0	0
	CDH23.3	1999	0	0	1	28	131	543	791	435	71	1	0	0
CDH26.7	426	0	0	0	3	14	125	195	75	13	0	0	0	
Wind	WSAvg	2.4	2.2	2.4	2.6	2.8	2.7	2.6	2.6	2.4	2.3	2.2	2.3	2.3
Precipitation	PrecAvg	569	4	7	19	40	56	57	113	106	100	43	19	4
	PrecMax	806	12	21	47	102	113	117	289	228	249	149	48	18
	PrecMin	360	0	1	0	7	11	6	44	19	25	10	0	0
	PrecStd	122	3	5	11	21	29	30	52	62	55	31	14	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	13.0	21.0	26.5	28.3	31.6	32.1	30.6	28.2	21.6	16.3	9.2
		MCWB	0.9	4.6	8.9	12.8	13.6	15.2	18.9	18.7	15.8	12.2	7.7	1.5
	2%	DB	6.2	10.2	17.9	23.4	26.3	29.6	30.3	28.6	25.2	19.3	14.0	6.8
		MCWB	-0.2	2.6	7.4	11.3	13.1	15.4	18.1	18.9	16.2	11.4	6.4	0.3
	5%	DB	4.1	8.0	15.3	21.2	24.7	28.1	28.9	27.1	23.1	17.5	12.0	5.1
		MCWB	-1.6	1.5	6.1	10.0	12.7	15.4	18.4	18.8	15.6	10.6	5.4	-0.6
	10%	DB	2.2	6.1	13.1	19.3	23.1	26.6	27.4	25.8	21.2	15.7	9.8	3.5
		MCWB	-2.7	0.4	5.2	9.4	12.3	15.2	18.5	18.6	15.0	9.9	4.4	-1.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.6	5.2	10.9	14.6	17.0	19.5	22.4	22.0	20.6	14.6	9.5	2.4
		MCDB	7.9	11.9	16.8	22.0	23.0	24.5	26.8	26.2	23.2	18.1	13.6	7.3
	2%	WB	0.0	3.4	8.3	13.1	15.8	18.5	21.5	21.2	18.5	13.3	8.2	0.9
		MCDB	5.6	8.8	16.1	19.9	21.3	23.9	25.9	25.5	21.9	16.5	11.5	5.8
	5%	WB	-1.3	2.0	6.9	11.9	14.8	17.7	20.9	20.6	17.0	12.2	6.7	-0.2
		MCDB	3.7	6.6	13.8	18.2	20.3	23.2	25.1	24.7	20.3	15.3	10.1	4.2
	10%	WB	-2.5	0.9	5.7	10.6	13.9	17.1	20.1	20.0	16.1	11.2	5.3	-1.1
		MCDB	1.7	4.9	11.8	16.6	19.9	22.5	24.4	23.7	19.1	14.2	8.8	2.8
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.5	8.4	9.1	8.7	7.8	7.2	6.7	7.0	7.2	6.9	
		MCDBR	9.8	10.7	11.7	11.7	11.6	11.3	10.2	9.1	9.6	9.5	10.2	9.3
		MCWBR	6.0	6.0	5.8	5.1	4.6	3.6	3.0	3.0	3.5	4.3	5.6	5.6
	5% WB	MCDBR	9.7	9.5	10.5	10.2	8.8	8.2	7.5	7.2	6.8	7.3	8.2	8.4
		MCWBR	6.0	5.7	5.5	5.1	4.3	3.3	2.9	2.9	3.2	4.0	5.1	5.2
Clear-Sky Solar Irradiance	taub		0.400	0.475	0.510	0.526	0.515	0.529	0.534	0.567	0.520	0.492	0.419	0.375
	taud		1.942	1.789	1.755	1.766	1.861	1.884	1.937	1.824	1.888	1.871	1.963	2.027
	Ebn at Noon		752	734	753	770	786	773	765	729	738	709	725	753
	Edh at Noon		143	188	212	221	203	199	187	206	184	171	139	123
All-Sky Solar Radiation	RadAvg		2.65	3.24	4.31	5.21	5.65	5.75	5.34	4.67	3.61	3.17	2.77	2.49
	RadStd		0.26	0.44	0.40	0.45	0.40	0.44	0.64	0.56	0.40	0.49	0.39	0.27

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-38

Nomenclature: See separate page