

JARUD QI, China

WMO: 540260

Lat: 44.5473N

Lon: 120.8988E

Elev: 873

StdP: 14.24

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	-2.1	-24.9	1.4	0.2	-21.4	1.7	3.2	18.0	14.9	16.3	12.3	5.2	290	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	93.6	68.1	90.5	67.5	87.6	66.8	75.1	84.6	73.2	82.7	71.4	81.1	6.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.2	123.3	80.3	70.2	114.6	79.0	68.2	107.2	77.3	39.4	84.7	37.6	82.7	36.0	81.3	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.4	14.3	12.3	DB	-8.3	99.7	4.5	3.7	-11.6	102.4	-14.2	104.6	-16.7	106.7	-20.0	109.4
(5)				WB	-9.5	77.6	4.2	1.9	-12.5	79.0	-14.9	80.1	-17.2	81.2	-20.2	82.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	11.5	19.2	32.1	49.4	62.8	72.5	76.8	73.6	63.1	47.2	28.0	14.8	
	DBStd	24.33	7.29	8.67	9.59	8.74	7.49	6.20	4.68	4.70	6.55	8.31	10.05	7.41	
	HDD50	4635	1192	861	559	114	3	0	0	0	3	150	661	1092	
	HDD65	7906	1657	1281	1019	473	131	11	1	4	109	553	1110	1557	
	CDD50	3195	0	0	4	95	401	674	831	731	395	63	1	0	
	CDD65	990	0	0	0	4	64	235	366	269	51	1	0	0	
	CDH74	9564	0	0	3	92	826	2337	3492	2244	538	32	0	0	
	CDH80	3610	0	0	1	21	306	968	1430	755	126	3	0	0	
Wind	WSAvg	5.2	5.5	5.8	6.3	6.6	6.3	4.8	4.3	4.0	4.3	4.7	5.0	5.2	
Precipitation	PrecAvg	15.2	0.0	0.0	0.2	0.4	0.9	2.8	5.2	3.6	1.2	0.6	0.2	0.0	
	PrecMax	21.3	0.2	0.2	0.7	2.4	2.8	6.9	10.0	12.4	4.4	2.5	0.6	0.3	
	PrecMin	8.7	0.0	0.0	0.0	0.0	0.1	0.6	1.4	0.6	0.1	0.0	0.0	0.0	
	PrecStd	3.8	0.0	0.1	0.2	0.5	0.7	1.7	2.4	2.5	1.1	0.7	0.2	0.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.9	48.0	68.0	82.5	94.1	98.5	98.3	93.8	88.4	78.1	60.2	41.1	
		MCWB	26.2	34.5	46.4	54.7	61.2	64.8	71.3	71.8	64.6	55.6	42.9	31.2	
	2%	DB	29.7	42.2	58.7	75.8	87.9	93.4	93.6	89.9	83.5	71.3	53.4	33.5	
		MCWB	22.7	30.8	41.3	51.8	59.2	65.4	70.9	69.9	62.2	52.5	39.9	25.9	
	5%	DB	26.2	37.6	52.9	71.4	82.4	89.3	90.6	87.1	80.1	65.6	47.7	29.3	
		MCWB	20.1	28.1	38.1	49.4	57.5	65.1	69.8	68.4	60.5	48.9	36.7	22.9	
	10%	DB	22.7	33.0	48.1	66.4	77.9	85.6	87.5	84.2	76.7	61.1	42.5	25.7	
		MCWB	17.4	25.2	35.0	47.0	55.3	63.8	69.4	67.2	58.9	46.7	33.2	20.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.3	35.0	46.3	56.7	64.5	72.4	78.0	77.2	69.9	57.4	43.6	31.4
			MCDB	34.2	47.4	64.4	76.9	83.9	85.8	87.7	87.8	82.1	72.0	58.5	40.8
2%		WB	22.8	31.0	41.9	52.8	61.2	70.2	75.9	74.4	66.4	54.2	40.0	26.1	
		MCDB	29.5	41.7	57.9	72.4	80.3	82.7	85.7	83.5	76.4	67.7	52.4	33.0	
5%		WB	20.1	28.1	38.4	50.2	59.2	68.3	74.1	72.6	63.9	51.0	37.0	23.0	
		MCDB	26.0	37.5	52.5	69.9	77.5	80.1	83.7	81.3	74.8	62.7	47.3	29.0	
10%		WB	17.5	25.3	35.3	47.5	57.2	66.8	72.6	70.7	61.3	47.8	33.6	20.4	
		MCDB	22.6	33.0	47.5	64.8	74.7	78.9	82.3	79.6	72.8	59.7	41.9	25.7	
Mean Daily Temperature Range	5% DB	MDBR	16.2	18.3	20.0	21.8	21.8	19.2	17.2	18.4	21.6	20.4	17.1	15.6	
		MCDBR	20.5	23.6	27.7	30.2	30.3	26.1	22.9	22.8	27.3	28.1	24.1	20.1	
		MCWBR	15.6	16.1	16.3	15.3	12.0	8.8	7.7	8.3	11.3	14.4	14.8	14.7	
	5% WB	MCDBR	20.3	23.4	27.0	28.0	25.1	19.1	17.8	17.8	21.4	25.1	23.6	20.0	
		MCWBR	15.5	16.1	15.9	15.1	11.0	7.9	8.0	8.6	10.6	14.1	14.6	14.8	
Clear-Sky Solar Irradiance	taub	0.286	0.316	0.371	0.455	0.541	0.586	0.535	0.483	0.426	0.385	0.322	0.293		
	taud	2.272	2.209	2.094	1.907	1.754	1.760	1.942	2.050	2.116	2.121	2.217	2.226		
	Ebn at Noon	262	272	270	255	237	226	237	245	249	241	242	243		
	Edh at Noon	26	34	44	58	70	70	57	50	43	37	28	25		
All-Sky Solar Radiation	RadAvg	731	1073	1464	1793	1952	1878	1833	1759	1501	1095	720	589		
	RadStd	43	63	83	121	116	150	141	78	83	72	56	54		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	-1.66	N/A	N/A	N/A	N/A	N/A	+110	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	-1.73	N/A	N/A	N/A	N/A	N/A	+153	+92	

Nomenclature: See separate page