

LINDONG, China

WMO: 540270

Lat: 43.9687N

Lon: 119.3782E

Elev: 485

StdP: 95.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.4	-20.4	-31.7	0.2	-18.5	-29.8	0.3	-16.8	12.8	-11.4	10.3	-11.3	1.5	290	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	33.3	19.6	31.6	18.9	30.0	18.5	23.0	28.7	22.0	27.4	21.1	26.5	3.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.4	17.0	25.7	20.3	15.9	25.0	19.3	14.9	24.1	71.3	28.7	67.4	27.4	63.9	26.5	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
10.0	8.1	6.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-24.5	36.5	2.9	1.6	-26.6	37.7	-28.3	38.7	-29.9	39.6	-32.0	40.8		
			-25.0	24.9	2.7	1.3	-27.0	25.8	-28.6	26.6	-30.1	27.3	-32.0	28.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-12.1	-8.1	-1.0	8.4	15.9	20.9	23.6	21.6	15.6	7.3	-3.1	-10.5
	DBStd	13.28	4.06	4.76	5.26	4.85	4.21	3.38	2.52	2.75	3.74	4.43	5.55	4.04
	HDD10.0	2760	685	508	341	86	4	0	0	4	104	394	634	
	HDD18.3	4673	943	741	598	299	100	13	1	5	96	341	643	893
	CDD10.0	1529	0	0	2	37	186	328	421	361	173	22	1	0
	CDD18.3	401	0	0	0	1	23	92	163	108	14	0	0	0
	CDH23.3	4077	0	0	2	46	380	981	1477	958	222	12	0	0
	CDH26.7	1442	0	0	0	10	137	375	563	305	52	1	0	0
Wind	WSAvg	2.5	2.5	2.6	3.1	3.4	3.1	2.3	2.0	1.8	2.0	2.4	2.4	2.4
Precipitation	PrecAvg	370	1	2	4	8	23	69	122	88	33	13	4	1
	PrecMax	618	7	19	22	36	67	225	259	270	142	56	23	9
	PrecMin	233	0	0	0	0	1	18	46	7	0	0	0	0
	PrecStd	92	2	4	5	8	20	47	56	62	31	14	6	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.8	9.0	19.6	28.0	34.0	35.5	35.7	34.2	30.7	25.1	15.4	4.6
		MCWB	-2.9	1.5	7.2	12.1	15.7	17.9	21.4	21.2	17.0	12.5	5.9	-0.9
	2%	DB	-1.2	5.7	14.7	24.0	30.4	32.7	33.4	31.5	28.2	21.2	11.4	0.4
		MCWB	-5.1	-0.5	4.7	10.1	14.2	17.9	21.3	20.0	15.9	10.6	3.8	-3.7
	5%	DB	-3.2	2.9	11.4	21.2	27.4	30.7	31.5	29.8	25.9	18.1	8.1	-1.7
		MCWB	-6.5	-2.3	3.2	8.8	13.3	17.4	20.6	19.5	15.0	8.8	2.0	-5.1
	10%	DB	-5.2	0.3	8.4	18.4	24.8	28.7	29.8	28.2	23.9	15.5	5.3	-3.8
		MCWB	-8.0	-4.0	1.2	7.6	12.1	16.9	20.2	18.9	14.3	7.4	0.2	-6.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.9	1.7	7.7	13.0	17.3	21.8	24.8	24.1	19.7	13.5	6.4	-0.8
		MCDB	1.4	8.5	17.8	25.4	28.8	28.8	30.5	30.6	26.5	21.4	14.4	4.5
	2%	WB	-5.0	-0.4	5.2	10.9	15.4	20.4	23.5	22.6	18.1	11.5	4.0	-3.5
		MCDB	-1.4	5.5	14.4	22.6	26.1	27.6	29.6	27.8	24.1	19.6	10.8	0.2
	5%	WB	-6.5	-2.2	3.1	9.3	14.3	19.3	22.6	21.6	16.7	9.7	2.2	-5.1
		MCDB	-3.3	2.8	10.9	19.9	24.3	26.3	28.2	26.5	22.7	16.2	7.9	-1.8
	10%	WB	-8.0	-3.9	1.4	7.9	13.2	18.4	21.7	20.6	15.4	8.0	0.3	-6.6
		MCDB	-5.2	0.3	8.0	17.4	23.1	25.3	27.2	25.5	21.7	14.6	5.1	-3.8
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.9	12.1	13.1	13.1	11.6	10.3	11.4	13.6	12.4	11.0	10.4
		MCDBR	13.7	15.6	17.6	18.8	18.2	16.0	13.9	14.4	17.3	17.6	15.3	13.4
		MCWBR	10.7	11.1	10.7	9.5	7.3	5.4	4.8	5.4	7.2	8.9	9.6	10.2
	5% WB	MCDBR	13.6	15.4	16.8	17.3	14.9	11.8	10.9	10.9	14.0	15.5	15.1	13.3
		MCWBR	10.7	11.1	10.3	9.1	6.5	4.7	4.8	5.1	6.4	8.2	9.5	10.2
Clear-Sky Solar Irradiance	taub	0.281	0.317	0.367	0.440	0.519	0.558	0.511	0.470	0.417	0.373	0.314	0.286	
	taud	2.301	2.212	2.106	1.954	1.806	1.816	2.003	2.082	2.144	2.167	2.248	2.266	
	Ebn at Noon	842	864	859	821	765	736	768	787	799	782	782	790	
	Edh at Noon	82	108	138	175	209	208	171	152	132	112	86	77	
All-Sky Solar Radiation	RadAvg	2.30	3.36	4.61	5.58	6.16	5.86	5.77	5.55	4.72	3.49	2.35	1.91	
	RadStd	0.17	0.20	0.25	0.36	0.40	0.46	0.39	0.25	0.24	0.24	0.19	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.53	N/A	N/A	+0.82	N/A	N/A	N/A	N/A	+130	+75
(47)	Regional (4 neighbors)	N/A	N/A	-1.36	N/A	N/A	-0.45	N/A	N/A	+68	N/A

Nomenclature: See separate page