

SUIFENHE, China

WMO: 540960

Lat: 44.3894N

Lon: 131.1645E

Elev: 1869

StdP: 13.73

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.4	-9.0	-21.5	1.8	-10.0	-18.5	2.1	-6.9	27.0	-0.8	25.0	-2.5	10.9	270	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	83.5	68.5	80.5	67.4	77.8	66.7	72.9	79.0	71.1	76.8	69.5	74.8	7.6	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.0	122.6	76.6	69.3	115.5	74.5	67.6	108.8	72.6	38.0	79.2	36.4	76.9	34.8	74.9	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.3	21.1	18.4	DB	-16.4	88.8	4.3	2.8	-19.5	90.8	-22.0	92.4	-24.4	94.0	-27.6	96.1	(4)
			WB	-16.8	75.5	4.2	1.7	-19.8	76.7	-22.3	77.7	-24.6	78.7	-27.7	80.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	38.4	4.4	11.2	24.5	41.0	52.7	61.7	67.9	66.7	56.2	42.2	22.9	7.9	(6)
(7)		DBStd	23.75	7.51	8.87	9.65	8.53	7.22	6.19	5.08	5.07	6.30	8.28	11.14	8.79	(7)
(8)		HDD50	6039	1413	1085	792	295	53	1	0	17	264	813	1306		(8)
(9)		HDD65	9958	1878	1505	1256	721	387	133	29	41	269	706	1262	1771	(9)
(10)		CDD50	1813	0	0	0	24	137	354	554	516	204	23	1	0	(10)
(11)		CDD65	259	0	0	0	0	6	36	118	93	6	0	0	0	(11)
(12)		CDH74	1589	0	0	0	8	104	314	691	428	42	2	0	0	(12)
(13)		CDH80	291	0	0	0	1	21	61	147	59	2	0	0	0	(13)
(14)	Wind	WSAvg	7.5	9.6	9.1	8.9	8.1	7.1	5.4	5.0	5.2	5.7	7.5	8.7	9.6	(14)
(15)	Precipitation	PrecAvg	22.2	0.2	0.4	0.4	1.1	2.0	3.8	4.4	4.9	2.6	1.4	0.7	0.4	(15)
(16)		PrecMax	35.7	0.7	1.1	1.7	2.2	5.0	10.0	9.3	10.5	5.6	3.7	1.9	1.7	(16)
(17)		PrecMin	12.0	0.0	0.1	0.0	0.1	0.4	1.2	0.9	1.5	0.4	0.1	0.1	0.0	(17)
(18)		PrecStd	5.6	0.2	0.3	0.4	0.7	1.2	2.0	2.1	2.4	1.5	0.9	0.5	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.4	40.1	55.8	73.5	83.3	86.0	88.1	85.2	78.6	70.2	55.2	38.3	(19)
(20)		MCWB	25.1	31.6	41.9	52.9	59.0	65.7	71.8	72.5	64.3	54.4	43.7	32.5		(20)
(21)		2%	DB	24.1	35.5	48.4	67.2	76.6	81.2	84.2	81.4	74.4	64.3	49.1	31.0	(21)
(22)		MCWB	20.5	28.7	36.8	48.6	56.9	64.5	70.7	70.2	61.6	51.2	40.2	27.0		(22)
(23)		5%	DB	20.2	30.8	43.1	61.6	71.7	77.5	80.9	78.7	70.8	59.8	44.3	26.1	(23)
(24)		MCWB	16.9	25.7	34.1	45.9	54.7	64.1	69.9	68.6	59.9	48.4	37.3	22.7		(24)
(25)		10%	DB	15.9	26.4	38.9	56.7	67.2	74.0	77.8	76.1	67.9	55.8	39.5	21.8	(25)
(26)		MCWB	13.3	22.1	31.6	43.0	52.9	63.0	68.8	68.1	58.3	46.9	33.7	18.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	32.9	42.6	53.9	61.9	70.5	75.6	75.3	68.0	56.7	45.2	32.6	(27)
(28)		MCDWB	28.6	38.6	53.6	69.6	76.8	79.3	83.9	80.9	73.8	65.7	53.0	37.8		(28)
(29)		2%	WB	20.7	29.3	38.2	49.5	58.4	68.1	73.5	72.9	64.7	53.3	41.2	27.2	(29)
(30)		MCDWB	23.8	34.8	46.8	64.5	72.5	75.8	80.2	78.5	70.6	60.4	47.5	31.0		(30)
(31)		5%	WB	16.9	25.8	34.7	46.6	56.3	66.1	71.8	71.1	62.5	50.9	37.4	22.8	(31)
(32)		MCDWB	19.9	30.9	42.3	60.0	68.4	73.8	77.8	76.1	67.7	57.6	43.7	25.9		(32)
(33)		10%	WB	13.3	22.1	31.8	43.9	54.2	64.3	70.2	69.5	60.3	47.8	33.9	18.8	(33)
(34)		MCDWB	15.8	26.4	38.0	55.3	64.6	71.8	75.8	74.0	65.7	55.0	39.0	21.7		(34)
(35)	Mean Daily Temperature Range		MDBR	14.6	16.5	16.4	18.7	19.0	17.6	14.6	14.8	19.6	18.7	14.9	13.8	(35)
(36)		5% DB	MCDBR	19.4	21.8	21.5	27.8	28.2	24.3	20.8	18.8	23.2	25.2	20.8	18.8	(36)
(37)		MCWBR	16.6	16.8	13.1	14.4	12.7	11.1	9.3	9.1	11.5	13.8	14.0	15.7	(37)	
(38)		5% WB	MCDBR	19.5	21.4	20.9	25.7	24.2	19.8	16.7	15.5	18.0	21.2	19.8	18.0	(38)
(39)		MCWBR	16.8	17.0	13.5	14.1	12.1	10.9	9.1	8.6	10.5	13.3	14.2	15.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.304	0.347	0.425	0.522	0.543	0.526	0.494	0.454	0.410	0.425	0.360	0.316	(40)	
(41)		taud	2.141	2.032	1.901	1.757	1.777	1.904	2.060	2.167	2.203	2.014	2.095	2.110	(41)	
(42)		Ebn at Noon	250	258	251	236	236	241	248	254	255	226	223	229	(42)	
(43)		Edh at Noon	30	41	54	68	68	60	51	44	39	42	32	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	724	1077	1396	1457	1608	1704	1545	1476	1343	969	663	586	(44)	
(45)		RadStd	53	51	108	125	157	186	156	132	108	69	52	32	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page