

LINXI, China

WMO: 541150

Lat: 43.6339N

Lon: 118.0283E

Elev: 2708

StdP: 13.31

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.0	(c) -7.2	(d) -26.6	(e) 1.4	(f) -3.8	(g) -22.8	(h) 1.7	(i) -1.0	(j) 23.1	(k) 19.2	(l) 21.0	(m) 16.3	(n) 4.1	(o) 250	(p) 0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	90.2	64.6	86.8	63.5	83.8	62.7	70.5	82.2	68.6	79.7	67.0	77.5	7.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.9	109.5	75.7	65.1	102.7	74.3	63.5	96.9	72.7	36.3	82.3	34.7	80.0	33.3	77.7	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	18.8	16.5	-15.7	95.8	4.4	3.7	-18.9	98.5	-21.5	100.7	-23.9	102.8	-27.1	105.5
			-16.4	73.9	4.2	2.9	-19.4	76.1	-21.9	77.8	-24.2	79.4	-27.3	81.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.9	8.3	15.1	28.3	45.1	58.1	67.0	72.0	68.5	58.3	43.5	25.3	11.6		
	DBStd	23.83	7.82	9.36	9.99	9.60	8.11	6.32	4.95	5.14	7.05	8.75	10.77	7.96		
	HDD50	5350	1292	976	677	204	18	0	0	0	13	237	744	1189		
	HDD65	8944	1757	1396	1139	600	243	49	5	22	220	667	1192	1654		
	CDD50	2392	0	0	3	56	270	510	682	574	261	35	1	0		
	CDD65	512	0	0	0	2	29	109	222	131	18	1	0	0		
	CDH74	5200	0	0	0	52	458	1190	2020	1208	259	13	0	0		
	CDH80	1685	0	0	0	10	141	395	733	351	54	1	0	0		
(14) Wind	WSAvg	6.6	7.1	7.0	7.9	8.5	8.0	5.7	4.7	4.4	5.2	6.4	6.7	7.1		
(15) Precipitation	PrecAvg	14.5	0.0	0.1	0.2	0.4	0.9	2.2	4.8	3.6	1.5	0.5	0.1	0.0		
	PrecMax	23.7	0.3	0.4	1.1	1.3	2.1	6.1	10.5	10.9	10.4	2.6	0.6	0.2		
	PrecMin	6.9	0.0	0.0	0.0	0.0	0.0	0.5	1.5	0.4	0.0	0.0	0.0	0.0		
	PrecStd	3.9	0.1	0.1	0.3	0.4	0.6	1.3	2.4	2.6	1.8	0.6	0.1	0.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.0	46.1	65.2	80.6	90.7	92.7	95.2	92.3	86.2	75.8	58.4	40.9		
		MCWB	26.2	33.7	42.8	51.3	58.0	62.3	68.0	67.6	60.0	52.9	41.2	31.1		
	2%	DB	29.2	40.2	55.8	72.9	84.1	88.2	91.0	87.2	80.9	69.1	51.2	32.7		
		MCWB	22.1	29.4	39.0	47.9	54.7	61.6	67.3	65.0	58.3	49.3	37.4	25.1		
	5%	DB	25.4	35.8	50.5	67.6	79.1	84.6	87.1	83.8	76.9	63.6	45.9	28.1		
		MCWB	19.4	26.6	35.9	45.8	53.9	60.6	66.2	64.4	56.5	46.7	34.7	21.8		
	10%	DB	21.7	31.3	45.3	62.8	74.6	81.1	83.8	80.6	73.1	58.7	41.1	24.5		
		MCWB	16.5	23.5	32.7	43.6	51.9	59.9	65.6	63.9	55.3	44.0	31.6	19.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	34.2	43.6	53.3	60.8	68.1	73.7	71.8	65.2	55.2	42.3	30.3		
		MCDB	35.0	44.4	62.2	77.5	82.7	81.5	86.0	84.1	78.0	70.1	55.0	40.5		
	2%	WB	22.3	29.7	39.6	49.6	57.7	65.7	71.5	69.7	61.8	51.2	37.9	25.2		
		MCDB	28.9	39.9	54.8	69.5	76.9	79.2	83.6	81.4	74.1	66.0	50.4	32.5		
	5%	WB	19.5	26.6	36.2	46.8	55.6	64.0	69.7	67.9	59.4	48.1	34.9	21.8		
		MCDB	25.3	35.4	49.9	65.1	73.8	77.3	80.8	78.2	71.9	60.7	45.6	27.9		
	10%	WB	16.5	23.6	32.8	44.3	53.5	62.5	68.1	66.2	57.3	45.1	31.9	19.2		
		MCDB	21.6	31.1	44.7	61.7	71.7	75.1	78.9	75.9	69.4	57.2	40.6	24.3		
(35) Mean Daily Temperature Range	MDBR		19.0	20.4	20.6	22.5	22.8	20.9	19.4	20.8	23.0	21.0	18.3	17.6		
	5% DB	MCDBR	23.9	25.2	28.6	31.2	31.0	27.8	26.2	26.6	29.9	28.6	24.0	22.0		
		MCWBR	18.6	17.8	17.3	15.3	12.7	9.8	8.9	10.1	12.3	14.2	14.8	16.5		
	5% WB	MCDBR	23.8	25.0	28.1	28.7	24.7	20.8	20.4	20.6	24.1	26.2	23.4	21.8		
		MCWBR	18.7	17.8	17.0	14.9	11.0	8.6	8.9	9.2	11.3	14.2	14.7	16.5		
(40) Clear-Sky Solar Irradiance	taub		0.271	0.310	0.357	0.417	0.486	0.519	0.477	0.449	0.402	0.359	0.299	0.276		
	taud		2.321	2.218	2.119	2.011	1.879	1.893	2.079	2.123	2.176	2.208	2.293	2.287		
	Ebn at Noon		273	278	276	268	252	244	253	256	259	255	257	257		
	Edh at Noon		26	34	43	52	62	61	50	47	41	34	26	24		
(44) All-Sky Solar Radiation	RadAvg		751	1101	1492	1794	1982	1875	1851	1759	1505	1115	766	616		
	RadStd		58	61	96	120	133	152	107	75	80	75	52	53		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	-2.36	-2.74	+1.35	N/A	-0.99	N/A	N/A	N/A	N/A	
(47) Regional (5 neighbors)		N/A	N/A	-2.57	N/A	N/A	-0.83	N/A	N/A	+104	N/A	

Nomenclature: See separate page