

LINXI, China

WMO: 541150

Lat: 43.6339N

Lon: 118.0283E

Elev: 825

StdP: 91.79

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.9	-21.8	-32.5	0.2	-19.9	-30.5	0.2	-18.3	10.3	-7.1	9.4	-8.7	1.8	250	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	32.3	18.1	30.5	17.5	28.8	17.1	21.4	27.9	20.4	26.5	19.5	25.3	3.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	15.6	24.3	18.4	14.7	23.5	17.5	13.8	22.6	66.5	27.9	62.7	26.7	59.5	25.4	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.4	7.4	-26.5	35.5	2.4	2.1	-28.3	36.9	-29.7	38.2	-31.1	39.3	-32.8	40.8		
(5)			-26.9	23.3	2.3	1.6	-28.6	24.5	-29.9	25.4	-31.2	26.4	-32.9	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-13.1	-9.4	-2.1	7.3	14.5	19.4	22.2	20.3	14.6	6.4	-3.7	-11.3	(6)
(7)		DBStd	13.24	4.35	5.20	5.55	5.33	4.50	3.51	2.75	2.85	3.91	4.86	5.98	4.42	(7)
(8)		HDD10.0	2972	718	542	376	113	10	0	0	0	7	132	413	661	(8)
(9)		HDD18.3	4969	976	776	633	333	135	27	3	12	122	371	662	919	(9)
(10)		CDD10.0	1329	0	0	2	31	150	283	379	319	145	19	1	0	(10)
(11)		CDD18.3	284	0	0	0	1	16	61	123	73	10	1	0	0	(11)
(12)		CDH23.3	2889	0	0	0	29	254	661	1122	671	144	7	0	0	(12)
(13)		CDH26.7	936	0	0	0	6	78	219	407	195	30	1	0	0	(13)
(14)	Wind	WSAvg	2.9	3.2	3.1	3.5	3.8	3.6	2.5	2.1	2.0	2.3	2.9	3.0	3.2	(14)
(15)	Precipitation	PrecAvg	368	1	2	6	10	23	57	123	92	37	12	3	1	(15)
(16)		PrecMax	603	8	11	29	32	54	156	266	277	263	65	16	5	(16)
(17)		PrecMin	176	0	0	0	0	0	13	37	10	0	0	0	0	(17)
(18)		PrecStd	100	2	3	7	10	15	33	60	67	46	15	3	1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.7	7.8	18.4	27.0	32.6	33.7	35.1	33.5	30.1	24.3	14.7	4.9	(19)
(20)			MCWB	-3.2	1.0	6.0	10.7	14.4	16.8	20.0	19.8	15.6	11.6	5.1	-0.5	(20)
(21)		2%	DB	-1.6	4.5	13.2	22.7	28.9	31.2	32.8	30.7	27.1	20.6	10.6	0.4	(21)
(22)			MCWB	-5.5	-1.4	3.9	8.8	12.6	16.4	19.6	18.3	14.6	9.6	3.0	-3.9	(22)
(23)		5%	DB	-3.7	2.1	10.3	19.8	26.2	29.2	30.6	28.8	24.9	17.5	7.7	-2.2	(23)
(24)			MCWB	-7.0	-3.0	2.1	7.6	12.2	15.9	19.0	18.0	13.6	8.2	1.5	-5.7	(24)
(25)		10%	DB	-5.7	-0.4	7.4	17.1	23.7	27.3	28.8	27.0	22.8	14.8	5.0	-4.2	(25)
(26)			MCWB	-8.6	-4.7	0.4	6.5	11.1	15.5	18.7	17.7	13.0	6.7	-0.2	-7.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.0	1.2	6.5	11.8	16.0	20.0	23.2	22.1	18.4	12.9	5.7	-0.9	(27)
(28)			MCD B	1.6	6.9	16.8	25.3	28.2	27.5	30.0	29.0	25.5	21.2	12.8	4.7	(28)
(29)		2%	WB	-5.4	-1.3	4.2	9.8	14.3	18.7	21.9	21.0	16.5	10.7	3.3	-3.8	(29)
(30)			MCD B	-1.7	4.4	12.7	20.8	25.0	26.2	28.7	27.5	23.4	18.9	10.2	0.3	(30)
(31)		5%	WB	-7.0	-3.0	2.3	8.2	13.1	17.8	21.0	20.0	15.2	9.0	1.6	-5.6	(31)
(32)			MCD B	-3.7	1.9	9.9	18.4	23.2	25.2	27.1	25.6	22.2	15.9	7.6	-2.3	(32)
(33)		10%	WB	-8.6	-4.7	0.5	6.8	12.0	16.9	20.1	19.0	14.1	7.3	-0.1	-7.1	(33)
(34)			MCD B	-5.8	-0.5	7.0	16.5	22.0	24.0	26.1	24.4	20.8	14.0	4.8	-4.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.6	11.3	11.5	12.5	12.7	11.6	10.8	11.5	12.8	11.7	10.2	9.8	(35)
(36)			MCDBR	13.3	14.0	15.9	17.3	17.2	15.5	14.5	14.8	16.6	15.9	13.3	12.2	(36)
(37)			MCWBR	10.4	9.9	9.6	8.5	7.0	5.5	4.9	5.6	6.8	7.9	8.2	9.2	(37)
(38)		5% WB	MCD BR	13.2	13.9	15.6	15.9	13.7	11.6	11.3	11.4	13.4	14.5	13.0	12.1	(38)
(39)			MCWBR	10.4	9.9	9.5	8.3	6.1	4.8	4.9	5.1	6.3	7.9	8.2	9.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.271	0.310	0.357	0.417	0.486	0.519	0.477	0.449	0.402	0.359	0.299	0.276	(40)	
(41)		taud	2.321	2.218	2.119	2.011	1.879	1.893	2.079	2.123	2.176	2.208	2.293	2.287	(41)	
(42)		Ebn at Noon	862	875	871	844	794	768	798	806	816	803	811	811	(42)	
(43)		Edh at Noon	81	108	136	165	195	193	158	147	128	108	83	76	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.37	3.47	4.70	5.66	6.25	5.91	5.83	5.54	4.74	3.52	2.41	1.94	(44)	
(45)		RadStd	0.18	0.19	0.30	0.38	0.42	0.48	0.34	0.24	0.25	0.24	0.17	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	-1.31	-1.52	+0.75	N/A	-0.55	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	-1.43	N/A	N/A	-0.46	N/A	N/A	+58	N/A

Nomenclature: See separate page