

DUOLUN, China

WMO: 542080

Lat: 42.1939N

Lon: 116.4664E

Elev: 1247

StdP: 87.21

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.4	-25.2	-31.8	0.2	-24.3	-29.8	0.3	-23.5	11.7	-12.3	10.5	-13.8	1.8	270	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	29.4	16.6	27.7	16.1	26.2	15.9	20.1	25.4	19.1	23.9	18.2	22.9	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	15.5	22.6	17.5	14.6	21.7	16.6	13.8	20.8	63.9	25.4	60.2	24.0	57.0	22.9	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.0	7.8	-31.3	32.1	3.1	2.1	-33.5	33.6	-35.4	34.8	-37.1	36.0	-39.4	37.5		
(5)			-31.5	21.2	3.1	1.1	-33.7	22.0	-35.5	22.6	-37.2	23.3	-39.5	24.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-15.9	-11.5	-3.1	5.4	11.9	16.8	19.8	18.0	12.4	4.6	-5.2	-13.3	(6)
(7)		DBStd	13.10	5.03	5.73	5.65	5.01	4.19	3.05	2.47	2.69	3.76	4.69	5.82	4.95	(7)
(8)		HDD10.0	3367	804	601	407	153	28	1	0	0	19	176	454	723	(8)
(9)		HDD18.3	5561	1062	834	665	389	204	63	12	39	180	427	704	981	(9)
(10)		CDD10.0	957	0	0	1	15	86	206	304	247	91	8	0	0	(10)
(11)		CDD18.3	109	0	0	0	0	4	18	58	27	2	0	0	0	(11)
(12)		CDH23.3	1247	0	0	0	7	105	269	527	292	47	1	0	0	(12)
(13)		CDH26.7	274	0	0	0	0	22	57	136	54	6	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.1	3.2	3.9	4.0	3.7	2.7	2.3	2.1	2.4	3.1	3.3	3.4	(14)
(15)	Precipitation	PrecAvg	366	2	3	7	15	28	60	104	87	39	15	5	2	(15)
(16)		PrecMax	513	12	13	25	76	69	156	177	243	84	53	14	7	(16)
(17)		PrecMin	258	0	0	0	0	3	23	12	24	12	0	0	0	(17)
(18)		PrecStd	70	2	3	5	15	15	32	43	45	20	12	4	1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.6	7.0	16.0	24.4	29.2	30.5	32.4	30.6	27.2	21.3	12.3	2.6	(19)
(20)			MCWB	-3.7	0.3	5.3	10.1	13.0	14.9	18.9	17.6	14.3	10.4	3.9	-2.4	(20)
(21)		2%	DB	-2.8	3.5	12.2	21.1	26.1	28.3	29.9	28.0	24.5	18.3	8.9	-0.7	(21)
(22)			MCWB	-6.1	-1.7	3.2	8.3	11.9	15.0	18.0	17.2	13.5	8.9	2.5	-4.2	(22)
(23)		5%	DB	-5.3	0.9	9.2	18.1	23.8	26.4	28.0	26.4	22.6	15.7	6.1	-3.3	(23)
(24)			MCWB	-7.8	-3.3	1.6	6.8	10.8	14.6	17.5	16.5	12.4	7.3	1.0	-6.0	(24)
(25)		10%	DB	-7.6	-1.6	6.4	15.3	21.4	24.6	26.3	24.8	20.6	13.2	3.5	-5.4	(25)
(26)			MCWB	-9.5	-4.9	0.0	5.7	10.0	14.1	17.3	16.4	11.9	6.1	-0.4	-7.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.6	0.9	5.9	11.6	15.0	18.7	21.6	21.0	17.2	11.7	5.1	-1.8	(27)
(28)			MCDWB	0.2	5.6	14.7	20.4	23.4	24.8	27.6	26.4	22.6	18.1	9.9	2.4	(28)
(29)		2%	WB	-5.9	-1.3	3.8	9.1	13.3	17.4	20.5	19.8	15.5	9.9	2.9	-4.1	(29)
(30)			MCDWB	-3.1	3.1	11.2	18.4	22.5	23.6	26.2	24.7	20.6	16.1	8.2	-1.0	(30)
(31)		5%	WB	-7.7	-3.2	1.9	7.7	12.2	16.5	19.7	18.8	14.2	8.3	1.3	-5.9	(31)
(32)			MCDWB	-5.4	0.9	8.5	16.5	20.3	22.6	24.7	23.2	19.7	14.0	5.7	-3.3	(32)
(33)		10%	WB	-9.5	-5.0	0.3	6.3	11.0	15.6	18.8	17.7	13.1	6.9	-0.4	-7.6	(33)
(34)			MCDWB	-7.5	-1.7	6.2	14.2	18.7	21.7	23.5	22.0	18.7	11.9	3.5	-5.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	12.5	12.4	13.2	13.9	12.7	11.5	12.1	13.4	12.6	11.1	10.5	(35)
(36)			MCDBR	13.8	15.4	16.3	18.2	18.4	16.4	15.1	15.1	16.8	16.9	14.0	13.4	(36)
(37)			MCWBR	11.2	11.1	9.5	8.6	7.5	5.9	5.3	5.9	7.1	8.6	8.7	10.6	(37)
(38)		5% WB	MCDWB	13.7	15.1	15.5	15.9	15.1	12.5	11.4	11.5	13.5	14.6	13.1	13.2	(38)
(39)			MCWBR	11.2	11.0	9.2	8.1	6.5	5.3	4.8	5.3	6.5	8.1	8.4	10.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.275	0.326	0.368	0.427	0.482	0.533	0.495	0.475	0.429	0.374	0.304	0.284	(40)	
(41)		taud	2.312	2.162	2.076	1.973	1.879	1.830	1.991	2.014	2.063	2.139	2.281	2.284	(41)	
(42)		Ebn at Noon	870	863	866	839	801	759	785	786	793	793	819	818	(42)	
(43)		Edh at Noon	85	117	144	173	196	206	174	165	145	119	87	80	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.46	3.50	4.86	5.74	6.43	6.08	5.87	5.55	4.75	3.64	2.55	2.07	(44)	
(45)		RadStd	0.20	0.27	0.35	0.43	0.39	0.44	0.29	0.30	0.26	0.22	0.19	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	-1.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	-1.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page