

BAOGUOTUXIANG, China

WMO: 542260

Lat: 42.3167N

Lon: 120.6856E

Elev: 1316

StdP: 14.01

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.4	(c) -1.3	(d) -25.6	(e) 1.4	(f) 6.0	(g) -21.5	(h) 1.8	(i) 7.1	(j) 22.3	(k) 12.4	(l) 19.6	(m) 11.6	(n) 3.9	(o) 0	(p) 0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	90.7	67.8	87.7	67.8	85.2	67.1	75.8	83.6	74.0	81.1	72.3	79.3	8.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	130.8	80.3	71.8	123.5	78.7	70.0	116.0	76.9	40.4	84.2	38.7	81.1	37.1	79.4	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	17.0	15.2	-8.8	96.4	4.3	4.1	-11.9	99.3	-14.4	101.7	-16.9	104.0	-20.0	106.9
			-9.8	78.1	4.0	2.2	-12.7	79.6	-15.0	80.9	-17.3	82.1	-20.2	83.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	13.2	20.4	33.2	49.4	62.1	70.6	74.9	71.8	62.1	47.6	29.8	16.8	(6)
(7)		DBStd	22.97	7.46	8.57	9.43	8.97	7.36	5.49	4.16	4.78	6.28	8.14	10.05	7.59	(7)
(8)		HDD50	4399	1139	829	526	116	5	0	0	0	4	142	609	1029	(8)
(9)		HDD65	7687	1604	1249	985	473	142	13	0	6	124	541	1056	1494	(9)
(10)		CDD50	2984	0	0	6	99	380	617	771	676	365	68	2	0	(10)
(11)		CDD65	797	0	0	0	5	52	180	306	217	36	1	0	0	(11)
(12)		CDH74	7155	0	0	3	88	706	1692	2480	1715	449	22	0	0	(12)
(13)		CDH80	2267	0	0	0	19	232	610	835	491	77	3	0	0	(13)
(14)	Wind	WSAvg	6.3	6.5	7.0	7.9	8.3	7.4	5.7	5.1	4.4	4.9	5.9	6.2	6.5	(14)
(15)	Precipitation	PrecAvg	16.5	0.0	0.1	0.2	0.7	1.5	3.0	4.9	3.5	1.6	0.7	0.2	0.1	(15)
(16)		PrecMax	24.4	0.2	0.9	2.0	2.4	4.2	5.8	12.8	10.2	4.8	2.9	0.5	0.5	(16)
(17)		PrecMin	11.4	0.0	0.0	0.0	0.0	0.1	1.0	1.0	0.1	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.7	0.0	0.2	0.4	0.6	0.9	1.3	2.5	2.2	1.2	0.6	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.7	50.0	70.6	82.6	91.7	95.2	94.1	91.7	85.6	77.6	62.4	44.0	(19)
MCWB			28.9	35.4	46.6	54.6	60.2	65.0	73.1	71.6	65.0	57.7	45.3	33.1	(20)	
2%		DB	33.5	45.0	60.9	75.8	86.1	90.0	90.3	87.5	82.1	71.3	55.6	37.8	(21)	
		MCWB	25.1	32.7	42.3	52.0	58.0	64.6	71.7	70.3	62.3	53.5	41.6	29.2	(22)	
5%		DB	29.7	40.2	54.9	71.1	81.6	86.7	87.5	85.1	79.2	66.7	50.6	33.3	(23)	
		MCWB	22.5	29.9	39.1	49.5	57.2	64.1	70.9	69.8	60.9	51.3	39.4	25.9	(24)	
10%		DB	26.0	35.6	49.9	66.1	77.2	83.2	84.8	82.6	76.2	62.5	45.7	29.7	(25)	
		MCWB	19.8	26.9	36.2	46.9	55.0	63.2	70.2	68.9	60.0	48.8	35.8	23.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.6	36.6	47.8	58.2	65.3	72.8	78.5	77.4	70.2	60.6	47.7	34.5	(27)
MDCB			38.7	47.3	68.5	74.5	81.0	82.9	88.4	85.6	79.3	70.5	57.2	41.8	(28)	
2%		WB	25.5	32.9	43.4	54.6	62.2	70.0	76.5	75.4	66.9	56.8	43.2	29.4	(29)	
		MDCB	33.3	44.0	58.8	71.1	77.7	80.8	85.0	82.7	76.5	67.3	54.2	37.5	(30)	
5%		WB	22.6	30.3	39.7	51.2	59.8	68.2	74.9	73.7	64.7	53.9	39.7	25.9	(31)	
		MDCB	29.6	40.1	54.2	67.0	74.5	78.6	82.3	80.0	73.9	63.4	50.0	33.1	(32)	
10%		WB	19.8	27.2	36.7	48.5	57.5	66.6	73.3	71.9	62.5	50.7	36.1	23.3	(33)	
		MDCB	25.8	35.5	49.1	63.9	72.8	76.4	80.3	78.4	72.2	60.8	45.1	29.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.4	19.7	20.9	21.8	22.1	19.4	16.6	18.4	23.3	22.1	19.4	18.0	(35)
MCDBR			24.7	26.3	29.8	30.8	30.0	26.1	21.9	22.2	28.6	28.8	26.6	24.0	(36)	
MCWBR			18.6	18.2	17.2	15.0	11.6	8.8	8.0	9.2	12.1	14.9	16.2	17.5	(37)	
5% WB		MCDBR	24.4	26.5	27.9	26.3	23.6	19.5	16.9	16.7	22.1	24.5	25.7	24.1	(38)	
		MCWBR	18.5	18.4	16.6	13.8	11.0	8.4	8.0	8.5	10.9	14.4	16.1	17.8	(39)	
																(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.361	0.414	0.508	0.572	0.645	0.616	0.539	0.482	0.442	0.359	0.316	(40)	
taud		2.216	2.066	1.962	1.785	1.704	1.631	1.744	1.904	1.959	1.964	2.109	2.187	(41)		
Ebn at Noon		259	259	258	242	231	214	219	232	235	226	233	242	(42)		
Edh at Noon		30	41	51	66	74	80	71	58	51	45	33	28	(43)		
(44)	All-Sky Solar Radiation	RadAvg	776	1082	1459	1735	1932	1805	1743	1679	1483	1111	782	662	(44)	
(45)		RadStd	56	63	89	101	141	137	133	99	67	69	58	46	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-2.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	-1.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page