

BAOGUOTUXIANG, China

WMO: 542260

Lat: 42.3167N

Lon: 120.6856E

Elev: 401

StdP: 96.60

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -20.2	(c) -18.5	(d) -32.0	(e) 0.2	(f) -14.5	(g) -29.7	(h) 0.3	(i) -13.8	(j) 10.0	(k) -10.9	(l) 8.7	(m) -11.4	(n) 1.7	(o) 0	(p) 0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.2	(c) 32.6	(d) 19.9	(e) 31.0	(f) 19.9	(g) 29.6	(h) 19.5	(i) 24.3	(j) 28.7	(k) 23.3	(l) 27.3	(m) 22.4	(n) 26.3	(o) 3.7	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	18.7	26.8	22.1	17.6	25.9	21.1	16.6	25.0	76.2	29.0	72.1	27.3	68.3	26.3	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.6	(b) 7.6	(c) 6.8	(e) -22.7	(f) 35.8	(g) 2.4	(h) 2.3	(i) -24.4	(j) 37.4	(k) -25.8	(l) 38.7	(m) -27.1	(n) 40.0	(o) -28.9	(p) 41.6		
(a) 8.6	(b) 7.6	(c) 6.8	(e) -23.2	(f) 25.6	(g) 2.2	(h) 1.2	(i) -24.8	(j) 26.4	(k) -26.1	(l) 27.1	(m) -27.4	(n) 27.8	(o) -29.0	(p) 28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-10.4	-6.5	0.7	9.7	16.7	21.4	23.8	22.1	16.7	8.7	-1.2	-8.4		
	DBStd	12.76	4.15	4.76	5.24	4.98	4.09	3.05	2.31	2.66	3.49	4.52	5.58	4.22		
	HDD10.0	2444	633	461	292	64	3	0	0	0	2	79	338	572		
	HDD18.3	4271	891	694	547	263	79	7	0	3	69	301	587	830		
	CDD10.0	1658	0	0	3	55	211	343	428	376	203	38	1	0		
	CDD18.3	443	0	0	0	3	29	100	170	121	20	1	0	0		
	CDH23.3	3975	0	0	2	49	392	940	1378	953	249	12	0	0		
	CDH26.7	1259	0	0	0	11	129	339	464	273	43	2	0	0		
(14) Wind	WSAvg	2.8	2.9	3.1	3.5	3.7	3.3	2.5	2.3	1.9	2.2	2.6	2.8	2.9		
(15) Precipitation	PrecAvg	420	1	3	6	17	38	77	125	89	41	18	4	2		
	PrecMax	619	5	23	51	61	106	147	325	258	122	74	13	13		
	PrecMin	290	0	0	0	0	3	25	25	2	0	0	0	0		
	PrecStd	94	1	4	10	15	24	34	63	56	31	15	4	3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.3	10.0	21.4	28.1	33.2	35.1	34.5	33.2	29.8	25.3	16.9	6.6		
		MCWB	-1.7	1.9	8.1	12.5	15.7	18.3	22.8	22.0	18.3	14.3	7.4	0.6		
	2%	DB	0.8	7.2	16.0	24.3	30.0	32.2	32.4	30.8	27.8	21.8	13.1	3.2		
		MCWB	-3.8	0.4	5.7	11.1	14.5	18.1	22.1	21.3	16.8	11.9	5.3	-1.6		
	5%	DB	-1.3	4.6	12.7	21.7	27.6	30.4	30.8	29.5	26.2	19.3	10.3	0.7		
		MCWB	-5.3	-1.2	3.9	9.7	14.0	17.8	21.6	21.0	16.1	10.7	4.1	-3.4		
	10%	DB	-3.3	2.0	9.9	19.0	25.1	28.5	29.3	28.1	24.5	16.9	7.6	-1.3		
		MCWB	-6.8	-2.8	2.3	8.3	12.8	17.3	21.2	20.5	15.6	9.3	2.1	-4.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.3	2.6	8.8	14.5	18.5	22.7	25.9	25.2	21.2	15.9	8.7	1.4		
		MCDB	3.7	8.5	20.3	23.6	27.2	28.3	31.3	29.8	26.3	21.4	14.0	5.5		
	2%	WB	-3.6	0.5	6.3	12.6	16.8	21.1	24.7	24.1	19.4	13.8	6.2	-1.4		
		MCDB	0.7	6.7	14.9	21.7	25.4	27.1	29.4	28.2	24.7	19.6	12.4	3.0		
	5%	WB	-5.2	-0.9	4.3	10.6	15.4	20.1	23.8	23.1	18.2	12.2	4.3	-3.4		
		MCDB	-1.3	4.5	12.3	19.5	23.6	25.9	28.0	26.7	23.3	17.4	10.0	0.6		
	10%	WB	-6.8	-2.7	2.6	9.2	14.2	19.2	22.9	22.2	16.9	10.4	2.3	-4.8		
		MCDB	-3.4	1.9	9.5	17.7	22.7	24.7	26.8	25.8	22.3	16.0	7.3	-1.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	11.0	11.6	12.1	12.3	10.8	9.2	10.2	12.9	12.3	10.8	10.0		
		MCDBR	13.7	14.6	16.5	17.1	16.6	14.5	12.2	12.3	15.9	16.0	14.8	13.4		
		MCWBR	10.3	10.1	9.6	8.3	6.4	4.9	4.4	5.1	6.7	8.3	9.0	9.7		
		MCDBR	13.6	14.7	15.5	14.6	13.1	10.8	9.4	9.3	12.3	13.6	14.3	13.4		
	5% WB	MCWBR	10.3	10.2	9.2	7.7	6.1	4.7	4.4	4.7	6.1	8.0	8.9	9.9		
(40) Clear-Sky Solar Irradiance	taub		0.307	0.361	0.414	0.508	0.572	0.645	0.616	0.539	0.482	0.442	0.359	0.316		
	taud		2.216	2.066	1.962	1.785	1.704	1.631	1.744	1.904	1.959	1.964	2.109	2.187		
	Ebn at Noon		816	816	814	764	727	675	690	732	741	711	733	762		
	Edh at Noon		94	129	162	209	233	252	223	184	162	142	104	89		
(44) All-Sky Solar Radiation	RadAvg		2.44	3.41	4.60	5.47	6.09	5.69	5.49	5.29	4.67	3.50	2.46	2.09		
	RadStd		0.18	0.20	0.28	0.32	0.44	0.43	0.42	0.31	0.21	0.22	0.18	0.14		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-1.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	-1.08	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page