

JINZHOU, China

WMO: 543370

Lat: 41.1402N

Lon: 121.1224E

Elev: 230

StdP: 14.57

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.3	6.8	-21.2	1.7	13.0	-17.1	2.2	14.7	18.1	24.3	16.2	23.4	3.6	20	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	89.9	71.8	87.5	71.3	85.4	71.0	78.4	84.0	77.0	82.3	75.6	80.7	8.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.9	141.1	82.1	75.4	134.3	80.5	73.9	127.7	79.2	42.3	84.0	40.8	82.4	39.4	80.7	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	16.5	14.4	DB	0.4	94.7	4.7	3.5	-3.0	97.2	-5.7	99.3	-8.4	101.2	-11.8	103.8	(4)
(5)			WB	-1.3	80.7	4.4	1.9	-4.4	82.1	-7.0	83.2	-9.4	84.2	-12.6	85.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	19.8	26.9	38.6	52.9	65.0	72.3	77.7	76.6	67.9	54.1	36.9	24.0		
	DBStd	21.36	7.07	7.42	7.70	6.61	5.83	4.62	3.68	4.02	5.42	7.58	9.23	7.34		
	HDD50	3246	935	648	362	45	0	0	0	0	0	47	402	807		
	HDD65	6218	1400	1068	820	364	72	3	0	0	33	342	844	1272		
	CDD50	3675	0	0	7	133	465	670	858	823	537	174	8	0		
	CDD65	1174	0	0	0	2	72	223	393	359	120	5	0	0		
	CDH74	8831	0	0	0	25	553	1482	3197	2877	680	17	0	0		
	CDH80	2459	0	0	0	5	117	441	970	821	104	1	0	0		
(14) Wind	WSAvg	6.2	4.8	6.0	7.2	7.9	7.5	6.7	6.4	5.6	5.6	5.8	5.7	4.9		
(15) Precipitation	PrecAvg	22.9	0.1	0.2	0.3	1.1	1.7	3.3	7.0	5.2	2.5	1.1	0.3	0.1		
	PrecMax	44.6	0.7	1.2	1.1	5.5	4.3	10.9	22.3	12.1	7.6	3.1	1.2	1.0		
	PrecMin	13.7	0.0	0.0	0.0	0.2	0.5	0.4	1.1	0.9	0.1	0.0	0.0	0.0		
	PrecStd	6.6	0.2	0.2	0.3	1.1	1.1	2.1	4.6	3.1	2.0	0.9	0.3	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.1	50.1	66.0	76.9	87.8	93.4	93.9	92.6	85.8	76.2	62.6	47.1		
		MCWB	31.4	37.2	48.4	53.7	61.2	68.0	74.6	75.0	68.1	60.9	50.5	40.6		
	2%	DB	36.9	45.1	59.1	71.9	83.2	88.2	90.1	88.8	82.9	72.2	58.3	42.4		
		MCWB	29.1	34.8	44.0	51.9	60.1	66.8	74.3	73.1	66.5	59.1	49.0	35.4		
	5%	DB	33.5	41.1	54.4	68.1	79.8	84.9	87.6	86.6	80.5	69.1	54.8	38.7		
		MCWB	27.5	33.1	41.6	50.5	58.8	66.0	73.3	72.9	65.0	57.3	46.6	32.2		
	10%	DB	30.6	37.8	50.4	64.5	76.7	81.8	85.2	84.5	78.0	66.1	51.1	35.4		
		MCWB	25.1	30.8	39.0	48.8	57.6	65.2	73.0	72.7	64.5	55.5	43.2	29.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.5	39.4	49.5	58.5	66.9	73.0	80.8	80.5	75.3	67.0	55.8	43.7		
		MCDB	37.9	45.8	61.5	68.4	80.7	82.2	88.5	86.6	80.4	71.6	58.6	44.8		
	2%	WB	30.3	36.4	46.1	55.8	64.3	71.5	78.7	78.6	72.0	64.0	51.1	36.7		
		MCDB	35.4	42.5	56.7	66.1	77.4	80.8	84.9	83.6	77.6	68.6	56.1	40.9		
	5%	WB	27.8	34.1	43.0	53.4	62.4	70.3	77.4	77.2	70.1	60.9	47.6	32.7		
		MCDB	33.4	40.2	52.2	62.9	73.5	78.1	82.9	82.3	75.7	65.9	53.3	38.0		
	10%	WB	25.2	31.6	40.2	51.2	60.5	69.0	76.0	75.8	68.3	58.3	43.5	29.5		
		MCDB	30.5	37.4	48.5	61.0	70.5	76.6	81.2	81.0	74.5	63.8	50.4	35.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.7	15.9	16.6	17.2	17.6	14.4	12.1	13.6	17.2	17.6	15.8	15.2		
		MCDBR	19.4	20.1	21.9	23.2	23.3	20.8	16.5	16.7	19.8	20.3	20.2	18.6		
	5% WB	MCWBR	14.0	13.2	12.3	10.8	9.6	7.4	6.4	6.8	8.5	11.2	13.5	13.9		
		MCWBR	18.9	18.4	20.7	18.3	18.7	14.5	12.0	12.1	14.8	15.7	18.1	17.8		
(40) Clear-Sky Solar Irradiance	taub		0.359	0.432	0.480	0.584	0.630	0.730	0.718	0.625	0.556	0.538	0.435	0.373		
	taud		2.098	1.918	1.857	1.691	1.646	1.525	1.591	1.752	1.832	1.791	1.971	2.089		
	Ebn at Noon		239	235	239	224	218	197	197	212	216	198	206	221		
	Edh at Noon		35	49	58	74	79	89	83	69	59	55	40	33		
(44) All-Sky Solar Radiation	RadAvg		755	1021	1445	1684	1893	1697	1574	1563	1424	1069	764	653		
	RadStd		64	72	90	104	153	155	149	110	84	68	72	49		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days					
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	-3.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+99	(46)
(47)	Regional (4 neighbors)	N/A	N/A	-1.96	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page